

ANNEX 3

(Item 3.2)

DECISIONS ON COMMENTS RECEIVED THROUGH MANAK MANTAN ON IS 4992: 2024 - DOOR HANDLES FOR MORTICE LOCKS - SPECIFICATION (*Second Revision*)

Sl. No.	Clause/Sub-clause/Para No.	Commentator	Comments/ Suggestions	Reasons/Justifications for the Proposed Changes	Decision of the Committee
(1)	(2)	(3)	(4)	(5)	(6)
1	4.4 Dimensional Details	MANAK MANTAN	For reference purpose, centre distance of handle cover plate (see 3.1) are given in Table 1.	Centre distance of handle cover plate (see 3.1) are given in Table 1 for reference purpose only and Not Restricted and compulsory. Manufacturer can make their own centre distance.	Decided to keep these dimensions as reference purpose only.
2	8.1 Marking	MANAK MANTAN	Each door handle/door knob for mortice lock shall be legibly and indelibly marked with the following information a) Manufacturer's name or trade-mark; and b) Classification as per 5	Door Handles are combination of Back Plate & Roses / Escutcheon. In case of Plate Classification as per 5 is feasible. But in Case of Rose it may not be feasible as space is very less to punch the classification grade. In that case what to be done.	The comment is related to the Certification matter also. Inputs may be asked from the concerned department of BIS.

Sl. No.	Clause/Sub-clause/Para No.	Commentator	Comments/ Suggestions	Reasons/Justifications for the Proposed Changes	Decision of the Committee
(1)	(2)	(3)	(4)	(5)	(6)
3	9.1 Packing	MANAK MANTAN	The door handles for mortice lock shall be suitably packed in cartons. Each carton shall be legibly and indelibly marked	ISI mark is for Handle only. If Only Handle set packed in box then it is O.K. to Mark ISI and CML number on Packing box. Now a days Most of the delivery is in Comboset packing box. Comboset means - One handle Set + One Mortise Lock + One Mortise Cylinder	The comment is related to the Certification matter also. Inputs may be asked from the concerned department of BIS.