

केन्द्रीय मुहर विभाग - III

हमारा संदर्भ- केन्द्रीय मुहर विभाग-3/16: IS 10617

दिनांक :14 12 2018

विषय: अनुपालन हेतु ग्रुपिंग गाईडलाईन

सभी शाखा कार्यालय से आग्रह है कि एस आई टी का अनुपालन तत्काल प्रभाव से सुनिश्चित करें।

(अमित कुमार)
वैज्ञानिक 'सी' (सी एम डी-III)

प्रमुख (सी एम डी-III)

सभी क्षेत्रीय/शाखा कार्यालय
आई टी एस विभाग – बीआईएस इंटरनेट पर अपलोड करने हेतू

CENTRAL MARKS DEPARTMENT-III

Our Ref: CMD-III/16:10617

14 12 2018

Subject: Grouping Guidelines for the certification of Hermetic Compressors as per IS 10617: 2013

This has reference to the subject mentioned above.

BOs may kindly ensure implementation of the Grouping Guidelines with immediate effect.

Amit Kumar
Sc. C (CMD III)

Head (CMD - III)

Circulated to: All ROs/BOs

केन्द्रीय मुहर विभाग -III (CENTRAL MARKS DEPARTMENT-III)

Our Ref: CMD-III/16:10617

14 12 2018

Subject: Grouping Guidelines for the certification of Hermetic Compressors as per IS 10617:2013

1 .The parameters given below shall be considered for grouping of Hermetic Compressors as per IS 10617:2013 for GoL/CSoL:

(a)	Category	(i) Low back pressure (LBP), (ii) Commercial back pressure (CBP) / Medium back pressure (MBP) (iii) High back pressure (HBP)
(b)	No.of phase	(i)Single phase (ii)Three phase

2. The Firm shall declare the varieties of Hermetic Compressors intended to be covered in the Licence.
3. The highest cooling capacity from each category (LBP/MBP/HBP) of Hermetic Compressors shall be tested for single phase and three phase separately to cover the entire range of Hermetic Compressor in that particular category.
4. The Scope of Licence may be restricted based on the Manufacturing and Testing capabilities of the Manufacturer.
5. During the operation of the Licence, BO shall ensure that all the varieties covered in the Licence are tested in rotation, to the extent possible.

Amit Kumar
Sc C (CMD-III)

Head (CMD-III)
DDG (Certification)