

भा.मा. ब्यूरो मुख्यालय/प्रशासन/परिपत्र(108)2021

BIS HQ/ADMN/Circular(108)/2021

दिनांक: 13 नवम्बर 2021

Date: 13 November 2021

भारतीय मानक ब्यूरो / BUREAU OF INDIAN STANDARDS

(प्रशासन विभाग/Administration Department)

परिपत्र/ CIRCULAR

**विषय: Monitoring Air Quality in BIS HQs premises - reg.**

It is to inform that PMWD has carried out air quality monitoring inside BIS HQs buildings of Manak Bhavan and Manakalaya on 08 November 2021 and observed that PM 2.5 is present inside the BIS campus in high concentration and the air quality can be categorized "Very Poor" to "Adverse", related report is attached.

2. Air quality is expected to improve in upcoming days but till such time all officials including all contractual persons at BIS HQ are advised to wear their face mask during the office hours to reduce the risk due to air pollution.

3. This issues with the approval of Competent Authority.

Encl: as above

हस्ता/-  
(संदीप मीना)  
निदेशक (प्रशासन)

संदर्भ : प्रशासन/01/24/2021

बीआईएस इंटरनेट के माध्यम से मुख्यालय के सभी विभागीय प्रमुखों, कर्मचारियों एवं सभी संविदा कर्मियों इत्यादि के लिए सूचनार्थ एवं अनुपालन हेतु परिचालित ।

## INDOOR AIR QUALITY MONITORING REPORT

Project Management & Works Department

Site of sampling		MANAK BHAVAN	
Date of sampling		08-11-21	
Time of sampling		10:15am - 12:15pm	
S.no.	LOCATIONS	PARAMETER	
		PM <sub>2.5</sub> $\mu\text{g}/\text{m}^3$	Permissible Limit $\mu\text{g}/\text{m}^3$
	<u>G. Floor</u>		
1	Cafeteria	348	60
2	Reception	340	
3	Corridor (Bronze room)	328	
	<u>1st Floor</u>		
4	Corridor (ITSD room-107)	346	
5	FAD	278	
	<u>2nd Floor</u>		
6	CHD	316	
7	MED	334	
	<u>3rd Floor</u>		
8	Corridor (CED)	293	
9	IRD	338	
	<u>4th Floor</u>		
10	Lift lobby (Outside DG Room)	303	
11	Outside Committee room	298	

52459/2021/PMWD

INDOOR AIR QUALITY MONITORING REPORT			
Project Management & Works Department			
Site of sampling		MANAKALAYA	
Date of sampling		08-11-21	
Time of sampling		10:15am - 12:15pm	
S.no.	LOCATIONS	PARAMETER	
		PM <sub>2.5</sub> $\mu\text{g}/\text{m}^3$	Permissible Limit $\mu\text{g}/\text{m}^3$
	<u>1st Floor</u>		
1	Reception	363	60
2	LITD	330	
3	MHD	259	
4	PRD	347	
	<u>2nd Floor</u>		
5	Canteen	324	
6	Corridor (planning & coordination Dept)	301	
7	Finance Dept.	289	
	<u>3rd Floor</u>		
8	Library	212	
9	Policy, Research & Training Dept.	224	
10	CMD1	288	
	<u>4th Floor</u>		
11	CMD3	295	
12	PMWD	225	
13	Registration Dept.	232	
	<u>5th Floor</u>		
14	GSD	279	
15	Corridor (HEAD, hall marking Dept)	251	
16	CMD2	242	