

**AMENDMENT NO. 1 NOVEMBER 2024**  
**TO**  
**IS 16700 : 2023 CRITERIA FOR STRUCTURAL SAFETY OF TALL**  
**CONCRETE BUILDINGS**  
*( First Revision )*

(Page 16, clause 10.2, para 2) — Substitute the following for the existing:

where

- 'Z = seismic zone factor [as defined in IS 1893 (Part 1)];
- x = height of point of attachment of the NSE above top;
- $a_p$  = component amplification factor (see Table 10);
- $I_p$  = importance factor of the NSE (see Table 9);
- $W_p$  = weight of the NSE;
- h = overall height of the building; and
- $R_p$  = component response modification factor (see Table 10).'

[Page 16, Table 10, col (3), heading] — Substitute ' $a_p$ ' for 'p'.

[Page 16, Table 10, col (4), heading] — Substitute ' $R_p$ ' for 'p'.

[Page 18, Table 10, Sl No. (ii) (h) (1)] — Substitute the following for the existing:

'SI No.	NSE	$a_p$	$R_p$
(1)	(2)	(3)	(4)
h)	General electrical:		
	1) Distributed systems (bus ducts, conduit, cable tray)	2.5	5.0