

**AMENDMENT NO. 3 AUGUST 2023**

**TO**

**IS 16444 : 2015 a.c. STATIC DIRECT CONNECTED WATTHOUR SMART METER  
CLASS 1 AND 2 — SPECIFICATION**

*(Page 6, clause 9.3.1)* — Substitute the following:

‘Network: IPv6 (RPL or other routing protocols complying to standards from ITU/IEC/IEEE/CEN/  
CENELEC/ETSI/IETF)

*for*

Network: IPv6 RPL’.