

भारतीय मानक ब्यूरो
(केंद्रीय मुहर विभाग III)

हमारा संदर्भ : सी एम डी - III/16 : 12615

16 अप्रैल 2018

विषय : आई एस 12615 :2011 के लिए समूहीकरण दिशानिर्देश

सभी संबंधित पक्षकारों से अनुरोध है कि आई एस 12615 :2011 के लिए संलग्न समूहीकरण दिशानिर्देश की अनुपालन तत्काल प्रभाव से सुनिश्चित करें।

(अलिस्मिता खाग)
वैज्ञानिक बी (सी एम डी-III)

प्रमुख (सी एम डी-III)

सभी क्षेत्रीय /शाखा कार्यालय
प्रतिलिपि : आई टी एस विभाग - बी आई एस इंटरनेट पर डालने हेतु।

**BUREAU OF INDIAN STANDARDS
(Central Marks Department-III)**

Our Ref: CMD-III/16: IS 12615

16 April 2018

**Subject: Grouping Guidelines for Certification of Energy Efficient Induction Motors-
Three Phase Squirrel Cage as per IS 12615:2011**

This has reference to the Grouping Guidelines for Certification of Energy Efficient Induction Motors-Three Phase Squirrel Cage as per IS 12615:2011 dt. 08 Sept 2017 which was circulated to all ROs/BOs.

Representations were received from the Industry regarding permitting relaxation based on voltages. The same was also deliberated during the Sectional Committee Meeting of ETD 15 wherein the committee was of the view that the change in voltage does not affect the performance of the motor therefore all the voltages permitted in IS 12615:2011 can be covered based on testing of sample of any one voltage as per the test plan.

Accordingly, in addition to the relaxations provided in the guidelines dated 08 Sept 2017, the Competent Authority has permitted the following relaxation:

“By testing Energy Efficient Squirrel Cage Induction Motors of any one rated voltage as per the plan of drawal of samples given in CMD-III guidelines no. CMD-III/16: IS 12615 dated 08 Sept 2017, the entire range of voltages covered in IS 12615:2011 can be included within the scope of license. ”

All concerned are requested to ensure compliance of the above guidelines with immediate effect.

Alismita Khag

Sc. B(CMD-III)

Head(CMD-III)

DDG(Certification)

Circulated to: All ROs/BOs

Copy to: ITS-for hosting on Intranet please