

केन्द्रीय मुहर विभाग -III

संदर्भ- केन्द्रीय मुहर विभाग-III/16: आई एस - 1180 (Part 1)

03 मई 2018

विषय- आई एस 1180 (Part 1) : 2014 का संशोधन नंबर 1 का अनुपालन

आई एस 1180 (Part 1) : 2014 का संशोधन नंबर 1 के अनुपालन से संबन्धित परिपत्र संलग्न है।

इसे सक्षम प्राधकारारी के अनुमोदन से जारी किया गया है।

सभी संबंधित पक्षकारो से अनुरोध हे कि अनुपालन सुनिश्चित करे ।

(अलिस्मिता खाग)

वैज्ञानिक "बी" (सी एम डी-III)

प्रमुख (सी एम डी- III)

सभी शाखा कार्यालय

आई टी एस विभाग - BIS Intranet पर डालने हेतू

CENTRAL MARKS DEPARTMENT III

Our Ref: CMD III/16: IS 1180 (Part 1)

03 May 2018

Subject: Implementation of Amendment No. 1 to IS 1180 (Part 1):2014

Circular regarding the implementation of Amendment 1 to IS 1180 (Part 1): 2014 is attached.

This issues with the approval of the Competent Authority.

All BOs may ensure compliance.

(Alismita Khag)
Sc B(CMD III)

Head (CMD III)

Circulated to: All BOs

Copy to: ITS for hosting on Intranet

CENTRAL MARKS DEPARTMENT- III

Our Ref: CMD-III/16:1180 (Part 1)

03-05-2018

Subject: Implementation of Amendment No. 1 to IS 1180 (Part 1):2014

This has reference to the subject mentioned above.

The last date of implementation of Amendment No. 1 to IS 1180 (Part 1):2014 was extended till 31st December 2018 vide CMD-III circular dated 24.01.2018 due to discrepancies in Loss Levels mentioned in Amendment 1 and as ETD is in the process of issuing Amendment 3 to rectify the same. Accordingly, vide CMD-III email dated 09.03.2018, it was communicated to all ROs/BOs to keep all endorsements w.r.t compliance to Amendment No.1 in abeyance till the last date of implementation of Amendment No. 1 i.e. 31.12.2018.

Now concerns have been raised by the industry and the BOs citing that specifications other than the loss levels as per Amendment No.1 can be implemented.

The matter was again reviewed in consultation with ETD and it has been clarified that the Loss Levels of 6.3 kVA and 10 kVA transformers as per Table 3 of Amendment No. 1 are discrepant and other changes are admissible.

In view of the above, it has been decided by the Competent Authority that implementation of Loss Levels as per Table 3 of the said Amendment may only be kept in abeyance.

All BOs may bring it to the notice of all Licensees and Applicants and ensure compliance. Necessary endorsements may also be issued for all such cases where compliance has been confirmed by the Licensees.

The other procedures of implementation of the above amendment shall remain the same.

Alismita Khag

Sc-B (CMD-III)

Head (CMD-III)

DDG(Certification)

Circulated to: All BOs