



AMENDMENT NO. 1 SEPTEMBER 2024

TO

**IS 18058 : 2023 GUIDELINES FOR SUPERVISORY CONTROL
AND DATA ACQUISITION (SCADA) SYSTEM DISPLAYS**

[Page No .9, Table 3, sl no. (v) and (vi), col (3)] — Substitute the following for the existing:

Line at 220 kV Voltage Level	 Lime Green (hex #00FF00; 0 Red, 255 Green and 0 Blue)
Line at 400 kV Voltage Level	 Red (hex #FF0000; 255 Red, 0 Green and 0 Blue)