

**AMENDMENT NO. 1 SEPTEMBER 2024**  
**TO**  
**IS 802 (PART 1/SECTION 2) : 2016 USE OF STRUCTURAL STEEL IN OVERHEAD**  
**TRANSMISSION LINE TOWERS — CODE OF PRACTICE**  
**PART 1 MATERIALS, LOADS AND DESIGN STRENGTHS**  
**SECTION 2 DESIGN STRENGTHS**  
*( Fourth Revision )*

[Page 4, clause **6.3(a) and (b)**] — Substitute the following for the existing:

- a) Leg members, ground wire support peak : 120  
members and lower members of the cross arms  
in compression
- b) Other members carrying computed stresses : 200'.  
(such as bracings)

(CED 07)

**Price Group 1**  
Publication, BIS, New Delhi