

1

2

3

4

5

6

7

8

9

10

11

12

भारतीय मानक  
ए. सी. विद्युत ऊर्जा मीटरों के लिए  
परीक्षण उपस्कर  
(IS12346 – revised)

*Indian Standard*  
TESTING EQUIPMENT FOR  
AC ELECTRICAL ENERGY METERS  
(IS12346 – revised)

13 Equipment for Electrical Measurement and Load Control Sectional Committee, ETD 13

14

15

16 FOREWORD

17

18 Indian Standard IS12346 (First Revision) was adopted by the Bureau of Indian Standards, after the draft  
19 finalized by the Equipment for Electrical Energy Measurement and Load Control Sectional Committee had  
20 been approved by the Electro technical Division Council.

21

22 While preparing this standard assistance was derived from IEC 736-1982 ‘Testing equipment for electrical  
23 energy meters (first edition)’ (now IEC60736) issued by the International Electro technical Commission.

24

25 As the New technology and higher accuracy meters has been put into use, the requirement of precision  
26 and standardization of Test system according to new technology is being raised. In this regard IEC has  
27 release the draft IEC 62057-1 which replaces IEC60736.

28 It is necessary that existing IS 12346 (first revision):1999 need to reaffirm. For this purpose ETD 13 has  
29 formed work group 3 under panel 2.

30 For the draft affirmation of IS12346 assistance was derived from CDV-IEC62057-1 (13/1816/CDV).

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

## 48 Contents

49	1. Scope.....	9
50	2. Normative references .....	9
51	3. Terms and definitions .....	11
52	3.1 Definitions related to the elements of the meter test system .....	11
53	3.1.1 Meter under Test (MUT).....	11
54	3.1.2 Meter Test System (MTS).....	12
55	3.1.3 Automatic Meter Test System (AMTS).....	12
56	3.1.4 Phantom loading.....	12
57	3.1.5 Primary standard (system).....	12
58	3.1.6 Transfer standard (meter).....	12
59	3.1.7 Reference standard (meter).....	12
60	3.1.8 Working Standard (meter).....	12
61	3.1.9 Standard (meter).....	13
62	3.1.10 Error Calculation System.....	13
63	3.1.11 Scanning head .....	13
64	3.1.12 Output terminals of MTS .....	13
65	3.1.13 Maximum output power of the test source .....	13
66	3.1.14 Output stability of source .....	13
67	3.2 Definitions of active, reactive and apparent power .....	14
68	3.2.1 Active power .....	14
69	3.2.2 Apparent power.....	15
70	3.2.3 Reactive power (var).....	16
71	3.3 Definitions related to influence quantities.....	17
72	3.3.1 Laboratory or test and measurement area.....	17
73	3.3.2 Controlled Electromagnetic Environment .....	17
74	3.3.3 Influence quantity.....	17
75	3.3.4 Reference conditions .....	17
76	3.3.5 Variation of error due to an influence quantity.....	18
77	3.3.6 Total harmonic distortion, THD (abbreviation).....	18
78	3.3.7 Reference temperature .....	18
79	3.3.8 Rated operating conditions.....	18
80	3.3.9 Enclosure port.....	18
81	3.4 Definitions related to accuracy.....	18
82	3.4.1 Maximum permissible measurement error.....	18
83	3.4.2 Meter constant .....	18
84	3.4.3 Accuracy.....	18
85	3.4.4 Accuracy of a standard meter.....	18
86	3.4.5 Accuracy of a complete MTS.....	19
87	3.5 Definitions related to testing.....	19
88	3.5.1 Type test.....	19
89	3.5.2 Routine test.....	19
90	3.5.3 Acceptance test.....	19
91	3.5.4 Verification (or calibration).....	20

92	3.5.5	Commissioning test.....	20
93	3.5.6	Maintenance test.....	20
94	3.5.7	Power x Time Measurement Method (Wattmeter Method).....	20
95	3.5.8	Energy Comparison Measurement Method (Standard Meter Method) .....	20
96	3.5.9	Basic Measurements.....	20
97	3.5.10	Control Measurements .....	20
98	3.5.11	Skilled operator.....	20
99	3.6	Definitions related to field (onsite) installations testing .....	20
100	3.6.1	Electro mechanical Meter.....	20
101	3.6.2	Static Meter .....	20
102	3.6.3	Current transformer (CT) .....	21
103	3.6.4	Voltage transformer (PT) .....	21
104	3.6.5	Nominal burden SN.....	21
105	3.6.6	Operating burden Sn.....	21
106	3.6.7	Current measuring clamps.....	21
107	3.6.8	Voltage measuring transformer.....	21
108	4.	Components of meter test system .....	21
109	4.1	Laboratory Meter Test System .....	21
110	4.2	Onsite (portable) Meter Test System.....	22
111	5.	Meter test methods .....	23
112	5.1	Introduction .....	23
113	5.2	Energy comparison method.....	23
114	5.3	Power – time measurement method (watt-meter method).....	23
115	5.4	Pulse comparison method .....	24
116	5.5	Method for onsite meter testing .....	25
117	5.5.1	Checking of Wiring for connection of reference meter .....	25
118	5.5.2	The measuring error for electricity meter at installation: .....	26
119	5.5.3	Total measuring error of the electricity meter (LT CT operated) installations.....	26
120	5.6	Testing of smart meter / communicable meters .....	26
121	5.6.1	Intensity test of optical data interface.....	26
122	5.6.2	End to End testing.....	26
123	5.6.3	Test for parameter verification as per IS15959 (part 2 and 3) of implemented commands.....	26
124	5.6.4	Functional test .....	26
125	5.6.4.1	As per Table A30 of IS15959 Part2 and Table 29 of IS15959 Part3 .....	26
126	5.6.4.2	Recommended test facility as per IS15959 part 2 and 3 .....	26
127	5.6.5	Provision for Burden measurement of the smart meter:.....	26
128	5.6.6	Verification of electrical tamper conditions. ....	27
129	5.6.7	Influence of metrological stress on communication .....	27
130	5.6.8	Automatic testing of Communication:.....	27
131	6.	Standard electrical values .....	27
132	6.1	Mains supply .....	27
133	6.2	Output values and ranges of the test circuits.....	27
134	6.2.1	Test voltage circuit.....	27
135	6.2.2	Test current circuit.....	28

136	6.2.3	Phase angle .....	29
137	6.2.4	Frequency.....	29
138	6.2.5	Harmonics .....	30
139	6.3	Standard meter .....	30
140	6.3.1	Accuracy class .....	30
141	6.3.2	Standard electrical values .....	30
142	6.4	Magnetic field of the MTS.....	31
143	6.5	Electrical and mechanical values for the scanning head(s) .....	31
144	6.6	Error calculation system .....	31
145	6.6.1	Functional requirements.....	31
146	6.6.2	Electrical values for error calculation system .....	32
147	7.	Constructional requirements of the MTS .....	32
148	7.1	General requirements.....	32
149	7.2	Source and standard meter .....	32
150	7.3	Meter mounting system .....	32
151	7.3.1	General.....	32
152	7.3.2	Terminals.....	33
153	8.	Information and Marking requirement .....	35
154	8.1	General.....	35
155	8.2	Labels, signs and signals.....	37
156	8.3	Information for selection .....	38
157	8.3.1	General.....	38
158	8.3.2	General Information .....	38
159	8.3.3	Information related to standard meters.....	38
160	8.3.4	Information related to sources, error calculator and frequency generators .....	39
161	8.3.5	Information related to the ICTs and MSVTs.....	39
162	8.3.6	Information related to clamp on transformers.....	39
163	8.3.7	For the communication interfaces and error calculators .....	39
164	8.3.8	For the meter installations.....	39
165	8.4	Information for installation and commissioning.....	40
166	8.4.1	General.....	40
167	8.4.2	Dimensions and weight.....	40
168	8.4.3	Connection .....	40
169	8.4.4	Protection.....	40
170	8.4.5	Self-consumption .....	41
171	8.5	Information for use .....	41
172	8.5.1	General.....	41

173	8.5.2	Display, push buttons and other controls.....	41
174	8.5.3	Connection to user’s equipment .....	41
175	8.5.4	External protection devices .....	41
176	8.5.5	Cleaning.....	41
177	8.5.6	Information for maintenance .....	41
178	9.	Climatic conditions for the MTS.....	42
179	9.1	Normal environmental conditions .....	42
180	9.2	Temperature limits .....	42
181	10.	Electrical requirements of the MTS .....	43
182	10.1	Influence of mains supply .....	43
183	10.2	Insulation .....	43
184	10.2.1	General.....	43
185	10.2.2	Clearances and Creepage distances.....	43
186	10.2.3	Verification of clearances and creepage distances.....	43
187	10.2.4	A.C. voltage test .....	43
188	10.2.5	Insulation Resistance test .....	45
189	11.	Electromagnetic compatibility .....	45
190	11.1	General requirements.....	45
191	11.2	General test conditions.....	46
192	11.2.1	Test of immunity to electrostatic discharges.....	46
193	11.2.2	Test of immunity of electromagnetic RF Fields .....	46
194	11.2.3	Immunity to power frequency magnetic fields of external origins .....	47
195	11.2.4	Test of immunity to fast transient bursts .....	47
196	11.2.5	Test of immunity to surges .....	48
197	11.2.6	Test of immunity to conducted disturbances, induced by RF fields.....	48
198	11.2.7	Radio interference suppression .....	48
199	12.	Standard meter .....	48
200	12.1	General.....	48
201	12.2	Accuracy requirements under reference conditions .....	49
202	12.3	Limits of error due to influence quantities .....	51
203	12.4	Accuracy tests in the presence of harmonics .....	54
204	12.4.1	Test with 3rd harmonic in the current.....	54
205	12.4.2	Test with 5th harmonic in the current and voltage .....	54
206	12.4.3	Tests of the influence of odd and sub-harmonics (Annex C) .....	54
207	13.	Software requirements.....	54
208	13.1	Application .....	54
209	13.2	Identification.....	55
210	13.3	Protection .....	55
211	13.4	Functional requirements.....	55

212	13.5	Protection of integrity and storage of test results and test protocols (reports) .....	55
213	13.6	Documentation of the software .....	55
214	14.	Accuracy requirements and tests .....	56
215	14.1	General.....	56
216	14.2	Test methods for determination of MTS accuracy .....	56
217	14.3	Test points for MTS.....	57
218	14.3.1	Selection of voltage and current ranges .....	57
219	14.4	Accuracy requirements.....	59
220	14.4.1	Limits of maximum permissible error .....	59
221	14.4.2	Correction of the error $\delta W$ of the meter test system .....	60
222	14.4.3	Mean value and repeatability of the measurements .....	60
223	14.5	Evaluation of test results .....	61
224	14.5.1	Basic measurements .....	61
225	14.5.2	Recalibration of meter test system.....	61
226	14.6	Test for output values and ranges of test circuits .....	61
227	15.	Tests and testing procedures.....	61
228	15.1.1	Type tests .....	61
229	15.1.2	Routine tests .....	62
230	15.1.3	Acceptance test.....	63
231	15.1.4	Commissioning test.....	63
232	16.	Test of climatic condition.....	63
233	16.1	Dry heat test .....	63
234	16.2	Cold test .....	63
235	16.3	Damp heat cyclic test.....	64
236	Annex A.....		65
237	Annex B.....		66
238	Annex C.....		67
239	C.1	Phase fired control (odd harmonics) .....	67
240	C.2	Burst control (sub-harmonics) .....	69
241	Annex D.....		70
242	D.1	Introduction .....	70
243	D.2	General Conditions .....	70
244	D.3	Quality of mains supply.....	70
245	D.4	Standard meter .....	70
246	Annex E.....		71
247	E.1	Introduction .....	71
248	E.2	Definitions.....	71
249	E.2.1	Meter With Permanently Closed Link.....	71

250	E.2.2	Multi Secondary Voltage Transformer, MSVT .....	71
251	E.3	Application .....	71
252	E.4	Technical requirements .....	73
253	E.4.1	Number of windings and ratio .....	73
254	E.5	Total accuracy of MTS with MSVT .....	73
255	Annex F	.....	74
256	F.1	Introduction .....	74
257	F.2	Definitions.....	74
258	F.2.1	Three phase closed-link meters.....	74
259	F.2.2	Isolating Current Transformer (ICT) .....	74
260	F.3	Application .....	74
261	F.4	Technical requirements .....	75
262	F.5	Wiring and terminals.....	75
263	F.6	Total accuracy of MTS with ICT .....	75
264		The overall error of the MTU while using ICT should not exceed the values specified in Table 35 .....	75
265	Annex G (informative)	Wiring samples of test sets and MUTs.....	76
266	G.1	Connection of the reference meter for wiring check / error measurement for testing of Single	
267		Phase energy meter .....	76
268	G.2	Connection of the reference meter for wiring check / error measurement for testing of 3 Phase	
269		Direct connected energy meter .....	77
270	G.3	Connection of the reference meter for wiring check / error measurement for testing of 3 Phase	
271		CT operated meter (from secondary side).....	78
272	G.4	Connection of the reference meter for wiring check / error measurement for testing of 3 Phase	
273		CT operated meter (from primary side-installation checking) .....	79
274	G.5	Connection of the reference meter for wiring check / error measurement for testing of 3 Phase	
275		CT-PT operated meter.....	80
276	Annex H (informative)	Maintenance of meter test system .....	81
277	H.1	Maintenance of MTS (being used in laboratory) .....	81
278	H.2	Maintenance of MTS (being used at Onsite) .....	81
279	Annex I (informative)	Testing of Smart Meter .....	82
280	I.1	End to End testing .....	82
281	I.2	Test for parameter verification as per IS15959 (part 2 and 3) of implemented commands.....	82
282	I.3	Recommended test facility as per IS15959 part 2 and 3 .....	82
283	I.3.1	Functional test .....	82
284	I.4	Provision for Burden measurement of the smart meter:.....	83
285	I.5	Verification of electrical tamper conditions. ....	83
286	I.6	Influence of metrological stress on communication .....	84
287	I.7	Automatic testing of Communication:.....	84
288	Annex J (Informative)	Software requirement and Validation Points.....	85
289	J.1	Control and supervision of the meter test system by the software .....	85
290	J.2	Creation, protection and storage of test programs .....	86
291	J.3	Software logs.....	86



292	J.4 Software Validation.....	86
293	Annex K (informative) Example of Uncertainty calculation of MTS (without ICT or MSVT).....	87
294	Example of Uncertainty calculation of MTS (with ICT) .....	90
295		
296	<b>Table of Figures</b>	
297	Figure 1- Block diagram of Lab MTS.....	33
298	Figure 2- Test circuit diagram (informative) .....	67
299	Figure 3 – Phase fired waveform .....	68
300	Figure 4– Informative distribution of harmonic content of phase fired waveform .....	68
301	Figure 5– Burst fired waveform .....	69
302	Figure 6 – Informative distribution of harmonics .....	69
303	Figure 7– Testing of single phase meters with closed link between the voltage and current circuits	
304	(variant 1).....	72
305	Figure 8– Testing of single phase meters with closed link between the voltage and current circuits	
306	(variant 2).....	72
307	Figure 9– Testing of 3-phase meters with closed link between the voltage and current circuits.....	74
308	Figure 10–Connection of the reference meter for wiring check / error measurement for testing of Single	
309	Phase energy meter .....	76
310	Figure 11–Connection of the reference meter for wiring check / error measurement for testing of 3	
311	Phase Direct connected energy meter .....	77
312	Figure 12–Connection of the reference meter for wiring check / error measurement for testing of 3	
313	Phase CT operated energy meter (secondary) .....	78
314	Figure 13 Connection of the reference meter (direct connection) .....	79
315	Figure 14 Connection of the reference meter (clamp on CT connection) .....	79
316	Figure 15–Connection of the reference meter for wiring check / error measurement for testing of 3	
317	Phase CT operated energy meter (Primary side-installation checking).....	79
318	Figure 16–Connection of the reference meter for wiring check / error measurement for testing of 3	
319	Phase CT-PT operated energy meter Using TTB) .....	80
320		
321		
322		
323		
324		
325		
326		
327		
328		
329		
330		

## 1. Scope

331  
332 This part of Standard applies to Meter test System, used for testing and calibration of  
333 electricity meters and electricity meter installations, Power meters, in particular for their type  
334 test, acceptance test and verification test in field (onsite) or laboratory as per IS13779,  
335 IS14697, IS15884, IS15959 (part 1, part 2 and part 3), IS15707 and IS16444 (Part1 and Part2).  
336 It covers the requirements for Meter test System for indoor laboratory application and  
337 outdoor meter testing and calibration units.

338 It applies to meter test systems to test electricity meters on 50 Hz networks with an AC voltage  
339 up to 300V (phase to neutral). Also the standard describes the test procedure for new meter  
340 installation as well as the one under operation. If meters are intended for system voltages not  
341 specified in this standard, special requirements should be agreed on between the  
342 manufacturer and the purchaser.

343 This standard also defines routine tests, acceptance tests, type tests and commissioning tests  
344 for meter test systems.

345 It does not apply to:

- 346 • Electricity meters;
- 347 • Personal computers supplied together with the meter test system.

## 2. Normative references

Table 1 Normative references

IEC 62057-1 (draft)	Test equipment, techniques and procedures for electrical energy meters - Part 1: Stationary Meter Test Units (MTU)
IEC 62057-2 (draft)	Portable Test Equipment and Test Procedure for Electricity Meter and Electricity Meter Installation Part-2
IEC 60050-300:2001	International electro-technical vocabulary (IEV)
IEC 60060-1:2010	High-voltage test techniques – Part 1: General definitions and test requirements
IEC 60085:2007	<i>Electrical insulation – Thermal evaluation and designation</i>
IEC 60269-1:2006	<i>Low-voltage fuses – Part 1: General requirements</i>
IEC 60417:2002	<i>Graphical symbols for use on equipment – 12-month subscription to regularly updated online database comprising all graphical symbols published in IEC 60417</i>
IEC 60359:2001	<i>Electrical and electronic measurement equipment - Expression of performance</i>
IEC 60375:2018	<i>Conventions concerning electric circuits</i>
IEC 60664-1:2007	<i>Insulation coordination for equipment within low-voltage systems – Part1: Principles, requirements and tests</i>
IEC 61140:2016	<i>Protection against electric shock – Common aspects for installation and equipment</i>
IEC 61326-1:2012	<i>Electrical equipment for measurement, control and laboratory use -EMC requirements</i>
IEC 62052-11 ED2	<i>Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 11: Metering equipment</i>
IEC 62052-21: 2004	<i>Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 21: Tariff and load control equipment</i>

IEC 62052-31:2015,	<i>Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests</i>
IEC 62053-11:2003	<i>Electricity metering equipment (a.c.) – Particular requirements – Part 11: Electromechanical meters for active energy (classes 0.5, 1 and 2)</i>
IEC 62053-21 ED2:	<i>Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)</i>
IEC 62053-22 ED2:	<i>Electricity metering equipment (a.c.) – Particular Requirements – Part 22: Static meters for active energy (classes 0.2 S and 0.5 S)</i>
IEC 62053-23 ED2:	<i>Electricity metering equipment (a.c.) – Particular requirements – Part 23: Static meters for reactive energy (classes 2 and 3)</i>
IEC 62053-24 ED2:	<i>Electricity metering equipment (a.c.) – Particular requirements – Part 24: Static meters for reactive energy (classes 0.5 S, 1S and 1)</i>
IEC 62058-11:2008,	<i>Electricity metering equipment (AC) – Acceptance inspection – Part 11: General acceptance inspection methods</i>
IEC 62058-21:2008,	<i>Electricity metering equipment (AC) – Acceptance inspection. Part 21: Particular requirements for electromechanical meters for active energy (classes 0,5, 1, and 2)</i>
IEC 62058-31:2008,	<i>Electricity meter equipment (AC) – Acceptance inspection. Part 31:Particular requirements for static meters for active energy (classes 0.2 S, 0.5 S, 1 and 2)</i>
IEC 61000-4-2:2008,	<i>Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques- Electrostatic discharge immunity test.</i>
IEC 61000-4-3:2006	<i>Electromagnetic compatibility (EMC)– Part 4-3: Testing and measurement techniques- Radiated, radio-frequency, electromagnetic field immunity test.</i>
IEC 61000-4-4:2012	<i>Electromagnetic compatibility (EMC) Part 4-4: Testing and measurement techniques- Electrical fast transient/burst immunity test.</i>
IEC 61000-4-5:2014	<i>Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques- Surge Immunity test.</i>
IEC 61000-4-6:2013	<i>Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques- Immunity to conducted disturbances, induced by radio frequency fields</i>
IEC 61000-4-8:2009 RLV,	<i>Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test</i>
IEC 61000-6-1:2016 RLV	<i>Electromagnetic compatibility (EMC) – Part 6-1: Generic standards - Immunity for residential, commercial and light-industrial environments</i>
IEC 61000-6-2:2016 RLV	<i>Electromagnetic compatibility (368 EMC) – Part 6-2: Generic standards - Immunity for industrial environments</i>
IEC 61000-6-3:2006	<i>Electromagnetic Compatibility (EMC) – Part 6-3: Generic Standards - Emission Standard for Residential, Commercial and Light-Industrial Environments</i>
IEC 61000-6-4:2006-	<i>Electromagnetic compatibility (EMC) – Part 6-4:Generic standards - Emission standard for industrial environments</i>

IEC 61010-1:2010,	<i>Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements</i>
IEC 61010-031:2015 RLV	<i>Safety requirements for electrical equipment for measurement, control and laboratory use – Part 031: Safety requirements for hand-held probe assemblies for electrical measurement and test</i>
IEC 60721-3-2:2001	<i>Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities - Section 2:Transportation</i>
IEC 60721-3-3:1994	<i>Classification of environmental conditions – Part 3-3: Classification of groups of environmental parameters and their severities – Stationary use at weather protected locations</i>
CISPR 11:2015,	<i>Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement</i>
EN 50160:2011	<i>Voltage characteristics of electricity supplied by public distribution systems</i>
EN 50470-1:2006,	<i>Electricity metering equipment (a.c.) Part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)</i>
EN 50470-2:2006,	<i>Electricity metering equipment (a.c.) Part 2: Particular requirements -Electromechanical meters for active energy (class indexes A and B)</i>
EN 50470-3:2006,	<i>Electricity metering equipment (a.c.) Part 3: Particular requirements -Static meters for active energy (class indexes A, B and C)</i>
JCGM 100:2008	<i>Evaluation of measurement data – Guide to the expression of uncertainty in measurement</i>
JCGM 200:2012	<i>International vocabulary of metrology – Basic and general concepts and associated terms (VIM)</i>
ISO 7000:2014	<i>Graphical symbols for use on equipment – Registered symbols</i>
ISO 3864-1:2011	<i>Graphical symbols – Safety colours and safety signs – Part1: Design principles for safety signs and safety markings.</i>
ISO 13732-1:2006	<i>Ergonomics of the thermal environment -- Methods for the assessment of human responses to contact with surfaces -- Part 1: Hot surfaces</i>
ISO/IEC 17025:2005	<i>General requirements for the competence of testing and calibration laboratories</i>

### 350 3. Terms and definitions

#### 351 3.1 Definitions related to the elements of the meter test system

352

##### 353 3.1.1 Meter under Test (MUT)

354 Electricity meter intended to measure active and/or reactive energy by integrating active  
355 and/or Reactive power with respect to time

356 Note: For the definition of various types of energy meters and their elements, see IS13010, IS13779:  
357 2020, IS14697:2021, IEC 62052-11, IEC 62053-23, IS16444 (Part1 and part 2) and IEC 62053-24.

### 3.1.2 Meter Test System (MTS)

Assembly of sources, frequency generator, standard meter, and error calculation and indication system to supply the required test values to the MUT and to measure, calculate and display the error of the MUT

### 3.1.3 Automatic Meter Test System (AMTS)

MTS which conducts, controls and monitors the desired function(s) or activity (ies) of meter testing through software

### 3.1.4 Phantom loading

The method of loading the meter in which voltage source(s) and current source(s) are supplied from two separate circuits; the voltage source(s) is generally supplied at reduced current and rated frequency. The current source(s) is generally supplied at reduced voltage and rated frequency. The phase angle between the two circuits is adjustable through phase shifter. [Phantom loading can be obtained by static power source(s) or transformer based power source(s)].

Note 1: These test signals shall be independent from the mains input in the specified operating range.

Note 2: The test signals are based on the command(s) received from the test software or controller.

### 3.1.5 Primary standard (system)

A primary standard in metrology is a standard that is sufficiently accurate such that it is not calibrated directly by or subordinate to other standards. It will be calibrated by calibration of base parameters. Primary standards are used to calibrate other standards referred to as Working Standards/Reference Standard/Transfer Standard.

### 3.1.6 Transfer standard (meter)

Transfer standard is a measurement standard used as an intermediate device when comparing two other standards. Typical applications of transfer standards are to transfer a measurement parameter from one organization to another, from a primary standard to a secondary standard, or from a secondary standard to a working standard in order to create or maintain measurement traceability.

### 3.1.7 Reference standard (meter)

A standard whose measurement traceability has been verified at an accredited laboratory and is used for in-house verification of other standards in the meter test station (M. T.S.).

Note: A reference standard meter must be traceable to national or international primary standards.

### 3.1.8 Working Standard (meter)

A standard including a complete meter testing system, which has been verified by comparison to either a reference standard or a transfer standard, and is used for calibration and testing of metering equipment.

Note 1: It is calibrated against the reference standard (meter).

Note 2: A MTS can also be fitted with a reference standard used for day to day calibration of MUTs of high accuracy (reference standard used as the working standard).

### 399 3.1.9 Standard (meter)

400 Common term for the reference standard according to 3.1.7 or the working standard in  
401 accordance to 3.1.8

### 402 3.1.10 Error Calculation System

403 Device or a group of devices to count pulses, or read energy values and to compare, calculate  
404 and indicate the percentage error of the MUTs

405 Note: The default error calculation system receives pulses from the scanning heads or from the pulse  
406 outputs of the MUTs and compares these with pulses received from the standard meter.  
407

### 408 3.1.11 Scanning head

409 For detecting optical impulse output of static meter or rotor disc of electro mechanical  
410 meter.

### 411 3.1.12 Output terminals of MTS

412 The terminals from which the power, corresponding to the separate application of voltages  
413 and currents, is supplied to the terminal block(s) of the meter(s) under test.

### 414 3.1.13 Maximum output power of the test source

415 Output power (in volt-amperes) corresponding to the highest load applied at the output  
416 terminals of a source. The output shall be defined separately for the voltage and current  
417 circuits.  
418

### 419 3.1.14 Output stability of source

420 Number or percentage of the output quantity of the source indicating that the output  
421 quantity may likely vary within this number or percentage when all other parameters such as  
422 supply voltage etc. are in accordance to reference conditions (Annexure B).

423 Note 1: The output stability (S) for voltage, current, power and frequency test output shall be  
424 separately defined in % and is given in formula  
425

$$S = \frac{\max\{m_1(T), m_2(T) \dots \dots m_N\} - \min\{m_1(T), m_2(T) \dots \dots m_N\}}{\frac{1}{N} \sum_{k=1}^N m_k(T)} \cdot 100\% \quad \text{Equation 1}$$

426 where:

427 S is the stability of the test output;

428  $m_N(T)$  is the Nth measured value with integration period T inside a successive sequence of  
429 measurements;

430  $m_k(T)$  is the kth value,  $k = 1 \dots N$  inside this sequence;

431 N is the number of values inside this sequence;

432 T is the integration period.

433  $\max$  is the greatest of  $\{m_1(T), m_2(T), \dots, m_N(T)\}$ ;

434  $\min$  is the least of  $\{m_1(T), m_2(T), \dots, m_N(T)\}$

435 The output stability ( $S_{abs}$ ) of the phase angle between output values must be separately defined in °  
 436 (degree) and given in below formula  
 437  
 438

$$S_{abs} = \max\{m_1(T), m_2(T), \dots, m_N(T)\} - \min\{m_1(T), m_2(T), \dots, m_N(T)\} \quad \text{Equation 2}$$

439 Note 2: The purchaser and the supplier may mutually agree for the integration period T and the values  
 440 N of the measuring sequence.  
 441

## 442 3.2 Definitions of active, reactive and apparent power

### 443 3.2.1 Active power

444 Active power at any single sinusoidal frequency component of a periodic signal in a single  
 445 phase circuit is defined as the product of the RMS values of current and voltage and the cosine  
 446 of the phase angle between them, where the phase angle is the angle of the voltage signal  
 447 vector with respect to the current signal vector.

448 Note 1: Under sinusoidal conditions, the active power is the real part of the complex power.

449 Note 2: The active power of the periodic signal is the algebraic sum of the active power of the sinusoidal  
 450 frequency components.

451 Note 3: The coherent SI unit for active power is the watt [W].

452 Note 4: Time domain calculation under general conditions.

$$P = \frac{1}{T} \int_0^T u(t) \cdot i(t) \cdot dt \quad \text{Equation 3}$$

453 Where:

454 P is the active power;

455  $u(t)$  is the instantaneous value of the voltage;

456  $i(t)$  is the instantaneous value of the current;

457 T is the integration time of the measurement cycle.  
 458

459 Fourier summation for frequency domain calculations with equal time periods for U and I up to nth  
 460 harmonic  
 461

$$P = \sum_{k=1}^N U_k \cdot I_k \cdot \cos(\varnothing_{uk} - \varnothing_{ik}) = P_1 + P_2 + P_3 \dots + P_N = P_1 + P_H \quad \text{Equation 4}$$

462 Where:

463 P1 is the fundamental active power;

464 PH is the harmonic active power;

465  $U_k$  is the RMS value of the voltage component of order k;

466  $I_k$  is the RMS value of the current component of order k;

467  $\varnothing_{uk}$  is the phase shift between the voltage component of order k and the fundamental voltage  
 468 component of order 1;

469  $\varnothing_{ik}$  is the phase shift between the current component of order k and the fundamental voltage  
 470 component of order 1.

471 [SOURCE: 62052-11 Ed.2, modified – Note 4 to entry has been added.]

472  
473  
474  
475  
476  
477  
478  
479

### 3.2.2 Apparent power

Product of the RMS voltage U between the terminals of a two-terminal element or circuit and the RMS electric current I in the element or circuit

Note 1: The SI unit for apparent power is the VA.

Note 2: There are no IS or IEC standards available for meters measuring apparent power / energy.

Note 3: Time domain calculation under general conditions

$$S = U \cdot I = \frac{1}{T} \sqrt{\int_0^T i^2(t) dt \cdot \int_0^T u^2(t) dt} \quad \text{Equation 5}$$

480  
481  
482  
483  
484  
485  
486  
487  
488  
489  
490

Where:

S is the apparent power;

U is the RMS value of the voltage;

I is the RMS value of the current;

u(t) is the instant value of the voltage;

i(t) is the instant value of the current;

T is the integration time of the measurement cycle.

Note 4: Power triangle method to calculate the absolute value of apparent power under general conditions.

$$S = \sqrt{P^2 + Q^2} \quad \text{Equation 6}$$

491  
492  
493  
494  
495  
496  
497  
498

Where:

S is the apparent power;

P is the active power;

Q is the reactive power.

Note 5: Fourier summation for frequency domain calculations with equal time periods for U and I up to nth harmonic:

$$S = U \cdot I = \sqrt{\sum_{k=1}^n U_k^2 \cdot \sum_{k=1}^n I_k^2} \quad \text{Equation 7}$$

499  
500  
501  
502  
503  
504  
505  
506

Where:

S is the apparent power;

U is the RMS value of the voltage;

I is the RMS value of the current;

U<sub>k</sub> is the RMS value of the voltage component of order k;

I<sub>k</sub> is the RMS value of the current component of order k.

[Source IEC 131-11-41, modified – Note 3, 4 and 5 to entry has been added].



### 507 3.2.3 Reactive power (var)

508 Reactive power for sinusoidal waveforms of any single frequency in a single phase circuit is  
509 defined as the product of the r.m.s. values of current and voltage and the sine of the phase  
510 angle between them.

511 [Source: Clause no. 3.1.3 of IS14697:2021]  
512

513 Note 1: For practical reason this standard applies to the reactive power for sinusoidal current and  
514 voltage containing the fundamental frequency only.

515 Note 2: The algorithm used for the calculation of reactive power is not specified, however the meter is  
516 expected to meet requirements of the relevant accuracy class standard.

517 Note 3: The coherent SI unit for reactive power is volt-ampere, VA. The special name var and its symbol  
518 var are also used.

519 Note 4: IEC 62053-24 specifies reactive power / energy for fundamental components explicitly.  
520 Harmonics are considered as influence quantities. The algorithm is not specified, but the change of  
521 accuracy in the presence of harmonics must be within the limits specified. To meet this requirement,  
522 meters need harmonic filtering. For testing it has to be verified, that also the standard meter measures  
523 the fundamental reactive power only in the presence of harmonics. This method is mandatory.  
524

525 Note 5: Reactive power Q in a single phase system for steady-state and periodic signals is defined as:  
526  
527

$$Q = U_1 \cdot I_1 \cdot \sin \phi \quad \text{Equation 8}$$

528 Where:

529 Q is the reactive power;

530 U1 is the RMS value of the fundamental frequency components of the voltage;

531 I1 is the RMS value of the fundamental frequency components of the current; and

532  $\phi$  is the phase angle between U1 and I1.  
533

534 Note 6: Power triangle method to calculate the absolute value of total non-active power under general  
535 conditions. This definition is widely known, used for the calculation of reactive power and called non  
536 active power according to IEC. Non-active power for a two-terminal element or circuit under periodic  
537 conditions, quantity equal to the square root of the difference of the squares of the apparent power  
538 and the active power.

539 [Source: IEC 60375].  
540

$$Q = \sqrt{S^2 - P^2} \quad \text{Equation 9}$$

541

542 Where:

543 Q is the non-active power;

544 S is the apparent power;

545 P is the active power.

546 This method is unambiguous if only fundamental components are present. With sinusoidal voltages  
547 and non- sinusoidal currents the result includes the fundamental and distortion power. Prefixes of Q  
548 shall conform to IEC 60375. Standard meters determining accuracy according to IEC 62053-24 do not  
549 use this method for sinusoidal conditions, the non-active power determined by Power Triangle Method  
550 is equal to the absolute value of the product of the apparent power and the sine of the displacement  
551 angle.

552  
553  
554

Note 7 to entry: Time domain calculation on pure sinusoidal conditions (time displacement method):

$$Q = \frac{1}{T} \cdot \int_0^T u \left( t - \frac{T}{4} \right) \cdot i(t) \cdot dt \quad \text{Equation 10}$$

555  
556  
557  
558  
559  
560

Where:

Q is the reactive power;

u(t) is the instantaneous value of the voltage;

i(t) is the instantaneous value of the current;

T is the time period of the fundamental component.

561  
562  
563  
564  
565  
566

This method is only unambiguous under sinusoidal conditions with fundamental frequencies. In that case reactive power determined by the Time Displacement Method is the product of the apparent power and the sine of the displacement angle. To realize this method, meters have a provision for phase shifting adjusted for the fundamental only. This method is not recommended.

567  
568  
569  
570  
571  
572

Note 8: For unambiguous determination of errors the algorithm used by the standard meter for measuring Q and S shall be indicated in the test report of a MUT. This is particularly important when testing poly phase meters. In addition, the calculation method of how poly phase power is determined shall be indicated in the test report.

[SOURCE: 62052-11 Ed.2, modified – Note 4, 5,6,7,8 to entry has been added.]

573

### 3.3 Definitions related to influence quantities

574

#### 3.3.1 Laboratory or test and measurement area

575  
576

Area that is specifically used for analysis, testing and servicing and places with equipment operated by trained personnel

577

#### 3.3.2 Controlled Electromagnetic Environment

578  
579

Environment usually characterized by recognition and control of EMC phenomena by users of the equipment

580

#### 3.3.3 Influence quantity

581  
582

Quantity which is not the subject of the measurement and whose change affects the relationship between the indication and the result of the measurement.

583

Note 1: This term is used in the "uncertainty" approach.

584  
585

Note 2: Influence quantities can originate from the measured system, the measuring equipment or the environment.

586  
587  
588  
589

Note 3: As the calibration diagram depends on the influence quantities, in order to assign the result of a measurement it is necessary to know whether the relevant influence quantities lie within the specified range.

[SOURCE: IEC 311-06-01]

590

#### 3.3.4 Reference conditions

591  
592

Appropriate set of influence quantities and performance characteristics, with reference values, their tolerances and ranges, with respect to which the intrinsic error is specified.

593 [SOURCE:3.6.2 of IS13779:2020]

### 594 3.3.5 Variation of error due to an influence quantity

595 Difference between the percentage errors of the meter when only one influence quantity  
596 assumes successively two specified values, one of them being the reference value.

597 [SOURCE: IEC 62052-11 3.6.6]

### 598 3.3.6 Total harmonic distortion, THD (abbreviation)

599 The ratio of the RMS value of the harmonic content of an alternating quantity to the RMS  
600 value of the fundamental component of the quantity.

601 [SOURCE: IEC 551-17-06]

### 602 3.3.7 Reference temperature

603 Ambient temperature specified for reference conditions. [SOURCE: IEC 62052-11 3.6.8]

### 604 3.3.8 Rated operating conditions

605 Set of specified measuring ranges for performance characteristics and specified operating  
606 ranges for influence quantities, within which the variations of operating errors of a MTS are  
607 specified and determined

608 [SOURCE: IEC 62052-11 3.6.10]

### 609 3.3.9 Enclosure port

610 Physical boundary of equipment through which electromagnetic fields may radiate or  
611 impinge.

612

## 613 3.4 Definitions related to accuracy

### 614 3.4.1 Maximum permissible measurement error

615 Extreme value of measurement error, with respect to a known reference quantity value,  
616 permitted by specifications or regulations for a given measurement, measuring instrument or  
617 measuring system

618

619 NOTE 1 usually, the term “maximum permissible errors” or “limits of error” is used where there are  
620 two extreme values.

621 NOTE 2 the term “tolerance” should not be used to designate ‘maximum permissible error’

622 [SOURCE: JCGM 200, 4.26]

### 623 3.4.2 Meter constant

624 The number of revolutions of the rotor of an electromechanical meter or the number of pulses  
625 of a static meter at the test output or electrical pulse output, per energy unit

### 626 3.4.3 Accuracy

627 Closeness of agreement between a measured quantity value and a true quantity value of a  
628 measurand

629 [SOURCE: JCGM 200, 2.13, modified]

### 630 3.4.4 Accuracy of a standard meter

631 Accuracy of a standard meter indicates the closeness of a measured quantity value in a given  
632 range of operation, at reference conditions and a true quantity value of a measurand

633 Note: The accuracy should be given for:

634

- 635 a) Accuracy of voltage measurements;  
 636 b) Accuracy of current measurements;  
 637 c) Accuracy of phase angle measurements;  
 638 d) Accuracy of frequency measurements;  
 639 e) Accuracy of active power / energy measurements;  
 640 f) Accuracy of reactive power / energy measurements;  
 641 g) Accuracy of apparent power / energy measurements.

### 642 3.4.5 Accuracy of a complete MTS

643 The accuracy of the MTS considering the accuracy of the standard meter, the accuracy of the  
 644 calculation system (if any), and the accuracy of the test signals including the differences  
 645 between the test positions

646  
 647 Note 1: Quantitative validations and qualifications should be done. The accuracy of the  
 648 complete MTS may be close to the accuracy of the standard meter if:

- 649 • all differences between the accuracy of the standard meter are considered in the  
 650 calculations;
- 651 • the MTS is designed for testing a small number of meters at a time;
- 652 • the manufacturer made efforts to reduce the voltage differences between the  
 653 terminals of the standard meter and the terminals of the MUTs;
- 654 • The manufacturer made efforts to compensate or minimize variations caused by the  
 655 error calculation system.

656 Note 2: The manufacturer has to specify both kinds of accuracies: that of the standard meter  
 657 and that of the MTS.

658

## 659 3.5 Definitions related to testing

### 660 3.5.1 Type test

661 Series of tests carried out on one meter or a small number of meters of the same type having  
 662 identical characteristics, selected by manufacturer to prove conformity with all the  
 663 requirements of this standard for the relevant class of meter. These are intended to prove the  
 664 general qualities and design of a given type of meter. [SOURCE: definition as per 3.7.1 of  
 665 IS13779]

666

### 667 3.5.2 Routine test

668 Tests carried out on each meter to check conformity with the requirements of this standard  
 669 in aspects which are likely to vary during production.

670 [SOURCE: definition as per 3.7.2 of IS13779]

671

### 672 3.5.3 Acceptance test

673 Tests carried out on samples taken from a lot for the purpose of acceptance of the lot.

674 NOTE — however specific qualities and design of the meters in a lot can be conclusively proved  
 675 by performing relevant type test(s) on a number of samples if agreed by the user and the  
 676 supplier. [SOURCE: definition as per 3.7.3 of IS13779]

677

- 678 **3.5.4 Verification (or calibration)**  
679 Set of operations which is used to check whether the indications, under specified conditions,  
680 correspond with a given set of known measurands within the limits of a predetermined  
681 calibration diagram.  
682 [SOURCE: IEV 311-01-13]  
683
- 684 **3.5.5 Commissioning test**  
685 Test on an item carried out on site, to prove that it is correctly installed and can operate  
686 correctly.  
687 [SOURCE: IEV 151-16-24]  
688
- 689 **3.5.6 Maintenance test**  
690 Test carried out periodically on an item to verify that its performance remains within specified  
691 limits, after having made certain adjustments, if necessary  
692 [SOURCE: IEV 151-16-25]  
693
- 694 **3.5.7 Power x Time Measurement Method (Wattmeter Method)**  
695 A method by which the energy supplied to the meter(s) under test is determined by the  
696 product of a known constant power and a known interval of time.  
697
- 698 **3.5.8 Energy Comparison Measurement Method (Standard Meter Method)**  
699 A method by which a known amount of energy is supplied to the meter(s) under test.  
700
- 701 **3.5.9 Basic Measurements**  
702 Minimum Measurements to be made before commencing service from a new MTS  
703
- 704 **3.5.10 Control Measurements**  
705 Measurements for periodical check on the accuracy of MTS while in service.  
706
- 707 **3.5.11 Skilled operator**  
708 A skilled operator is any operator who has special skill, training, knowledge which they can  
709 apply to their work of calibration and testing.
- 710 **3.6 Definitions related to field (onsite) installations testing**
- 711 **3.6.1 Electro mechanical Meter**  
712 Meter in which currents in fixed coils react with the current included in the conducting  
713 moving element, generally (a) disc(s), which causes their movement proportional to the  
714 energy to be measured. [IEC 62052-11, 3.1.1]
- 715 **3.6.2 Static Meter**  
716 Meter in which currents and voltage act on solid state (electronic) elements to produce an  
717 output proportional to energy to be measured. [IEC 62052-11, 3.1.1]

### 718 3.6.3 Current transformer (CT)

719 An instrument transformer in which the secondary current, in normal condition of use, is  
720 substantially proportional to the primary current and differs in phase from it by an angle  
721 which is approximately zero for an appropriate direction of the connections.

722 [Source: IEV 312-02-01]

723

### 724 3.6.4 Voltage transformer (PT)

725 An instrument transformer in which the secondary voltage, in normal condition of use, is  
726 substantially proportional to the primary voltage and differs in phase from it by an angle  
727 which is approximately zero for an appropriate direction of the connections.

728 [Source: IEV 312-03-01]

729

### 730 3.6.5 Nominal burden SN

731 The burden or burden range in VA at secondary rated voltage for PT or current for CT indicated  
732 on the type plate of the measuring transformer. The specification of the measuring  
733 transformer based on this burden resp. burden range. Therefore the measuring transformer  
734 must be loaded with an impedance inside this range.

735

### 736 3.6.6 Operating burden $S_n$

737 Under the operating condition of the measuring transformer with reference meter measured  
738 burden in VA related to the secondary rated voltage for PT or current for CT.

739

### 740 3.6.7 Current measuring clamps

741 Inductive or with other alternating procedure working current transformer for measuring of  
742 test current which cannot connected direct to the reference meter.

743 The current measuring clamps are looped around the current leading wire. The measuring  
744 value of the clamp to the reference meter is proportional to the wire current and can be an  
745 AC current, DC current, DC voltage or their digital information.

746

### 747 3.6.8 Voltage measuring transformer

748 Inductive or with other alternating procedure working voltage transformer for measuring of  
749 test voltage which cannot connected direct to the reference meter.

750 The voltage measuring clamps are connected direct to the voltage leading wire. The  
751 measuring value of the clamp to the reference meter is proportional.

## 752 4. Components of meter test system

### 753 4.1 Laboratory Meter Test System

754 Laboratory Meter test Systems (MTS) are assemblies of sources, standard meter, error  
755 calculators and indication systems to supply test parameters to and determine error of the  
756 MUT. This assembly of MTS may be integrated in one unit or separate units.

757

758 The measuring procedures shall preferably automated. These AMTS are MTS which conducts,  
 759 controls and monitors the desired function(s) of meter testing through software/firmware.  
 760 These activities generally include the following minimum tasks:

- 761 • Setting, generating, monitoring and controlling the test parameter(s), within defined  
 762 limits and tolerances;
- 763 • Carrying out the test automatically, measuring, calculating and indicating the error  
 764 of the MUT;
- 765 • Storing and reporting the results in a non-editable and reusable database.  
 766

767 The purchaser and the supplier may mutually agree for further automation such as connecting  
 768 the meter and performing other activities automatically using agreed methods or techniques.  
 769

770 The AMTS generally includes the following components:

- 771 • Source;
- 772 • Standard meter;
- 773 • Scanning heads to detect the meter pulses or rotor marks;
- 774 • Error calculation system;
- 775 • Meter mounting fixtures;
- 776 • MSVT/ICTs (Refer note 1);
- 777 • Interface for data read outs of meter under test;
- 778 • Software.

779 Note 1: MSVT (Multi secondary voltage transformer) or ICTs (Isolating current transformer) have to be  
 780 included in the AMTS if more than 1 meter under test with permanent closed link to be tested. Both  
 781 transformer types are described and specified in Annex F and Annex G.

782 Note 2: To determine the error of the meters under test, scanning heads may be replaced by register  
 783 readings via interfaces of the AMTS if sufficient synchronism of the readings and/or sufficient register  
 784 resolution in the MUT can be achieved.

785 Note 3: Data read out ports have to be agreed between manufacturer and user.  
 786

## 787 4.2 Onsite (portable) Meter Test System

788 Onsite (Portable) Meter test systems are assemblies of portable Standard Meter, portable  
 789 sources, and the basic design of onsite (portable) test system shall be consisting of inbuilt  
 790 error calculator, display and connection panel. Onsite meter test system shall be suitable to  
 791 carry to meter installations for testing of energy meter or complete installation at onsite.  
 792 Testing of energy meter or the complete installation can be carried out on running load or on  
 793 desired load point using portable power source (phantom loading set).

794 Generally include the following minimum tasks:

- 795 • Connection to onsite with meter or installation, measuring, calculating and  
 796 indicating the error of the MUT;

797  
 798 Storing and reporting the results in a non-editable and reusable database. The purchaser and the  
 799 supplier may mutually agree for further features performing other activities using agreed methods  
 800 or techniques.  
 801  
 802  
 803  
 804

805  
806  
807  
808  
809  
810  
811  
812

The Onsite Meter test system generally includes the following components:

- Portable Standard meter
- Portable Power Source (option)
- Software

Note 1: Instead of separate sources and standard meters also combined devices (Calibrators) can be applied. Accuracy and environmental tests of both -sources and standard meters- are applicable for calibrators.

813  
814  
815  
816  
817  
818  
819  
820  
821  
822  
823  
824  
825  
826

## 5. Meter test methods

### 5.1 Introduction

The test methods described below can be used for all tests required for testing the MUTs. Modified or other test methods validated by National/International standards or publications, which fulfill the same requirements, may also be applied.

The test points and the required stability of the test signals shall be as specified in clause 6.2. The required accuracy of the standard meter and the complete MTS shall be as specified in Table 19 and Table 21.

### 5.2 Energy comparison method

A method by which a known amount of energy is supplied both to the MUT and the standard meter. This kind of test is also known as “register test” or “dial Test”. The percentage error for energy comparisons is calculated as follows:

$$\delta W_{MUT} = \frac{W_{MUT} - W_{st}}{W_{st}} \cdot 100\% \quad \text{Equation 11}$$

827  
828  
829  
830  
831  
832  
833  
834  
835

Where:

- $\delta W_{MUT}$  is the error of MUT in %;
- $W_{MUT}$  is the energy recorded by the MUT in kWh / kVAh / kVAh;
- $W_{st}$  is the energy recorded by the standard meter in kWh / kVAh / kVAh.

Sufficient test duration shall be selected in order to minimize errors caused by switching on-off & filter effect in the standard meter.

### 5.3 Power – time measurement method (watt-meter method)

A method by which the energy supplied to the meter(s) under test is determined by the product of a known constant power and a known interval of time.

836  
837  
838  
839  
840

$$\delta W_{MUT} = \frac{W_{MUT} - P_{st} \cdot t}{P_{st} \cdot t} \cdot 100\% \quad \text{Equation 12}$$

841  
842



843 Where:  
 844 WMUT is the energy recorded by the MUT  
 845 Pst is the power recorded by the standard meter, used for control the Constance.  
 846 t is the measuring time interval

847  
 848 Note 1: This method requires highly stable sources and accurate time controls.  
 849 Note 2: The overall uncertainties due to the stability of power and time intervals have to be considered.  
 850 Note 3: Due to the increased accuracy of electronic DTUs this method is seldom used.  
 851 Note 4: The measuring time should guarantee in minimum a progress of 200 digits of the lowest register  
 852 value, to reach a suitable measuring resolution accuracy.  
 853

#### 854 5.4 Pulse comparison method

855 For this method pulses of an energy proportional pulse output of a standard meter are  
 856 counted by a pulse counting device. The counter is started by a 1st pulse from MUT and is  
 857 stopped after completion of a given number of pulses from the MUT.

858 Pulses from energy meters can be generated with help of a scanning head, based on sensing  
 859 the rotor mark, or in case of static meters by a blinking LED or an electrical pulse output. A  
 860 suitable pulse adapter is needed.

861 For counting the pulses delivered by the standard meter the following conditions shall be met:  
 862 the test duration, at each test point, shall be selected so that the resolution error determined  
 863 by the number of pulses from the standard meter shall be less than 1% of the accuracy class  
 864 of the MUT. In case the manual or type approval of the MUT indicates a minimum test time  
 865 e.g. to fulfil the legal metrology requirements this time shall be used.

866 The percentage error of MUT can be calculated from the nominal and actual number of pulses  
 867 counted during the measurement period, as per the formula given below:  
 868

$$869 \delta W_{MUT} = \frac{N_{nom} - N_{act}}{N_{act}} \cdot 100\% \quad \text{Equation 13}$$

870 Where:  
 871  $\delta W_{MUT}$  = is the error of MUT in %  
 872  $N_{act}$  is the number of pulses actually received from the standard meter during the test  
 873  $N_{nom}$  is the number of pulses from the standard meter expected for the given measuring  
 874 period.

$$875 N_{nom} = \frac{3600 \cdot 1000 \cdot N_{MUT} \cdot f_{nom}}{m \cdot U_r \cdot I_r \cdot c_m} \quad \text{Equation 14}$$

877 Where:  
 878  $N_{MUT}$  is the number of pulses (or revolutions) of MUT.  
 879  $f_{nom}$  is the power proportional frequency output of standard meter;  
 880 m is the number of phases;  
 881  $U_r$  is the voltage range of standard meter;  
 882  $I_r$  is the current range of standard meter;  
 883  $c_m$  is the meter constant of MUT in [1/kWh] or [1/kVArh] or [1/kVAh].  
 884

885 If the error of the standard meter ( $\delta W_{st}$ ) needs to be considered determining the total error  
 886 of MUT the formula above has to be adapted by an additional term as follows:  
 887

$$\delta W_{MUT} = \left[ \left( \frac{N_{nom} - N_{act}}{N_{act}} \right) + \left( \frac{N_{nom}}{N_{act}} \cdot \frac{\delta W_{st}}{100\%} \right) \right] \cdot 100\% \quad \text{Equation 15}$$

888 Where  
 889  $\delta W_{MUT}$  is the error of MUT in %  
 890  $\delta W_{st}$  is the error of the standard meter in % (taken from calibration certificate).  
 891

## 892 5.5 Method for onsite meter testing

893 Before the beginning of the test the skilled operator must familiarize himself with the  
 894 connection diagram of the electricity meter installation by the available documentation and  
 895 marking.  
 896

897 From the documentation must be identified clearly:

- 898 - Connection diagram of the electricity meter installation
- 899 - rating of instrument transformers

900 -  
 901 For electricity meter installations must be made sure that:

- 902 - Electricity meter is connected in the correct phase sequence
- 903 - Polarity of the phases is not changed
- 904 - Screws of the connecting terminals are tightened

### 905 5.5.1 Checking of Wiring for connection of reference meter

906 Checking of Wiring must be done to check for possibilities of wiring errors of the electricity  
 907 meter installation according to type of installations:  
 908

- 909 - One or several voltage phases are not connected or interrupted
- 910 - One or several current phases are not connected or interrupted
- 911 - One or several current phases polarity is changed
- 912 - Voltage phases are changed
- 913 - Current phases are changed
- 914 - Voltage phases are changed cyclically
- 915 - Current phases are changed cyclically
- 916 - Voltage neutral is not connected

917  
 918 Note: in case of any abnormality in wiring of the installed meter is noticed, the same shall be  
 919 recorded and reported. The decision on conducting the test under the incorrect wiring or after  
 920 correcting the wiring shall be based on agreement between utility and test laboratory.  
 921

922 The connection of the reference meter (measuring point) is carried out near the MUT  
 923 terminals or extended terminals. The connection of the test current to the reference meter  
 924 can be done directly or using current measuring clamps.

925 Checking of Wiring can be done by reading the measuring values for current, voltage, power  
 926 and phase angles as well as the vector diagram. The measuring values found out must be  
 927 recorded.

928

929 **5.5.2 The measuring error for electricity meter at installation:**930 The meter test system used for testing electricity meters at installation as per IS 15707 shall  
931 comply with this standard.932 **5.5.3 Total measuring error of the electricity meter (LT CT operated) installations.**933 The meter test system used for testing electricity meters along with LT CT as per IS 15707 shall  
934 comply with this standard.

935

936 **5.6 Testing of smart meter / communicable meters**937 Test system may have capability to test smart meters complies with IS16444 (part 1 and Part  
938 2) and IS15959 (part 1, 2 and 3). The test shall be performed to prove the functionality of  
939 smart meters as per IS16444 (part 1 and 2) and IS15959 (Part 1, 2 and 3), refer Informative  
940 Annex I

941 Following facility may be included as a part of smart meter testing:

942 **5.6.1 Intensity test of optical data interface**

943 Refer clause 4.3.5.2 of IS/IEC62056-21.

944 **5.6.2 End to End testing**

945 Refer Informative Annex I

946 **5.6.3 Test for parameter verification as per IS15959 (part 2 and 3) of implemented  
947 commands**

948 Refer Informative Annex I

949 **5.6.4 Functional test**950 The Test system shall perform all the routine functional test as mentioned below  
951 simultaneously on all connected meters on the test bench over the communication port.952 **5.6.4.1 As per Table A30 of IS15959 Part2 and Table 29 of IS15959 Part3**

953 Test shall be performed as per informative Annex I

954 **5.6.4.2 Recommended test facility as per IS15959 part 2 and 3**

955 Test shall be performed as per informative Annex I

956 **5.6.5 Provision for Burden measurement of the smart meter:**957 Facility to measure burden (power consumption) as per clause no 6.10.1 of IS16444 (part  
958 1and 2) using suitable methods:

959 The power consumption in voltage circuit has to be measured in following conditions:

- 960
- During idle mode of communication module
  - If a separate module to service a IHD is present
  - During data transmission per communication module.

963 Under each of above mentioned condition the burden measurement in the voltage circuit  
964 shall be performed

965

966 Also provision for Burden measurement in current circuit shall be provided with Test  
967 System.

968 **5.6.6 Verification of electrical tamper conditions.**

969 Test shall be performed as per informative Annex I

970 **5.6.7 Influence of metrological stress on communication**

971 Test shall be performed as per informative Annex I

972 **5.6.8 Automatic testing of Communication:**

973 Test shall be performed as per informative Annex I

974 **6. Standard electrical values**975 **6.1 Mains supply**

976 The mains supply voltage shall be sufficiently stable to ensure a suitable accuracy of all  
 977 components of the MTS necessary for testing meters of the given accuracy class. If necessary,  
 978 mains supply voltage regulators shall be used with stationary equipment. The requirement  
 979 are shown in Table 2.

980

*Table 2 Mains power supply condition*

Parameter	Value
Supply voltage $U_n$	230 V
Variation in supply voltage	0.85 $U_n$ to 1.1 $U_n$
Frequency $f_n$	50Hz
Frequency range	$f_n \pm 2\%$
Power consumption	Shall be specified by the manufacturer
Neutral to ground voltage	< 2V
Voltage quality of mains supply	As specified in IS12360

981

982

983

984

Note: The MTS manufacturer may specify equipment to operate correctly under the mains conditions beyond specified above; however under such conditions the performance of MTS shall be within the specified limits in this standard.

985

**6.2 Output values and ranges of the test circuits**

986

**6.2.1 Test voltage circuit**

987

988

989

990

The test voltage circuit shall provide output voltage range as required for testing of meter as per relevant MUT standard to ensure suitable load conditions and accuracy. The requirement are shown in Table 3

*Table 3 Test voltage circuit each phase*

Parameter	Standard Electricity meter			Smart and prepayment Electricity meter	
	Direct connected meter	LT-CT operated Meter	CT-PT operated meter	Direct connected meter	Transformer operated Meter
Test circuit voltage range, $U$ (r.m.s. Phase to neutral voltage):	30V to 300V		30 to 85V	30V to 300V	30V to 85V
Setting resolution	0.1V		0.01V	0.1V	0.01V
Accuracy of the amplitude	$\pm 0.1\%$ of the test value				

Stability (S) of the amplitude	<100 x 10 <sup>-6</sup> (with T = 60 s, N = 10) <500 x 10 <sup>-6</sup> (with T = 5 s, N = 24)	
Distortion factor at linear load	< 0.5%	
Maximum d.c. voltage permitted	<0.2%	
Minimum output power per meter test position	15 VA r.m.s at the high end of the voltage range and at resistive loads	25 VA r.m.s at the high end of the voltage range and at resistive loads
Protection	The output circuit shall be protected against short circuit and overload	
NOTE 1 The value in above table are indicative, covering the requirement of directed connected and transformer operated meters requirement as per relevant Indian Standard. The values beyond this can be agreed between purchaser and manufacturer.		
NOTE 2 The purchaser should specify if the MTS should be designed for single phase or three phase meter testing. The values given above shall be valid for each phase.		
NOTE3 The purchaser and the manufacturer may agree for any suitable value for output power considering the peak current drawn by the power supply of MUTs.		
NOTE4 A particular MTS may be suitable to cover more than one standard covering all ranges required by different metering standards		

991

992

### 6.2.2 Test current circuit

993

The test current circuit shall provide several current ranges to ensure suitable load conditions and accuracy. The requirement are given in Table 4

994

*Table 4 Test current circuit each phase*

995

Parameter	Standard Electricity meter			Smart and prepayment Electricity meter	
	Direct connected meter	LT-CT operated Meter	CT-PT operated meter	Direct connected meter	Transformer operated Meter
Test circuit current range I: r.m.s value	5mA to 100A	5mA to 10A	1mA to 10A	5mA to 100A	1mA to 10A
Setting resolution	0.1mA to 10 mA (depending on range)				
Accuracy of amplitude of I	±1.0 % (1 mA ≤ I < 10 mA) ± 0.5% (10 mA ≤ I < 50 mA) ± 0.1% (50 mA ≤ I < 100 A)				
Stability (S) of amplitude	< 100 x 10 <sup>-6</sup> (with T = 60s, N = 10) < 500 x 10 <sup>-6</sup> (with T = 5s, N = 24) for I > 50 mA				
Distortion factor at linear load	< 0.5%				
Maximum permitted DC current	< 0.1 % of test current				

Minimum output power per meter test position.	Minimum 30 VA r.m.s at the end of range and at resistive loads
Protection	Output circuit shall be protected against open circuit and overload
<p>NOTE 1 The value in above table are indicative, covering the requirement of directed connected and transformer operated meters requirement as per relevant Indian Standard. The values beyond this can be agreed between purchaser and manufacturer.</p> <p>NOTE 2 The purchaser should specify if the MTS shall be designed for single phase meter testing or three phase meter testing. The values given above shall be valid for each phase.</p> <p>NOTE 3 The values mentioned above are indicative and considering ideal conditions. The purchaser and the manufacturer may agree on any suitable value for maximum current and / or power ratings, considering distance, connectivity and the use of isolating current transformers.</p> <p>NOTE 4 A particular MTS may be suitable to cover more than one standard covering all ranges required by different metering standards.</p> <p>NOTE 5 The above specified VA rating shall be available at the terminals for connection of each MUT position.</p>	

996 (Values are taken from IEC 62057-1 standard)

### 997 6.2.3 Phase angle

998 The requirement are given in Table 5.

999 *Table 5 Setting of phase angle between each phase voltage and current circuit*

Parameter	Limits
Range of phase angle	0 to 360 deg
Setting resolution	0.01°
Stability (S) of the angle setting	0.1° (with T = 60s, N = 10)
Accuracy of setting	± 0.1°
Angle between phase voltages	120 deg ± 1deg

1000 (Values are taken from IEC 62057-1 standard)

### 1001 6.2.4 Frequency

1002 The requirement are given in Table 6.

1003 *Table 6 Setting of frequency*

Parameter	Value
Range of frequency	As per requirement of relevant MUT standard
Setting resolution	0.01 Hz
Stability (S) of the frequency setting	0.1 Hz (for an integration time T = 60s, N = 10)
Accuracy of setting	± 0.01 Hz

1004 The values are specified considering the overall uncertainty measurement requirement of  
1005 metrology test.

### 1006 6.2.5 Harmonics

1007 The superimposition of harmonics may be possible in voltage and current circuit. The  
1008 requirement are given in Table 7.

1009

*Table 7 Setting of harmonics*

Parameter	Value
Harmonic range (frequency and amplitude)	As per requirement of relevant MUT standard
Setting resolution	Maximum 1% of fundamental frequency amplitude
Phase angle with respect to fundamental frequency	0° to 180°
Accuracy of setting	Amplitude: 1% Phase angle: 1° related to fundamental
NOTE The source may be capable to generate signal of Odd harmonics and Sub harmonics according to Annex C (informative). Generation of higher harmonic may be agreed between the purchaser and the manufacturer.	

1010 (Values are taken from IEC 62057-1 standard)

## 1011 6.3 Standard meter

### 1012 6.3.1 Accuracy class

1013 The accuracy of the standard meter should be 10 times better than the accuracy class of the  
1014 MUT. To meet the better uncertainty requirement for metrology, reference meter are also  
1015 available. However in case of higher accuracy class of DUC then next higher available accuracy  
1016 shall be selected. The recommended accuracy classes for the reference meter as per Table 18  
1017 are 0.01%, 0.02%, 0.05%, 0.1% and 0.2%. Other accuracy classes can be agreed between the  
1018 purchaser and manufacturer.

### 1019 6.3.2 Standard electrical values

1020 The standard electrical values for standard meter are given in Table 8.

1021

*Table 8 Standard electrical values for the standard meter*

Parameter	Standard value
Mains supply	Un (as defined in 6.1)
Voltage measuring range	30 V to 300 V (phase to neutral) <sup>1)</sup>
Current measuring range	1 mA to 120 A
Frequency measuring range	45 Hz to 55 Hz
Minimum frequency bandwidth	Up to 1050 Hz (21st harmonic of 50 Hz)
Measurement mode for single phase MTS	1 ph 2 wire active / reactive
Measurement mode for three phase MTS	1 ph 2 wire active / reactive 3 ph 4 wire active / reactive and apparent 3 ph 3 wire active / reactive and apparent
Frequency output	The standard meter shall provide a power proportional frequency output for calibration and measuring purposes.

Interface	The standard meter shall have interface(s) for communication & control
1)The maximum value of current and voltage can be mutually agreed between purchaser and manufacturer	

1022 (Values are taken from IEC 62057-1 standard)

1023

#### 1024 6.4 Magnetic field of the MTS

1025 The magnetic induction produced by the MTS at the position of the meter(s) under test and  
1026 given current and frequency ranges according to Table 8 shall not exceed the following values:

1027 For  $I \leq 120$  A  $B \leq 0.05$  mT

1028

1029 (As per limits specified in Reference condition table of IS13779:2020 and IS14697:2021)

1030

1031 Where:

- 1032 •  $I$  is the output current of the MTS;
- 1033 •  $B$  is the magnetic induction in air due to the magnetic field ( $B = \mu_0 H$ ).
- 1034 • The test shall be performed without MUT and current circuit shall be short circuited.

1035

#### 1036 6.5 Electrical and mechanical values for the scanning head(s)

1037 *Table 9 Electrical and mechanical values for the scanning head(s)*

Parameter	Standard value
Receiver diode	To sense the optical test output according to IEC 62052-11 clauses 5.11.1 & 5.11.2
Distance to the LED of the MUT	From 10 mm to minimum 60mm
Minimum impulse duration detection	100 $\mu$ s for LED sensing of electronic MUT
Distance to rotor disk	Up to 45 mm
1) If the LED of the MUT radiates with the maximum strength specified in IEC 62052-11 & IS15884 (1000 $\mu$ W / cm <sup>2</sup> ) the distance rises to 60 mm. 2) In case of changes in the IEC62052-11 the relevant changes will be applicable.	

1038

#### 1039 6.6 Error calculation system

##### 1040 6.6.1 Functional requirements

1041 The error calculation system receives pulses from the scanning head(s) or from the pulse  
1042 output of the MUT(s) and compares those with pulses received from the standard meter. The  
1043 error calculation system shall be able to count pulses and to calculate and indicate the  
1044 percentage error of one or more MUTs.

1045 This system shall have the following standard functions:

- 1046 • The system shall indicate, for each MUT, the error along with the sign (+ or -);
- 1047 • A reset function shall be available allowing to reset the error indication in the case the error  
1048 measurement is wrong for any reason;
- 1049 • The system shall provide the parameters of the error calculation process for verification  
1050 purposes.



1051 Additional functionalities may be agreed between purchaser and manufacturer.

1052 Error shall be displayed with suitable indicator at each meter test position for MUT. The error  
1053 indication shall be clearly visible to the operator from viewing angle of 170 degree.

## 1054 6.6.2 Electrical values for error calculation system

1055 *Table 10 Electrical values for the error calculation system*

Parameter	Standard value
Pulse frequency range, which the system shall be able to count	0 to 1 kHz
Resolution of error indication	Minimum 0.01 %
Indication of the error	± indication, digits and unit in %
Accuracy	± 1digit of the lowest digit

## 1056 7. Constructional requirements of the MTS

### 1057 7.1 General requirements

1058 The MTS shall be of protective class I according to IEC 61140 (clause no. 7.3) or protective  
1059 class II according to IEC 61140 (clause no. 7.4). All parts which are subject to corrosion under  
1060 normal working condition shall be protected effectively. Any protective coating shall not be  
1061 liable for damage by ordinary handling nor damages due to exposure to air under normal  
1062 working conditions.

1063 IP class for Laboratory MTS shall be IP20 or higher. For Onsite equipment IP class shall be  
1064 IP51 with carrying case and IP20 or higher without carrying case as to be used in operating  
1065 condition.

1066 As per IEC 60664-1 Over voltage category CATIII or higher shall be provided for onsite  
1067 equipment. Over voltage category CAT-II or higher shall be provided for Laboratory  
1068 Equipment.

### 1069 7.2 Source and standard meter

1070 The source and the standard meter may constitute a stand-alone unit or they may be located  
1071 in the meter mounting system. If they are permanently connected to the MTS, then MTS shall  
1072 have a protective connection terminal to Connect MUT with it. Operator shall be prevented  
1073 to expose to live parts in normal operation.

1074 Connection among reference meter, source and MUT shall not be exposed and shall not be  
1075 hazardous to operator.

1076 Protective earthing on MTS shall be provided according to Category of Protection.

1077 The standard meter shall have frequency output proportional to measured power/energy for  
1078 its calibration with higher accuracy standards.

### 1079 7.3 Meter mounting system

#### 1080 7.3.1 General


1081 The meter mounting system is a rack including the necessary constructional requisites and  
1082 the connections, designed to allow meters to be tested under the test conditions specified in

1083 the relevant standards. The wiring layout and cross sections should be suitably selected in  
 1084 order to minimize voltage drop, power losses, magnetic induction and capacitive interference.

1085 It shall be designed to accommodate the number of MUTs specified, together with the  
 1086 scanning heads, error calculation and display units, and, when required, secondary voltage  
 1087 transformers (MSVT) and / or isolated current transformers (ICT) for each MUT position.

1088 The design of the bench shall be agreed by the manufacturer and purchaser.

1089 *Figure 1- Block diagram of Lab MTS*



1090

## 1091 7.3.2 Terminals

### 1092 7.3.2.1 General

1093 The purchaser and the manufacturer shall agree on the terminals where the output values of  
 1094 the MTS are specified. All the terminals shall be safety terminals i.e. no live parts shall be  
 1095 exposed.

1096 NOTE: These terminals may be the terminals of the source or one of the MUT positions.

1097 All parts of each terminal shall be such that the risk of corrosion/oxidation resulting from  
 1098 contact with any other metal part is minimized.

1100 Electrical connections shall be designed to avoid contact pressure transmitted through too  
 1101 flexible insulating material.

### 1102 7.3.2.2 Test voltage output terminals

1103 Each meter test position shall have voltage output terminals, according to the number of  
 1104 phases. These terminals may be connected in parallel to the voltage source directly, or via  
 1105 MSVTs. Normally In case of single phase meter secondary terminals of the ICT cables do not  
 1106 match with the size of low rating single phase meters and/or sufficient VA rating are not  
 1107 available, to meet the VA burden and connection requirement, the MSVT shall be used.

1108  
 1109 The terminals shall be equipped with sockets of 1000V, CAT III according to IEC 61010-031,  
 1110 6.5.2.1 that prevent an accidental touch of hazardous live parts.

1111  
 1112 The wiring shall ensure that the accuracy requirements and the reference test conditions are  
 1113 met at each meter test position.

1114  
 1115 In case of MSVT it should meet requirement of Annex E

1116  
 1117 NOTE: Voltage cables supplied with the MTS shall be rated for the maximum test voltages and shall meet the  
 1118 requirement of CATIII, 300V as per IEC61010-1.  
 1119

### 1120 7.3.2.3 Test current terminals

1121 The meter mounting system shall have current in and output terminals according to the  
 1122 number of phases. These terminals may be connected in series to the current source directly,  
 1123 or via ICTs (refer to Annex F). In case of voltage and current terminals of meter under test are  
 1124 permanently connected or inseparable, ICT shall be used as isolation medium.  
 1125 The current terminals shall be able to carry the maximum test currents continuously, without  
 1126 forced cooling condition under the operating conditions specified.

1127  
 1128 It shall be possible to open the current circuits without dangerous voltages arising.

1129  
 1130 NOTE: The manufacturer and the purchaser may agree on the connection method for example using free wiring  
 1131 or quick connectors. Quick connectors is a pre-assembly of prongs designed for the terminal block of MUT. By  
 1132 means of a mechanical lifter all prongs contact the terminal of the terminal block simultaneously.  
 1133

### 1134 7.3.2.4 Onsite Meter test system with carrying case

1135 The case of the portable reference meter/power source must be adapted to the  
 1136 environmental conditions of the electricity meter installation for which they may be used.  
 1137 For transportation the portable reference meter must be resistant against the listed vibration  
 1138 and shock conditions in without influence on function and accuracy. If required these  
 1139 conditions can be achieved by a suitable protection case. Protective class shall be as per clause  
 1140 7.1.

1141  
 1142 Portable Reference meter/source with carrying case (if specified by manufacturer) shall confirm  
 1143 to following requirement.  
 1144

#### 1145 7.3.2.4.1 Vibration:

1146 The test shall be carried out as per IS 9000 (Part 8) under the following conditions:

1147 a) MTS in non-operation condition with carrying case in position as preferred by manufacturer during  
 1148 transportation

1149 b) Frequency range: 10 – 150 – 10 Hz.

1150 c) Transition frequency ( $f$ ):  $60 \pm 3$  Hz.

1151 d) Frequency below  $f$ : constant amplitude of movement 0.15 mm

1152 e) Frequency above  $f$ : constant acceleration 2 g ( $1g = 9.8 \text{ m/s}^2$ )

1153 f) Single point control

1154 g) Number of sweep cycles per axis: 10

1155 NOTE — 10 sweep cycles = 75 minutes

- 1156
- 1157 **7.3.2.4.2 Shock**
- 1158 The test shall be carried out as per IS 9000 (Part 7/Sec 1) under the following conditions:
- 1159 a) MTS in non-operation condition with carrying case;
- 1160 b) Half-sine pulse;
- 1161 c) Peak acceleration: 40 g (400 m/s<sup>2</sup>); and
- 1162 d) Duration of the pulse: 18 ms
- 1163 Number of shock: two in both direction of three mutual perpendicular axes (Total of 12 shocks).
- 1164
- 1165 For both test mentioned above, after the test the equipment shall functional properly and
- 1166 performance of the equipment shall not be degraded.

## 1167 8. Information and Marking requirement

### 1168 8.1 General

1169 NOTE: This clause 8 is based on the following references:

- 1170 • IEC 62052-11 sub-clause 5.12, IEC 62052-21 sub-clause 5.12, IEC 62055-31 sub-clause
- 1171 5.13; IEC 62052-31
- 1172 • IS 13779:2000 clause no. 7, IS 14697 :1999 clause no. 7, IS 15884,
- 1173 • IEC 61010-1 clause 5; and
- 1174 • IEC 62477-1 Clause 6

1175

1176 The purpose of this Clause is to define the information necessary for the safe selection,

1177 installation and commissioning, use, and maintenance of a MTS. The required information is

1178 presented in Table 11 showing where the information shall be provided, with reference to

1179 explanatory sub-clauses.

1180

1181 The requirements of this Clause 8 apply to all MTS, unless otherwise stated.

1182

1183 All information shall be in an appropriate language, and documents shall have identification

1184 references.

1185 *Table 11 Information requirements*

Information For selection	Sub-clause reference	Location a b				Technical sub-clause reference
		C	IM	UM	MM	
<b>General information</b>	8.3					
Manufacturer's name or trade mark		X	X	X	X	
Designation of function, and type		X	X	X	X	
Space for approval mark (if any)		X	X	X	X	
Place of manufacture		X				
Serial number		X				
Protective class		(X)	X		X	8.4.4.1
Environmental conditions, storage			X		X	9.1
Environmental conditions, operation			X		X	9.1
Reference temperature if different from 23 °C			X		X	9.1

Information For selection	Sub-clause reference	Location a b				Technical sub-clause reference
		C	IM	UM	MM	
Owner specified information						
Reference to standards			X		X	
Reference to instructions			X	X	X	
Fuse ratings		X	X	X	X	
Supply voltage, frequency, max. apparent power, number of phases		X	X	X	X	6.1
<b>For standard meters</b>						
Measuring voltage range	8.3.2, 8.3.3	X	X	X	X	6.3.2
Measuring current range		X	X	X	X	6.3.2
Measuring frequency range		X	X	X	X	6.3.2
Number of phases, number of wires, service type(s)			X	X	X	6.3.2
Accuracy		X	X	X	X	6.3.1
<b>For sources, generators</b>						
Voltage, Current and Power	8.3.4	X	X	X	X	6.2.1, 6.2.2, 6.2.3
Product specific markings		X	X	X	X	
<b>ICTs and MSVTs</b>						
Measuring range	8.3.5	X	X	X	X	E.4.1
Frequency range		X	X	X	X	E.4.1
Accuracy		X		X		E.4.1
Output power		X	X	X	X	E.4.1
<b>For Clamp on Transformers</b>	8.3.6					
Accuracy		X	X	X	X	
Rating		X	X	X	X	
Insulation class (category)		X		X		
<b>For the communication interfaces and error calculators</b>	8.3.7					
Product specific markings		X	X	X	X	
Communication medium		X	X	X	X	
<b>For meter installations</b>	8.3.8					
<b>For installation and commissioning</b>	8.4					
Dimensions and mass	8.4.2		X		X	
Connection requirements	8.4.3		X			
Connecting cables identification	8.4.3.2	X	X		X	
Connection and wiring diagrams	8.4.3.3		X		X	
Auxiliary terminals	8.4.3.4	X	X		X	
Protection requirements	8.4.4	X				
Protective class and earthing	8.4.4.1		X		X	
Self-consumption	8.4.5		X		X	
<b>For user</b>						
General	8.5			X		

Information For selection	Sub-clause reference	Location a b				Technical sub-clause reference
		C	IM	UM	MM	
Display, push buttons and other controls	8.5.2			X		
Connection to other equipment	8.5.3			X		
External protection devices	8.5.4			X		
Cleaning	8.5.5			X		
<b>For maintenance</b>	8.5.6				X	
<p>a Location:  C= Case. These markings may appear on nameplate(s) or may be carried by the unit cover(s) in a permanent manner;  IM = Installation manual;  UM = User’s manual;  MM = Maintenance manual.</p> <p>b The installation, user’s and maintenance manuals may be combined as appropriate and, if acceptable to the customer, may be supplied in electronic format.  X – for all type of equipment  (X) – only for portable onsite equipment</p>						

1186

## 1187 8.2 Labels, signs and signals

1188 Labelling shall be in accordance with good ergonomic principles so that notices, controls,  
1189 indications, test facilities etc. are sensibly placed and logically grouped to facilitate correct  
1190 and unambiguous identification.

1191 All safety related equipment labels should be placed in such a way that they will be readily  
1192 visible to the intended viewer and alert the viewer to any hazard in time to take appropriate  
1193 action.

1194 Graphic symbols shall conform to IEC 62053-52, IEC 60417, IEC 60617, ISO 7000, as  
1195 appropriate. IEC 60417-2 and ISO 7000 symbols that may be used on metering equipment are  
1196 shown in Annex A. Symbols not shown in these standards shall be explained where used.  
1197 There are no color requirements for symbols.

1198  
1199 The documentation of the MTS equipment shall include a statement that it must be consulted  
1200 in all cases where symbol 14 of Table 29 is marked, in order to find out the nature of the  
1201 potential hazards and any actions which have to be taken to avoid them.

1202  
1203 Safety signs shall comply with ISO 3864-1.

1204  
1205 The signal words indicated hereinafter shall be used and the following hierarchy

1206  
1207 **DANGER** to call attention to a high risk, for example: “High voltage”;

1208 **WARNING** to call attention to a medium risk, for example: “This surface can be hot.”

1209 **CAUTION** to call attention to a low risk, for example; “Some of the tests specified in this  
1210 standard involve the use of processes imposing risks on persons concerned.”  
1211

1212 Danger, warning and caution markings on the metering equipment shall be prefixed with the  
 1213 word “DANGER”, “WARNING”, or “CAUTION” as appropriate in letters not less than 3.2 mm  
 1214 high. The remaining letters of such markings shall be not less than 1.6 mm high.  
 1215

### 1216 8.3 Information for selection

#### 1217 8.3.1 General

1218 MTS shall be provided with information relating to its function, electrical characteristics and  
 1219 intended environment, so that its fitness for purpose can be determined. This information  
 1220 includes, but is not limited to the following.  
 1221

#### 1222 8.3.2 General Information

1223 For MTS equipment following general information shall be provided:

- 1224 • Manufacturer’s name or trade mark;
- 1225 • Designation of type;
- 1226 NOTE 1 Designation of the function shall be preferably in English language.
- 1227 • Approval mark or space for it, if required;
- 1228 • Place of manufacture, if required;
- 1229 • Serial number;
- 1230 • Protective class;
- 1231 • Environmental conditions for storage;
- 1232 • Reference temperature if different from 27 °C;
- 1233 • Owner-specified information, as agreed by the manufacturer and the purchaser;
- 1234 • Reference to instructions for installation, operation and maintenance.

#### 1235 8.3.3 Information related to standard meters

1236 For standard meters, the following information shall be provided in accordance to the  
 1237 relevant product standards for the MUT:  
 1238

- 1239 • Measuring voltage,
- 1240 • Measuring current;
- 1241 • Frequency range;
- 1242 • Service type. This implies:
  - 1243 - The number of phases;
  - 1244 - The number of wires for which the meter is suitable.
- 1245 • Quantities measured. This implies:
  - 1246 - Active energy;
  - 1247 - Reactive energy;
  - 1248 - Apparent energy;
  - 1249 - Voltage;
  - 1250 - Current;
  - 1251 - Frequency;
  - 1252 - Phase angle.
- 1253 • Measuring principle (according to clause 3.2);
- 1254 • Accuracy (related to the measured quantity).

1255

1256 **8.3.4 Information related to sources, error calculator and frequency generators**1257 The equipment includes frequency generators, error calculators and voltage and current  
1258 sources. For these, the following information shall be provided:

- 1259 • The type & value of auxiliary supply voltage (a.c. or d.c.);
- 1260 • The measuring range (if applicable);
- 1261 • The maximum power consumption

1262 For sources, following additional information shall be provided:

- 1263 • Output specifications for voltage ranges in respect to frequency;
- 1264 • Output specifications for current ranges in respect to frequency;

1265

1266 For sources, the following information shall be suitably displayed:

- 1267 • The active operating range;
- 1268 • On/Off status;
- 1269 • Faults;
- 1270 • The actual value of voltage;
- 1271 • The actual value current.
- 1272 • The actual value of frequency

1273 **8.3.5 Information related to the ICTs and MSVTs**

1274 For ICTs and MSVTs, the following information shall be provided

1275

- 1276 • Voltage range / max. load and accuracy for MSVTs;
- 1277 • Current range / max. load and accuracy for ICTs;
- 1278 • Frequency range.

1279

1280 **8.3.6 Information related to clamp on transformers**1281 Connections of different current and voltage measuring clamps as well as connections with  
1282 the same plug connector types and design must mechanically be fixed against wrong  
1283 connection and shall be suitably marked for

- 1284 • Polarity of cable passing/connecting
- 1285 • Polarity of connector to equipment
- 1286 • Primary Current/voltage range
- 1287 • Secondary current/voltage range
- 1288 • Accuracy (if any)
- 1289 • Protection class

1290

1291 **8.3.7 For the communication interfaces and error calculators**

1292 For these devices, the following information shall be provided:

- 1293 • Communication medium and the relevant standard(s), status information.

1294

1295 **8.3.8 For the meter installations**1296 Suitable connection diagram to meter installation shall be elaborated in the equipment  
1297 manual.



## 1298 8.4 Information for installation and commissioning

### 1299 8.4.1 General

1300 Safe and reliable installation is the responsibility of the installer. The manufacturer of MTS  
1301 shall provide information to support this task. This information shall be unambiguous, and  
1302 may be in diagrammatic form.

1303  
1304 NOTE Since any electrical equipment can be installed or operated in such a manner that hazardous conditions  
1305 can occur, compliance with the requirements of this standard does not by itself assure a safe installation.  
1306 However, when equipment complying with those requirements is properly selected and correctly installed,  
1307 commissioned and used, the hazards will be minimized.

### 1308 8.4.2 Dimensions and weight

1309 The following information shall be provided by the manufacturer:

- 1310 • Dimensions and layout.
- 1311 • Weight

### 1312 8.4.3 Connection

#### 1313 8.4.3.1 General

1314 Information shall be provided to enable the installer to make safe electrical connections to  
1315 the MTS. This shall include information for protection against hazards.

#### 1316 8.4.3.2 Connecting cables

1317 NOTE: generally, national regulations are in place concerning electrical installations. These regulations, among  
1318 others specify the type and size of the connection cables to be used.

1319 The installation manual shall include a statement that the installer shall consult the local  
1320 regulations. The installation manual shall contain recommendations for the type of  
1321 connecting cables to be used. Recommended cable terminations and requirements for  
1322 tightening torque values shall be specified as well wherever applicable. The cables and  
1323 connections shall be CATII/CATIII/CATIV compliance and marking on it.

#### 1324 8.4.3.3 Connection diagrams

1325 Every MTS shall be provided with a diagram of connections. If the terminals are marked, this  
1326 marking shall appear on the diagram.

#### 1327 8.4.3.4 Auxiliary terminals

1328 Terminals and connectors of auxiliary circuits shall be readily identifiable by the equipment  
1329 markings. The following information shall be provided in the documentation as far as  
1330 relevant for safety and as applicable:

- 1331 • The function(s): e.g. pulse input/output, control input/output;
- 1332 • The kind of the circuit(s), e.g. opto-coupler, relay, solid state relay;
- 1333 • Kind of voltage (a.c. or d.c.), nominal, minimum and maximum voltages.
- 1334 • Nominal and maximum frequency as applicable.

### 1335 8.4.4 Protection

#### 1336 8.4.4.1 Protective class and earthing

1337 Laboratory MTS may be connected to the mains via a plug or permanently. As the  
1338 equipment is of protective class I a protective conductor shall be provided.

1339 The installation manual shall include a statement how the earth wire is or shall be  
1340 connected.

#### 1341 8.4.5 Self-consumption

1342 For the supply circuits of the portable MTS and for auxiliary circuits the following  
1343 information shall be provided in the instruction and maintenance manuals.

1344 The maximum power consumption in watts (active power) or volt-amperes (apparent  
1345 power), or the maximum rated input current, with all accessories or plug-in modules  
1346 connected but without MUT

### 1347 8.5 Information for use

#### 1348 8.5.1 General

1349 The user's manual shall include all information regarding the safe operation of the MUT. In  
1350 particular, it shall identify any hazardous materials and risks of electric shock, overheating,  
1351 explosion, excessive acoustic noise, etc.

1352 All safety marking shall be clearly explained.

1353 The user's manual shall also indicate any hazards, which can result from reasonably  
1354 foreseeable misuse of the metering equipment.

#### 1355 8.5.2 Display, push buttons and other controls

1356 The user's manual shall provide a description of the main items that can be displayed/  
1357 visualized at the MTS.

#### 1358 8.5.3 Connection to user's equipment

1359 If connection of user's equipment is possible, the necessary connection diagrams, the  
1360 identification, marking and description of the connectors, and the necessary operations shall  
1361 be provided.

1362 The user's manual shall also indicate any hazards, which can result from connecting user's  
1363 equipment.

#### 1364 8.5.4 External protection devices

1365 If external protection devices such as fuses and circuit breakers may be operated by the user,  
1366 then any safety hazards related to their operation shall be explained in the user's manual of  
1367 the MTS.

#### 1368 8.5.5 Cleaning

1369 The user's manual shall provide information for cleaning if applicable.

#### 1370 8.5.6 Information for maintenance

1371 Safety information shall be provided in the installation and maintenance manuals including,  
1372 the following (as and if applicable):

- 1373 • Preventive maintenance procedures and schedules;
- 1374 • Safety precautions during maintenance;
- 1375 • Location of live parts that can be accessible during maintenance (for example, when  
1376 covers are removed);
- 1377 • Adjustment procedures;

- 1378
- 1379
- 1380
- 1381
- Sub-assembly and component repair and replacement procedures;
  - Information on safe disposal of the equipment and any replaceable parts;
  - Verification of the safe state of the equipment after repair;
  - Any other relevant information.

## 1382 9. Climatic conditions for the MTS

### 1383 9.1 Normal environmental conditions

1384 The MTS shall be designed to operate under the following climatic conditions.

1385 *Table 12 Normal Environmental condition*

Parameter	For lab use	For Onsite use
Nominal Temperature for operation <sup>note1</sup>	15°C to 35 °C	0°C to 45 °C
Humidity	Per Annexure B of IS13779:2020	Per Annexure B of IS13779:2020
Climatic condition for storage & transport	Low air temperature (-) 25°C, High air temperature + 70 °C, high relative humidity 75% Storage and transport of the MTS at the extremes of this temperature range should only be for a maximum period of 6 h.	Low air temperature (-)25°C, High air temperature + 70 °C, high relative humidity 75% Storage and transport of the MTS at the extremes of this temperature range should only be for a maximum period of 6 h.
Limit range of operation	0°C to 45 °C	-10°C to +50 °C
a See IEC 60721-3-3: (IS 13736 latest amendment)		
b See IEC 60721-3-2.		
Note1: Accuracy may be deviated as per defined temperature coefficient as defined in this standard.		

### 1387 9.2 Temperature limits

1388 The temperature of easily touched surfaces shall not exceed the values of Table 12 at the maximum

1389 temperature of the operating range.

1390 *Table 13 Surface temperature limits*

Part	Limit Deg. C
1) Outer surface of enclosure parts likely to be touched (approx. 1 s)	
a) metal, uncoated or anodized	65
b) metal, coated (paint, nonmetallic)	75
c) glass and ceramics	80
d) plastics	85
2) User operated devices	
a) metal	55
b) glass and ceramics	65
c) plastics	70
NOTE: ISO13732-1 gives information about the effect of the duration of contact.	

1391 (Values taken from IEC62057-1)

## 1392 10. Electrical requirements of the MTS

### 1393 10.1 Influence of mains supply

1394 The MTS and its components shall be designed to work under the mains supply conditions  
1395 as described Annexure B without affecting the guaranteed accuracy class.

### 1396 10.2 Insulation

#### 1397 10.2.1 General

1398 The MTS and its incorporated components shall retain adequate dielectric qualities under  
1399 normal conditions of use.

#### 1400 10.2.2 Clearances and Creepage distances

1401 Clearances and Creepage distances shall comply with the requirements of IEC 61010-1 for  
1402 minimum overvoltage category II and with the requirements of IEC 61010-031 for  
1403 measurement minimum category II.

1404 For onsite testing equipment the minimum overvoltage category III.

#### 1405 10.2.3 Verification of clearances and creepage distances

##### 1406 10.2.3.1 Verification by measurement

1407 Verification of clearances and creepage distances shall be performed as specified in IS/IEC  
1408 60664-1 sub-clause 6.2.

##### 1409 10.2.3.2 Verification of clearances using impulse voltage tests

1410 The clearances shall be verified by performing the impulse voltage tests as specified in IEC  
1411 60664-1. These are type tests and refer to the single components of a MTS.

#### 1412 10.2.4 A.C. voltage test

##### 1413 10.2.4.1 Test voltage

1414 Test has to perform in accordance to IEC62052-31 sub clause 6.10.2.5. The test voltage shall  
1415 be substantially sinusoidal, having a frequency between 45 Hz and 65 Hz, and applied for  
1416 60s. The power source shall be capable of supplying at least 500 VA.

1417  
1418 The source voltage shall be verified with an accuracy of better than 3%.

1419  
1420 The voltage shall be applied to the test object starting at a value sufficiently low to prevent  
1421 any effect of over voltages due to switching transients. It shall be maintained for the specified  
1422 time and then rapidly decreased, but not suddenly interrupted as this may generate switching  
1423 transients which could cause damage or erratic test results.

##### 1424 10.2.4.2 Performing the tests

1425 The test voltages and the points of application are specified in Table 14.

1426 Each component of the lab MTS shall be treated and tested as a MUT:

- 1427 • Voltage and current source;
- 1428 • Standard meter
- 1429 • Meter test rack

1430  
1431 Note: for Onsite testing portable equipment it shall be perform on reference meter or source wherever applicable.  
1432

- 1433 For Onsite testing equipment:  
 1434 The tests are carried out during the manufacturing of a newly manufactured meter test unit.  
 1435 The test voltages and the points of application are specified in Table 14 (on standard meter  
 1436 and source).  
 1437 Each test equipment shall be treated and tested individually as a single MUT:  
 1438 • Portable source;  
 1439 • Portable standard meter (if applicable)  
 1440 • Portable Meter Test Unit  
 1441 The tests are carried out during the manufacturing.

1442 *Table 14 A.C. voltage tests (Laboraotry Equipment)*

Applies on component	Test voltage kV Protective class I	Point of application of test voltage
Meter test rack Without Source and Standard meter	2	Between, on the one hand, all the current and voltage circuits as well as the auxiliary circuits whose reference voltage is above 40 V, connected together, and, on the other hand, earth
	2	Between, on the one hand, any circuit whose reference voltage is above 40 V and, on the other hand, all other independent circuits whose reference voltage is above 40 V connected together.

- 1443 During these tests no flashover, disruptive discharge or puncture shall occur.  
 1444

1445 *Table 15 A.C. voltage tests (Onsite Equipment)*

Applies on component	Test voltage kV	Point of application of test voltage
For <b>Protective class I</b> Source Standard meter	2	Between, on the one hand, all the current and voltage circuits as well as the auxiliary circuits whose reference voltage is above 40 V, connected together, and, on the other hand, earth
For <b>Protective class II or higher</b> Source Standard meter	4	Between, on the one hand, all the current and voltage circuits as well as the auxiliary circuits whose reference voltage is above 40 V, connected together, and, on the other hand, earth

1446

1447 **10.2.5 Insulation Resistance test**

1448 *10.2.5.1 Test voltage shall be  $500 \pm 50$  V dc*

1449 *10.2.5.2 Performing the tests*

1450 The test voltages and the points of application are specified in Table 16 Table 14.

1451 Each component of the lab MTS shall be treated and tested as a MUT:

- 1452 • Voltage and current source
- 1453 • Standard meter
- 1454 • Meter test rack

1455

1456 *For Onsite testing equipment:*

1457 The tests are carried out during the manufacturing of a newly manufactured meter test unit.

1458 The test voltages and the points of application are specified in Table 16 (on standard meter  
1459 and source).

1460 If reference meter and source are separate units, each test equipment shall be treated and  
1461 tested individually as a single MUT:

- 1462 • Portable source;
- 1463 • Portable standard meter (if applicable)
- 1464 • Portable Meter Test Unit

1465 The tests are carried out during the manufacturing.

1466

*Table 16 Insulation resistance test*

Test voltage	Point of application of test voltage	Insulation resistance
500 ± 50 V dc	Between, on the one hand, all the current and voltage circuits as well as the auxiliary circuits whose reference voltage is above 40 V, connected together, and, on the other hand, earth.	5 MΩ
	Between circuits not intended to be connected together in service.	50 MΩ

1467 **11. Electromagnetic compatibility**

1468 **11.1 General requirements**

1469 The MTS shall be designed in such a way that conducted or radiated electromagnetic phenomena and  
1470 electrostatic discharge neither damage nor subsequently influence the function and the accuracy. The  
1471 MTS shall meet the requirements for light industrial EMC environments. However, RF transmitters such  
1472 as mobile telephones shall not be used in close proximity of the MTS.

1473 The phenomena and test levels shall be as specified in IEC 61326-1 Table 1, unless otherwise specified  
1474 in the following sub-clauses.

1475 Short duration electromagnetic phenomena are considered as disturbance and the performance  
1476 criteria specified in IEC 61326-1 Table 1 apply.

1477 Continuous and long duration electromagnetic phenomena are considered as influence quantities and  
1478 the accuracy requirements for the standard meter are specified in Table 17 for these tests, the test  
1479 points shall be as follows:

1480

- 1481 •  $I_n$  - nominal current of selected current range;

- 1482 • *Un* - nominal voltage of selected voltage range;

1483

1484 The test points shall be for Onsite testing/ Lab testing equipment:

- 1485 •  $I_n = 5 \text{ A}$ ;
- 1486 •  $U_n = 240/110 \text{ V}$  (user shall define as applicable);
- 1487 • Frequency = 50 Hz
- 1488 • Auxiliary circuits energized with reference voltage (where applicable);
- 1489 • Balanced voltage and current;
- 1490 • Power factor  $\cos \phi = 1$  and  $\sin \phi = 1$ .

1491 NOTE Standard meters may have several current ranges and voltage ranges, laboratory may select minimum and maximum  
1492 ranges.

1493

*Table 17 Limits of variation of error of standard meters during immunity test*

Phenomenon	Accuracy class of the standard meter used in the MTS				
	0.01	0.02	0.05	0.1	0.2
Electromagnetic RF fields	0.10	0.10	0.25	0.50	1.00
Conducted RF	0.10	0.10	0.25	0.50	1.00
Power frequency magnetic field test	0.10	0.10	0.25	0.50	1.00

1494 Note: Appropriate methodology to be used to protect the cable carrying frequency/pulse  
1495 output of EUT to Reference meter from getting influenced.

1496

1497 The definition of acceptance criteria is in line with the definition in IS13779/IS14697 and Table  
1498 17, the primary functions are the energy registration and the error calculation.

## 1499 11.2 General test conditions

1500 The EMC tests may not be possible to perform on the complete MTS. Therefore, each  
1501 component may be treated and tested separately as a EUT.

1502

1503 Unless otherwise specified, the MTS shall be tested as floor mounted. In case of separate  
1504 component wise testing, it may be tested as table-top equipment, in their normal working  
1505 position and operating condition. All parts intended to be earthed shall be earthed.

1506 Wherever the performance post EMC-EMI test is not possible to check individually, it shall be  
1507 integrated with MTS to check its performance.

1508

1509 Note: If it is not feasible to integrate with MTS, simulator can be used for checking  
1510 performance of individual component.

1511

### 1512 11.2.1 Test of immunity to electrostatic discharges

1513 The discharges shall be applied to the enclosure port, Switches, keypad of the voltage- and  
1514 current sources, the standard meter and the error calculator.

1515 The test level shall correspond to IS 14700-section 2 2018 Level 2.

1516 Functional performance shall not be permanently degraded.

### 1517 11.2.2 Test of immunity of electromagnetic RF Fields

1518

1519 This test applies to the enclosure port of the voltage- and current sources, the standard meter  
1520 and the error calculator. The cable length exposed to the field shall be 1m. The test level shall be

1521 1V/m (80 MHz to 1 GHz) for Lab testing equipment and 3V/m (80 MHz to 1 GHz) for onsite  
 1522 testing equipment. The test shall be carried out according to IS 14700 (Part 4/Sec 2).

1523 Test of standard meter

- 1524     • Test points as specified in 11.1;  
 1525     • Limits of variation of error during application of RF field as specified in Table 17

1526

1527 a) Test of voltage- and current sources:

- 1528     • Device in operating condition;  
 1529     • Test points as specified in 11.1;  
 1530     • Limits of variation equal to as specified in Table 3 and Table 4

1531

1532 b) Test of MSVT and ICTs:

- 1533     • Device in operating condition;  
 1534     • Test points as specified in 11.1;  
 1535     • Limits as specified in Table 32 and Table 34 . The accuracy test shall be performed Pre  
 1536     and Post application of RF field and the accuracy variation shall not be more than  
 1537     accuracy specified in Table 32 and Table 34.  
 1538

### 1539 11.2.3 Immunity to power frequency magnetic fields of external origins

1540 This test applies to onsite meter test system. The test level shall correspond to IEC 61326-1  
 1541 Table 2, industrial locations, but with 400 A/m, using immersion method.

1542

1543 a) Test of standard meter

- 1544     • test points as specified in 11.1;  
 1545     • Limits of variation of error as specified in Table 17

1546

1547 b) Test of voltage- and current sources:

- 1548     • Device in operating condition;  
 1549     • Test points as specified in 11.1;  
 1550     • Limits as specified in Table 3 and Table 4

1551

1552 c) Test of MSVT and ICTs:

- 1553     • Device in operating condition;  
 1554     • Test points as specified in 11.1;  
 1555     • Limits as specified in Table 32 and Table 34 . The accuracy test shall be performed Pre  
 1556     and Post application of Magnetic field and the accuracy variation shall not be more  
 1557     than accuracy specified in Table 32 and Table 34.  
 1558

### 1559 11.2.4 Test of immunity to fast transient bursts

1560 The test voltage shall be applied to the AC power ports of the voltage- and current sources  
 1561 and the standard meter:

- 1562 a) Between the terminals of each circuit normally connected to the mains;  
 1563 b) Between any two independent circuits having reference voltages over 40V;  
 1564 c) Between each independent circuit having reference voltage over 40 V and earth.

1565 Pre and Post accuracy test shall be perform. The test level shall correspond to IEC 61326-1  
 1566 Table 2, industrial locations.

1567 Duration of the test: 60 s at each polarity.



1568 Test shall be perform on supply –mains, for voltage circuit transits are not required in  
1569 stationary but required on Onsite test equipment.

### 1570 11.2.5 Test of immunity to surges

1571 The surges shall be applied line-to-line to the AC power ports of the voltage- and current  
1572 sources and the standard meter.

1573 The test level shall correspond to IEC 61326-1 Table 2, industrial locations.

1574 Test shall be perform on supply –mains, for voltage circuit. Surge test are only applicable on  
1575 Onsite test equipment.

### 1576 11.2.6 Test of immunity to conducted disturbances, induced by RF fields

1577 The surges shall be applied line-to-line to the AC power ports of the voltage- and current  
1578 sources and the standard meter.

1579 The test level shall correspond to IEC 61326-1 Table 2, industrial locations.

1580 a) Test of standard meter

- 1581 • test points as specified in 11.1;
- 1582 • Limits of variation of error as specified in Table 17

1583

1584 b) Test of voltage and current sources:

- 1585 • Device in operating condition;
- 1586 • Test points as specified in 11.1;
- 1587 • Limits as specified in Table 3 and Table 4

1588

1589 c) Test of MSVT and ICTs:

- 1590 • Device in operating condition;
- 1591 • Test points as specified in 11.1;
- 1592 • Limits as specified in Table 32 Technical requirements of MSVTs and Table 34 . The  
1593 accuracy test shall be performed Pre and Post application of RF field and the accuracy  
1594 variation shall not be more than accuracy specified in Table 32 and Table 34.

1595

### 1596 11.2.7 Radio interference suppression

1597 The test shall be carried out for the standard meter and the voltage and current sources of  
1598 the MTS according to CISPR 11.

1599 The standard meter shall be in normal operating condition:

- 1600 • device in operating condition;

1601 The voltage- and current source shall be in normal operating condition:

- 1602 • Auxiliary/ power circuits energized with reference voltage;
- 1603 • Loaded with 50% of the maximum output power, with resistive load.

1604 The test result shall comply with the requirements given in IEC 61326-1 for Class A Group 1  
1605 equipment.

1606 (Taken from IEC62057-1)

## 1607 12. Standard meter

### 1608 12.1 General

1609 The tests in sub-clause 12.3 and 12.4 are applicable for type testing.

1610

Table 18 Standard Accuracy Classes

Accuracy class of MTS	0.01	0.02	0.05	0.1	0.2
	<b>Standard Meter</b>				
Recommended accuracy class of MTS standard meter	0.01	0.02	0.05	0.1	0.2

1611 Note: Better accuracy class standard meter may be used in order to achieve required overall uncertainty of MTS as defined in  
1612 Table 26.

## 1613 12.2 Accuracy requirements under reference conditions

1614 When the standard meter is under the reference conditions given in Annex B, the percentage  
1615 errors shall not exceed the limits for the relevant accuracy class given in Table 19. If the  
1616 standard meter is designed for the measurement of energy in both directions, the values shall  
1617 apply for both directions.

1618 Note 1 The values given in Table 19 apply to standard meters with voltage range 30 – 300 V, current range 1 mA  
1619 – 120 A and frequency range 45 Hz to 65 Hz. Other ranges may be agreed between the manufacturer and the  
1620 purchaser.  
1621  
1622

Table 19 Percentage error limits for the laboratory standard meter

Quantity measured	Range	Percentage error limits for accuracy class (in percentage of the true value)				
		0.01	0.02	0.05	0.1	0.2
Voltage	30 V to 300 V	± 0.005	± 0.01	± 0.025	± 0.05	± 0.1
Current	$1 \text{ mA} \leq I < 10 \text{ mA}$	± 0.02	± 0.05	± 0.10	± 0.2	-
	$10 \text{ mA} \leq I < 50 \text{ mA}$	± 0.01	± 0.03	± 0.08	± 0.2	± 0.3
	$50 \text{ mA} \leq I < 120 \text{ A}$	± 0.005	± 0.01	± 0.025	± 0.05	± 0.1
		Percentage error limits for accuracy class (in percentage of the true value of apparent energy / power) <sup>1</sup>				
Active, reactive and apparent power / energy in the complete voltage range	$1 \text{ mA} \leq I < 10 \text{ mA}$	± 0.04	± 0.08	± 0.2	± 0.4	± 0.8
	$10 \text{ mA} \leq I < 50 \text{ mA}$	± 0.02	± 0.04	± 0.1	± 0.2	± 0.4
	$50 \text{ mA} \leq I < 120 \text{ A}$	± 0.01	± 0.02	± 0.05	± 0.1	± 0.2
		Limits of drift per year for accuracy class (in percentage of the true value) <sup>2</sup>				
Drift Voltage Measurement	30 V to 300 V	± 0.003	± 0.005	± 0.01	± 0.025	± 0.05
Drift Current measurement	50 mA to 120 A	± 0.003	± 0.005	± 0.01	± 0.025	± 0.05
Drift Active, reactive and apparent power / energy	30 V to 300 V 50 mA to 120 A	± 0.005	± 0.01	± 0.025	± 0.05	± 0.1

- 1) The percentage error limits for active and reactive power or energy is related to Unity power factor. The percentage error limits for power factors different arise from Unity Power Factor, the percentage error limits at Unity Power factor divided by the corresponding power factor according to the example below.
- 2) For uncertainty calculations it is feasible to take the drift of voltage, current and power measurement accuracy from the manufacturer's type specification.
- 3) Reference shall have lower current ranges as specified above.

Example:

Calculation of error limits for active and reactive power measurement at power factors  $\cos \phi=0.5$  or  $\sin \phi=0.866$  and percentage error limit for apparent energy measurement of + 0.05%.

The percentage error limit of active power measurement is equal to  $+ 0.05\% / 0.5 = + 0.1\%$ .

The percentage error limit of reactive power measurement is equal to  $+ 0.05\% / 0.866 = + 0.0577\%$

1623  
1624  
1625  
1626  
1627  
1628  
1629  
1630  
1631

The error limits shall remain the same in the case when a three phase standard meter measures single phase current but with balanced poly-phase voltage applied to the voltage circuits. The difference between the percentage error when the standard meter is carrying a single-phase load and a balanced poly-phase load at unity power factor shall not exceed 0.01%, 0.02%, 0.05%, 0.1% and 0.2% for standard meter of classes 0.01, 0.02, 0.05, 0.1 and 0.2 respectively.

*Table 20 Percentage error limits for the Onsite standard meter*

Quantity measured	Range	Percentage error limits for accuracy class (in percentage of the true value)				
		0.01	0.02	0.05	0.1	0.2
Voltage	30 V to 300 V	$\pm 0.005$	$\pm 0.01$	$\pm 0.025$	$\pm 0.05$	$\pm 0.10$
Current (direct measurement) <sup>2</sup>	$1 \text{ mA} \leq I < 10 \text{ mA}$	$\pm 0.02$	$\pm 0.05$	$\pm 0.20$	$\pm 0.10$	-
	$10 \text{ mA} \leq I < 50 \text{ mA}$	$\pm 0.01$	$\pm 0.04$	$\pm 0.10$	$\pm 0.20$	$\pm 0.30$
	$50 \text{ mA} \leq I < 120 \text{ A}$	$\pm 0.005$	$\pm 0.01$	$\pm 0.025$	$\pm 0.05$	$\pm 0.10$
Current measurement (Clamp on CT) <sup>2</sup>	$500 \text{ mA} \leq I < 120 \text{ A}/300 \text{ A}$	$\pm 0.15$				
	$50 \text{ mA} \leq I < 500 \text{ mA}$	$\pm 0.30$				
		Percentage error limits for accuracy class (in percentage of the true value of apparent energy / power) <sup>1)</sup>				
Active, reactive and apparent power / energy in the complete voltage range (direct measurement)	$1 \text{ mA} \leq I < 10 \text{ mA}$	$\pm 0.04$	$\pm 0.08$	$\pm 0.2$	$\pm 0.4$	-
	$10 \text{ mA} \leq I < 50 \text{ mA}$	$\pm 0.02$	$\pm 0.04$	$\pm 0.1$	$\pm 0.2$	$\pm 0.4$
	$50 \text{ mA} \leq I < 120 \text{ A}$	$\pm 0.01$	$\pm 0.02$	$\pm 0.05$	$\pm 0.1$	$\pm 0.2$
Active, reactive and apparent power / energy in the complete voltage range (Clamp on CT measurement)	$500 \text{ mA} \leq I < 120 \text{ A}/300 \text{ A}$	$\pm 0.2$				
	$50 \text{ mA} \leq I < 500 \text{ mA}$	$\pm 0.4$				
		Limits of drift per year for accuracy class (in percentage of the true value) <sup>2)</sup>				
Drift Voltage	40 V to 300 V	$\pm 0.003$	$\pm 0.005$	$\pm 0.01$	$\pm 0.025$	$\pm 0.05$

Drift Current-direct measurement	50 mA to 120 A	± 0.003	± 0.005	±0.01	± 0.025	± 0.05
Drift Current-clamp on CT measurement	500 mA ≤ I < 120 A/300A	±0.05				
Drift Active, reactive and apparent power / energy(direct measurement)	40 V to 300 V 50 mA to 120 A	±0.005	±0.01	± 0.025	± 0.05	± 0.1
Drift Active, reactive and apparent power / energy(Clamp on CT measurement)	40 V to 300 V 500 mA ≤ I < 120 A/300A	± 0.1				
	40 V to 300 V 50 mA ≤ I < 500mA	± 0.2				
1) The percentage error limits for active and reactive power or energy is related to power factor 1. The percentage error limits for power factors different 1 arise from the percentage error limits at 1 divided by the corresponding power factor according to the example below.						
2) The other ranges and their accuracies for clamp on/flexible CTs shall be decided by buyer and seller.						
2) For uncertainty calculations it is feasible to take the drift of voltage, current and power measurement accuracy from the manufacturer's type specification.						
Example: Calculation of error limits for active and reactive power measurement at power factors $\cos \phi=0.5$ or $\sin \phi=0.866$ and percentage error limit for apparent energy measurement of + 0.05%. The percentage error limit of active power measurement is equal to + 0.05% / 0.5 = + 0.1%. The percentage error limit of reactive power measurement is equal to + 0.05% / 0.866 = + 0.0577%						

1632

1633

### 12.3 Limits of error due to influence quantities

1634

The additional percentage error due to the change of influence quantities with respect to reference conditions, as given in Annex B shall not exceed the limits for the relevant accuracy class given in Table 21.

1635

1636

1637

1638

1639

1640

1641

Note 1 The values given in Table 21 apply to standard meters with voltage range 30 – 300 V and current range 1 mA – 120 A and frequency range 45 Hz to 65 Hz. Other ranges and their accuracies may be agreed between the manufacturer and the purchaser.

Table 21 Influence quantities for standard meter used in laboratory (controlled environment)

Influence quantity	Range <sup>1)</sup>	cos $\phi$ / sin $\phi$	Mean temperature coefficient in /K for accuracy class				
			0.01	0.02	0.05	0.1	0.2
Ambient temperature variation (+ 15°C to 35°C)							
Voltage measurement	30 V to 300 V	NA	1 PPM	5 PPM	10 PPM	20 PPM	50 PPM
Current measurement	50 mA to 120 A	NA	1 PPM	5 PPM	10 PPM	20 PPM	50 PPM

Active, reactive and apparent power / energy Measurement	30 V to 300 V 50 mA to 120 A	1	2 PPM	10 PPM	20 PPM	40 PPM	100 PPM
NOTE The effect of the following influence quantities applies to the measurement of active, reactive apparent Power / Energy only.		<b>Limits of variation in percentage error for standard meter of accuracy class</b>					
<b>Influence quantity</b>	<b>Range <sup>1)</sup></b>	<b><math>\cos \phi</math> / <math>\sin \phi</math></b>	<b>0.01</b>	<b>0.02</b>	<b>0.05</b>	<b>0.1</b>	<b>0.2</b>
Reversed phase sequence	30 V to 300 V 50 mA to 120 A	1	± 0.005	± 0.01	± 0.02	± 0.05	± 0.1
Harmonic components (5th harmonics) in voltage and current circuit 2)	U1 =30 V to 300 V I1= 50mA to 120A	1	± 0.02	± 0.04	± 0.1	± 0.2	± 0.4
3rd harmonics in current circuit	U1 = 30V to 300 V I1 = 50mA to 120A	1	± 0.02	± 0.04	± 0.1	± 0.2	± 0.4
Odd harmonics in the a.c. current circuit 3)	I1 = 50mA to 120A	1	± 0.02	± 0.04	± 0.1	± 0.2	± 0.4
Sub-harmonics in the a.c. current circuit	I1 = 50mA to 120A	1	± 0.02	± 0.04	± 0.1	± 0.2	± 0.4
Magnetic induction of external origin 0.5mT 4)	30 V to 300 V 50 mA to 120 A	1	± 0.02	± 0.04	± 0.1	± 0.2	± 0.4
<p>1) The manufacturer can choose the test point which represents the entire range/spectrum.</p> <p>2) The test condition shall be according to clause 12.4.2.</p> <p>3) The test condition shall be according to clause 12.4.3</p> <p>4) A magnetic induction of external origin of 0.5mT produced by a current of the same frequency as that of the voltage applied to the meter and under the most unfavorable conditions of phase and direction shall not cause a variation in the percentage error of the meter exceeding the values shown in this table. The magnetic induction shall be obtained by placing the standard meter in the center of a circular coil, 1m in mean diameter, of square section and of small radial thickness relative to the diameter, and having 400 AT.</p> <p>5) Reference meter shall be back to its original condition i.e. within its accuracy class when operated in reference condition after influence.</p>							
<p>Note :In addition the influence quantities and limits of variation of Table 17 are applicable There shall be no change in accuracy of Reference meter when change in its auxiliary supply for +/- 10% and Auxiliary supply frequency +/- 5%</p>							

1642  
1643  
1644  
1645  
1646  
1647

1648

Table 22 Influence quantities for standard meter used at Onsite (uncontrolled environment)

Influence quantities	Limits of variation in percentage error for standard meter of accuracy class during the test				
	0.01%	0.02%	0.05%	0.1%	0.2%
Supply voltage variation of $\pm 10\%$	$\leq \pm 0.005\%$	$\leq \pm 0.01\%$	$\leq \pm 0.025\%$	$\leq \pm 0.05\%$	$\leq \pm 0.1\%$
Frequency range 45 to 55 Hz	According to Table 8				
Magnetic induction of external origin 0.5mT	$\leq \pm 0.07\%$				
Drift of the voltage measurement per year	$\leq \pm 0.003\%$	$\leq \pm 0.005\%$	$\leq \pm 0.01\%$	$\leq \pm 0.025\%$	$\leq \pm 0.05\%$
Drift of the current measurement per year	$\leq \pm 0.003\%$	$\leq \pm 0.005\%$	$\leq \pm 0.01\%$	$\leq \pm 0.025\%$	$\leq \pm 0.05\%$
Additional error at 5th harmonics in voltage and current circuit	$\leq \pm 0.02\%$	$\leq \pm 0.04\%$	$\leq \pm 0.1\%$	$\leq \pm 0.2\%$	$\leq \pm 0.4\%$
Additional error at 10% 3rd harmonics in current circuit of 50mA to 120A	$\leq \pm 0.02\%$	$\leq \pm 0.04\%$	$\leq \pm 0.1\%$	$\leq \pm 0.2\%$	$\leq \pm 0.4\%$
Additional error at reverse phase sequence in the range 50 mA to I <sub>max</sub> (direct measurement ) 500mA to I <sub>max</sub> (clamp on measurement)	$\leq \pm 0.005\%$	$\leq \pm 0.01\%$	$\leq \pm 0.02\%$	$\leq \pm 0.05\%$	$\leq \pm 0.1\%$
Temperature coefficient (Direct measurement)/Clamp +0°C to +45°C	$\leq \pm 5$ PPM/K	$\leq \pm 10$ PPM/K	$\leq \pm 20$ PPM/K	$\leq \pm 50$ PPM/K	$\leq \pm 100$ PPM/K
<p>1) The manufacturer can choose the test point which represents the entire range/spectrum.</p> <p>2) The test condition shall be according to clause 12.4.2.</p> <p>3) The test condition shall be according to clause 12.4.3</p> <p>4) A magnetic induction of external origin of 0.5mT produced by a current of the same frequency as that of the voltage applied to the meter and under the most unfavorable conditions of phase and direction shall not cause a variation in the percentage error of the meter exceeding the values shown in this table. The magnetic induction shall be obtained by placing the standard meter in the center of a circular coil, 1m in mean diameter, of square section and of small radial thickness relative to the diameter, and having 400 AT.</p>					
Note :In addition the influence quantities and limits of variation of Table 17 are applicable					

1649  
1650  
1651

## 1652 12.4 Accuracy tests in the presence of harmonics

### 1653 12.4.1 Test with 3rd harmonic in the current

1654 Test conditions:

- 1655 • Fundamental frequency current:  $I_1 = 5 \text{ A}$ ;
- 1656 • Fundamental frequency voltage:  $U_1 = 240 \text{ V}$ ;
- 1657 • Fundamental frequency power factor:  $\cos \phi_1 = 1$  and  $\sin \phi_1 = 1$
- 1658 • Content of 3rd harmonic current:  $I_3 = 10 \%$  of  $I_1$ ;
- 1659 • Harmonic power factor:  $\cos \phi_3 = 1$  and  $\sin \phi_3 = 1$

1660 Fundamental and harmonic currents are in one case in-phase, at positive zero crossing and  
 1661 other case out-phase, at positive Zero crossing. The variation in percentage error in both of  
 1662 above cases, when the meter is subjected to the test condition shall not exceed the limits of  
 1663 variation given in Table 21.

### 1664 12.4.2 Test with 5th harmonic in the current and voltage

1665 Test conditions:

- 1666 • Fundamental frequency current:  $I_1 = 5 \text{ A}$ ;
- 1667 • Fundamental frequency voltage:  $U_1 = 240 \text{ V}$ ;
- 1668 • Fundamental frequency power factor:  $\cos \phi_1 = 1$  and  $\sin \phi_1 = 1$
- 1669 • Content of 5th harmonic voltage:  $U_5 = 10 \%$  of  $U_1$ ;
- 1670 • Content of 5th harmonic current:  $I_5 = 40 \%$  of  $I_1$ ;
- 1671 • Harmonic power factor:  $\cos \phi_5 = 1$  and  $\sin \phi_5 = 1$

1672 Fundamental and harmonic voltages are in phase, at positive zero crossing. The variation in  
 1673 percentage error when the meter is subjected to the test condition shall not exceed the limits  
 1674 of variation given in Table 21.

### 1675 12.4.3 Tests of the influence of odd and sub-harmonics (Annex C)

1676 The tests of the influence of odd and sub-harmonics shall be made with the circuit shown in  
 1677 Figure C. 1 or with other equipment able to generate the required wave-forms, and the  
 1678 current waveforms as shown in Figure C. 2 and Figure C. 4 respectively. The variation in  
 1679 percentage error when the meter is subjected to the test wave-form given in Figure C. 2 and  
 1680 Figure C. 4 respectively and when it is subjected to the reference waveform shall not exceed  
 1681 the limits of variation given in Table 21.

1682  
 1683 Note 1 : the values given in the figures are for 50 Hz only. For other frequencies the values have to be adapted  
 1684 accordingly.

## 1685 13. Software requirements

### 1686 13.1 Application

1687 These requirements apply to the software supplied with the MTS.

1688 The manufacturer and the purchaser may agree on different requirements for the software if  
 1689 needed.

1690 Software:

- 1691 1. Embedded software
- 1692 2. Software required for testing of meter
- 1693 3. Software required for automation of testing
- 1694 4. Software require for data retrieval and report generation.

1695

## 1696 13.2 Identification

1697 The software shall be clearly identifiable by the program name, version number and target  
1698 operating system (if applicable).

## 1699 13.3 Protection

1700 The software and the test programs written by the operator(s) shall be protected against  
1701 unauthorized modification and / or use i.e. integrity of software shall be protected. The  
1702 administrator of the software may assign specific rights to each operator. Each entry of a  
1703 program module shall only be possible with an identification of the operator at least by a  
1704 password before use. Measurement data shall be protected against unauthorized access.

## 1705 13.4 Functional requirements

1706 The software shall support following minimum functionalities

- 1707
- 1708 • Programming facilities for setting parameters,
  - 1709 • Acquiring the data,
  - 1710 • Monitor and control the source and measuring system,
  - 1711 • Computation of error,
  - 1712 • Display of error and measurement,
  - 1713 • Evaluation and presentation of test results.
  - 1714 • Provision for limiting the generation of current and voltage for protection of unit  
1715 under test.
  - 1716 • Display of software version.

1717

1718 Any other requirement shall be as agreed between the manufacturer and the purchaser  
1719 Annex J may be referred for details.

1720

1721 Note 1: the requirements are met should be verifiable by the local certification bodies and depend on the code  
1722 of practice.

## 1723 13.5 Protection of integrity and storage of test results and test protocols (reports)

1724 Measured values, test results and related parameters shall be printed or stored as needed in  
1725 suitable formats. It shall be always possible to correlate the test results to the test program  
1726 generating those results and its parameters such as test sequence, test points, operator  
1727 inputs, meter constants, error limits, fail/pass criteria etc. The test protocols shall be stored  
1728 for each batch tested. They shall be easily identifiable, they shall be protected against any  
1729 changes and it shall be not possible to erase them without prior approval by the responsible  
1730 authority.

1731

## 1732 13.6 Documentation of the software

1733 The software of the MTS shall be properly documented and accompanied with operating  
1734 instructions delivered on a suitable storage media (paper or digital data storage devices). It  
1735 shall be written in clear and unequivocal terms and in consistent form.

1736

1737 The software documentation shall at least include:

- 1738 • the program name;
- 1739 • the software version, release and operating system
- 1740 • the author of the program;
- 1741 • contact details of the organization / person providing support;
- 1742 • explanation of all functions and operator commands;



- 1743 • description of test sequences;
- 1744 • description of parameter tables;
- 1745 • description of all calculation formulae used for calculating the results;
- 1746 • list of error messages, diagnostic information and hints for troubleshooting;
- 1747 • Description of all display screens, printout and storage formats.
- 1748 • Software validation certificate with version no. (from Manufacturer)

## 1749 14. Accuracy requirements and tests

### 1750 14.1 General

1751 This clause specifies the overall accuracy requirements for the MTS, describes the various  
1752 tests to be performed, the test points, test methods and the evaluation of the results.

1753 Note 1: Error definitions and error determination are given in Annex D.

### 1754 14.2 Test methods for determination of MTS accuracy

1755 The determination of the overall error of an MTS shall be made according to either of the  
1756 following methods

1757

1758 Method 1 Comparison is done by comparing the energy delivered and indicated by the MTS  
1759 standard meter with the energy indicated by the precision standard meter.

1760

1761 Method 2 The energy comparison can be done by comparing the number of pulses from a  
1762 test output of the MTS standard against the number of pulses from the test output of the  
1763 precision standard meter using suitable error calculator according to the method clause 5.4

1764

1765 To measure the overall error of the MTS, the following conditions shall be fulfilled.

1766

1767 a) The MTS shall operate under reference conditions performing accuracy test on a MUT.  
1768 The standard meter shall be connected at the preferred output terminals of the meter  
1769 test rack as the MUT. The determined errors are errors of the MTS at that particular  
1770 position;

1771

1772 b) The MTS and the standard meter shall reach thermal stability;

1773

1774 c) The recommended accuracy class of the standard meter used for testing of overall  
1775 accuracy of the MTS is given in Table 23. If the calibration error of the standard meter  
1776 is known a required error correction can be applied;

1777

1778 d) The tests are performed under reference conditions given in Table B. 1;

1779

1780 e) The MTS should have suitable hardware and software provisions to determine the  
1781 overall error of the MTS. Error results should be stored for corrections of the error of  
1782 the standard meter.

1783

1784

1785

1786

1787

1788

1789

Table 23 Recommended accuracy class of standard meter to Test MTS

Accuracy Class of under test MTS	Accuracy class of the standard meter used in the MTS				
	0.01	0.02	0.05	0.1	0.2
Recommended accuracy class of standard meters	0.005	0.01	0.01	0.02	0.05
NOTE					
<p>1 In order to obtain best possible uncertainty of measurement it is highly recommended that correction of errors of standard meter is used in all cases. However it is mandatory to use correction of errors of standard meter in cases of class 0.02 and class 0.01 MTS. (Example: Obtained error of 0.02 class reference meter on particular load point is -0.015%, whereas During calibration error of reference standard on particular load point (from calibration certificate) is -0.005%, hence after correction the error shall be reported as follows: -0.015%-0.005% =+0.020%</p> <p>2 The above accuracy class of standard meter are only recommended. Actual accuracy class may be decided in order to achieve required overall uncertainty of measurement for respective MUT class as defined in Table 26.</p>					

1790

1791

### 14.3 Test points for MTS

1792

#### 14.3.1 Selection of voltage and current ranges

1793

1794

1795

1796

1797

1798

From all value combinations related to voltage, current, power factor and measuring mode the most significant ones for practice should be tested. The values given in Table 24 are recommended test points and can be separately agreed upon by the supplier and the purchaser.

Table 24 Basic measurement table (recommended test points for lab equipment)

Measurement mode	Voltage	Current	cos $\phi$ / sin $\phi$	Load of the MTS			
				Phase 1	Phase 2	Phase 3	All Phases
All available measurement mode	Vmin	I <sub>max</sub> 0.8I <sub>max</sub> 0.5 I <sub>max</sub> 0.2 I <sub>max</sub> 0.1 I <sub>max</sub> 0.05 I <sub>max</sub> I min	1 0.5 Lag 0.5 lead	x	x	x	X (note 6)
	Vmax	I <sub>max</sub> 0.8 I <sub>max</sub> 0.5 I <sub>max</sub> 0.2 I <sub>max</sub> 0.1 I <sub>max</sub> 0.05 I <sub>max</sub>	1 0.5 Lag 0.5 lead	x	x	x	X (note 6)

		I min					
3 phase 4 wire active	240V	120 or I <sub>max</sub>	1 0.5 inductive 0.5 capacitive	X	X	X	X
		50		X	X	X	X
		20		X	X	X	X
		10		X	X	X	X
		5		X	X	X	X
		2		X	X	X	X
		1		X	X	X	X
		0.5		X	X	X	X
		0.1		X	X	X	X
		0.05		X	X	X	X
		0.01		X	X	X	X
3 phase 4 wire reactive	240V	5	1 0.5 inductive 0.5 capacitive	X X X	X X X	X X X	X X X
3 phase 3 wire active	110Vp-p	1	1	x	x	x	X
3 phase 3 wire reactive	110Vp-p	1	1	x	x	x	X
<p>NOTE 1 Tests can be carried out at frequency 50 Hz. if it is ensured that influence due to frequency is not significant. These are the minimum requirement, other load points can be decided as per purchaser and manufacturer according to test bench design/specification of MTS.</p> <p>NOTE 2 For single phase MTS only the test points of one phase are valid.</p> <p>NOTE 3 For I<sub>max</sub> &gt; 120A an additional test point at I<sub>max</sub> has to be added.</p> <p>Note 4  V<sub>min</sub> &lt;= 0.3 V<sub>ref</sub> of meter under test.  V<sub>max</sub> &gt;= 1.2 V<sub>ref</sub> of meter under test  I<sub>min</sub> &lt;= 0.01 I<sub>b</sub>/I<sub>n</sub> of meter under test  I<sub>max</sub> &gt;= 1.2 I<sub>max</sub> of meter under test</p> <p>Note 5 the periodicity of performing control measurement shall be one year, user is free to split the table on quarterly or half yearly basis as per convenience and cover all the points once in a year.</p> <p>Note 6: these measurement shall be perform for control measurement.</p> <p>Laboratory/purchaser may decide additional load points applicable for the test bench depending on use.</p>							

1799  
1800  
1801

*Table 25 Recommended test points for Onsite equipment for functional check before taking to Onsite and and bring back from Onsite*

Measurement mode	Voltage	Current	cos $\phi$ / sin $\phi$	Load of the MTS			
				Phase 1	Phase2	Phase 3	All Phases
		A					
3 phase 4 wire active	30 V or V <sub>min</sub>	0.05 or I <sub>min</sub>	1	X	X	X	X
	300 V or V <sub>max</sub>	120 or I <sub>max</sub>	1	X	X	X	X

1802

1803 **14.4 Accuracy requirements**1804 **14.4.1 Limits of maximum permissible error**

1805 The overall error of MTS ( $\delta W_{\text{MTS}}$  - as per Table 33 and Table 35) and maximum permissible  
 1806 error of MTS at given at different current range is denoted as  $\delta W_{\text{max}}$  in Table 27.

1807  
 1808 Overall uncertainty of measurement shall be better than as specified in Table 26

1809  
 1810 It is recommended that Transformer operated meters shall not be tested using ICTs or MSVTs.

1811  
 1812

*Table 26 Overall uncertainty of Meter Test System*

	<b>MUT (Electricity meter)</b>				
MUT accuracy class	0.1	0.2 / 0.2S	0.5 / 0.5S	1	2
Overall uncertainty of MTS (for testing at Laboratory condition)	Better than 1/5 of limit of error defined in product standard for particular load point.				
Overall uncertainty of MTS (for testing at site)	IS15707 clause no. 12.3.2				

1813

1814 Note: 1. for site testing of meters particularly Low tension meters, the general practice is to use the MTS with clamp on CTs.  
 1815 Hence for such testing of all types of meters, one class better accuracy MTS than the meter under test may be used. Such MTS  
 1816 can be tested as per the relevant standard of accuracy. For eg. For 0.5 class of meter installation Clamp on CT of class 0.2 can be  
 1817 used.

1818 2. The expanded uncertainty calculation shall be perform as per NABL guideline NABL-141. The examples of uncertainty budgets  
 1819 are given under informative Annex K

1820 Example is illustrated for calculation of uncertainty of MTS as per Annex K)

1821

1822 *Table 27 Limits of maximum permissible error ( $\delta W_{\text{max}}$ ) of the complete MTS in laboratory  
 1823 condition (without MSVT and ICT)*

	<b>Standard Meter</b>									
Accuracy class of MTS standard meter	0.01		0.02		0.05		0.1		0.2	
	<b>Maximum permissible error of MTS</b>									
Power factor	1	0.5 Ind/ 0.5 cap	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap
$\delta W_{\text{max}}$ in % (1 mA $\leq$ I < 10 mA)	$\pm 0.04$	$\pm 0.08$	$\pm 0.08$	$\pm 0.16$	$\pm 0.20$	$\pm 0.40$	$\pm 0.40$	$\pm 0.80$	$\pm 0.80$	$\pm 1.6$
$\delta W_{\text{max}}$ in % (10 mA $\leq$ I < 50 mA)	$\pm 0.02$	$\pm 0.04$	$\pm 0.04$	$\pm 0.08$	$\pm 0.10$	$\pm 0.20$	$\pm 0.20$	$\pm 0.40$	$\pm 0.40$	$\pm 0.80$
$\delta W_{\text{max}}$ in % (50 mA $\leq$ I < 120 A)	$\pm 0.01$	$\pm 0.02$	$\pm 0.02$	$\pm 0.04$	$\pm 0.05$	$\pm 0.10$	$\pm 0.1$	$\pm 0.2$	$\pm 0.02$	$\pm 0.40$

1) Accuracy class of MUT according to the Metering Standards. IS13779/IS14697/IS13010 and reference meter accuracy class according to this standard. For MUT accuracy class better than 0.02, the limits shall be considered half of the limits mentioned for 0.02 class.

NOTE 1 The standard voltage range for  $\delta W_{\max}$  shall be 30 V to 300 V.

NOTE 2 For active energy measurements  $\delta W_{\max}$  is determined for  $\cos \phi = 1$  and 0.5. For Reactive Energy measurements  $\delta W_{\max}$  is determined for  $\sin \phi = 1$  and 0.5

1824  
1825

#### 1826 14.4.2 Correction of the error $\delta W$ of the meter test system

1827 If any measurement exceeds the maximum permissible limits, two additional measurements  
1828 at this particular test point shall be taken. The results of the additional measurements should  
1829 be within the permissible limits of  $\delta W_{\max}$ .

1830  
1831 The MTS can be used for meters of the relevant class according to Table 27. If the results of  
1832 any test points are not within the limits, the use of this MTS shall be restricted excluding such  
1833 range (s) . Such restriction shall be indicated at the MTS and in the test report.

1834  
1835 If the error  $\delta W_{\max}$  of the MTS in service is out of the limits of the maximum permissible error  
1836 but less than twice the relevant values of Table 27 a correction for the error of the MTS shall  
1837 be applied to the results of the tests on the MUT. In these cases, an effort should be made to  
1838 reduce the error of the MTS in order to bring it within the permissible limits. How this is done  
1839 must be documented.

#### 1840 14.4.3 Mean value and repeatability of the measurements

1841 Maximum acceptable repeatability of measurement ( ) are specified in Table 28 as standard  
1842 deviation of errors.

1843  
1844 The number of measurements shall support a reasonable statistical basis. As a proof the  
1845 estimation  $s$  of the standard deviation shall be in accordance to Table 28

1846  
1847 A sequence of repeated measurements at test points and power factors given in Table 28 is  
1848 recommended. Not less than 10 measurements for each test point shall be made to calculate  
1849 the estimation  $s$  of the standard deviation.  
1850

$$s = \sqrt{\frac{1}{n-1} \sum_{i=1}^n (\delta W_i - \overline{\delta W})^2} \quad \text{Equation 16}$$

1851 where:  
1852  $s$  is the estimation for standard deviation;  
1853  $\delta W_i$  is the measurement results of the MTS determined by one individual measurement of a  
1854 sequence of repeated measurements at a certain test point;  
1855  $\overline{\delta W}$  is the mean value of measurement results  $\delta W_i$ ;  
1856  $n$  is the total number of individual measurements.

1857  
1858 The value  $s$  of a newly manufactured MTS shall be within the limits of  $S_{\max}$  given Table 28.

1859 These measurements shall be repeated in case of any overloading, mishandling, gives questionable  
1860 results or has been shown to be defective or outside specified requirements.

1861

Table 28 Limits of permissible values of standard deviation of MTS

Accuracy class of MTS standard meter	Standard Meter									
	0.01		0.02		0.05		0.1		0.2	
	<b>Maximum permissible standard deviation of MTS reference meter</b>									
Power factor	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap	1	0.5 ind/ 0.5 cap
Smax	0.0015	0.0025	0.002	0.004	0.005	0.01	0.01	0.02	0.02	0.04
1) Accuracy class of MUT according to the Metering Standards. IS13779/IS14697/IS13010 and reference meter accuracy class require according to this standard. For MUT accuracy class better then 0.02, the limits shall be considered half of the limits mentioned above for 0.02 class.										

1862

1863 

## 14.5 Evaluation of test results

1864 

### 14.5.1 Basic measurements

1865 The basic measurements according to Table 24 shall be performed on newly manufactured  
 1866 MTS before putting into service. Repeated measurements also shall be made in case of any  
 1867 overloading, mishandling, gives questionable results or has been shown to be defective or  
 1868 outside specified requirements.

1869

1870 

### 14.5.2 Recalibration of meter test system

1871 The time interval of recalibration shall be adapted to the use of the equipment and has to be  
 1872 determined by the detected drift of the measurement results. e.g. the measurements  
 1873 according to **Error! Reference source not found.**

1874

1875 Note 1: National regulations have to be considered.

1876

1877 

## 14.6 Test for output values and ranges of test circuits

1878 Requirements as specified in clause 6.2 shall be complied.

1879

1880 

## 15. Tests and testing procedures

1881 

### 15.1.1 Type tests

1882 In case it is difficult to conduct any type test on complete MTS it may be conducted on  
 1883 individual major components.

1884 These major components shall include:

- 1885 • Source and its parts such as voltage, current amplifier, controller and generators
- 1886 • Standard meter;
- 1887 • MSVT and ICTs;
- 1888 • Error calculation system;
- 1889 • scanning head.

1890 The requirements are given in clause 10.2.3.2, 10.2.410, 10.2.5, 11, 12.3, 13, 14 and 16.

## 1891 15.1.2 Routine tests

1892 15.1.2.1 *General*

1893 A routine test is made on each individual component of the MTS during or after manufacturing  
 1894 to check if it complies with the requirements of the standard concerned or the criteria  
 1895 specified.

1896 The following routine tests shall be performed on each meter test unit or on the integrated  
 1897 components respectively (such as source, standard meter, generator, etc.)

1898 15.1.2.2 *Visual inspection*

1899 Visual inspection shall be performed on the MTS to ensure the:

- 1900 • Mechanical aspect as per its design;
- 1901 • Wiring and connection as per its design;
- 1902 • Terminals and marking as defined in this standard.

1903 15.1.2.3 *AC voltage test and IR test*

1904 The A.C. voltage tests and IR test shall be performed on each MTS as defined in clause  
 1905 10.2.4.

1906 15.1.2.4 *Operation and Inspection of safety devices*

1907 The operation of devices for indication of hazards or protective switches - such as visible  
 1908 warnings and alarms, emergency switches - shall be inspected. The operation of alarms shall  
 1909 be tested by invoking various failures like:

- 1910 • Short circuits;
- 1911 • Overloads;
- 1912 • Input power overvoltage and under voltage
- 1913 • Other test as agreed between supplier and customer

1914 15.1.2.5 *Accuracy of standard meter*

1915 The standard meter used in the MTS shall be calibrated against a traceable standard of higher  
 1916 accuracy. The error of the standard meter shall be within the limits specified in clause 12.2.  
 1917

1918 15.1.2.6 *Electrical and Functional test*

1919 The following tests shall be performed on each MTS:

- 1920 • Functionality of emergency switch, mains power switch, other control circuit, of each  
 1921 hardware and software control elements;
- 1922 • Testing of the protection system and fault indication by short and open circuits;
- 1923 • Matching of respecting phases i.e. L1, L2 and L3 as per labelling.
- 1924 • Symmetry of the output voltage and current at full load and no load, at preferred MUT  
 1925 locations as per clause 6.2.3.
- 1926 • Waveform distortion measurement: Measurements shall be made in each current and  
 1927 voltage circuit at no load and full load; refer to Table 3 and Table 4
- 1928 • Generation of test signals: It shall be verified that the test signals necessary for testing  
 1929 the MUTs with harmonics can be generated as specified by the manufacturer and  
 1930 according to Table 7.

1931  
 1932 Note 1 No load for the MTS means that the voltage terminals are open and the current terminals are short  
 1933 circuited and the MTS is switched on for its minimum and/or maximum test value.

1934 Note 2 Full Load for the MTS means that both the voltage and the current circuits are loaded with the highest  
 1935 load specified for the voltage- and current sources.  
 1936

- 1937 **15.1.2.7** *Basic measurement of complete meter test system*
- 1938 Basic measurements as defined in **Error! Reference source not found.** shall be carried out on
- 1939 newly manufactured MTS. The maximum permissible error should not exceed the percentage
- 1940 error limits defined in Table 27 for the given class accuracy of MUT and for which MTS is going
- 1941 to be used.
- 1942 The test points for newly manufactured MTS can be reduced to exemplary tests. The standard
- 1943 meter shall be supplied with a calibration certificate which covers all points.
- 1944
- 1945 **15.1.2.8** *Software function test*
- 1946 All general tests to ensure the proper functioning of software as described in clause no. 13.4
- 1947 shall be carried out once for the given version number.
- 1948 Specific tests requested by the purchaser shall be carried out according to specification of the
- 1949 purchaser.
- 1950 **15.1.2.9** *Test for smart meters/communicable meter*
- 1951 The software shall be capable to conduct all smart meters/ communication tests as specified
- 1952 in clause no. 5.6
- 1953 **15.1.3** *Acceptance test*
- 1954 Acceptance tests are contractual tests proving that the MTS meets the specification. This shall
- 1955 be mutually agreed between the customer and the manufacturer.
- 1956 **15.1.4** *Commissioning test*
- 1957 Commissioning tests are contractual tests proving that the MTS meets the specification. This
- 1958 shall be mutually agreed between the customer and the manufacturer.
- 1959 **16. Test of climatic condition**
- 1960 These test are applicable for MTS to be used for onsite.
- 1961 **16.1 Dry heat test**
- 1962 The test shall be carried out according to relevant section of IS 9000 (Part 3/Sec 3). Under the
- 1963 following conditions:
- 1964 a) Meter test system in non-operating condition with carrying case
- 1965 b) Temperature:  $+ 70 \pm 2$  °C
- 1966 c) Duration of the test: 72 h
- 1967
- 1968 After the test meter test system shall show no damage and function as per this standard.
- 1969 Accuracy test shall be carried out on test points for control measurement as per Table 24
- 1970 **16.2 Cold test**
- 1971 The test shall be carried out according to relevant section of IS 9000 (Part 2/Sec 3) under the
- 1972 following conditions:
- 1973 a) Meter test system in non-operating condition with carrying case
- 1974 b) Temperature:  $- 25 \pm 3$  °C
- 1975 c) Duration of the test: 72 h
- 1976
- 1977 After the test meter test system shall show no damage and function as per this standard.
- 1978 Accuracy test shall be carried out on test points for control measurement as per Table 24



1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
  
1998  
  
1999  
  
2000  
  
2001  
  
2002  
  
2003  
  
2004  
  
2005  
  
2006

### 16.3 Damp heat cyclic test

The test shall be carried out according to relevant section of IS 9000 (Part 5/Sec 2) under the following condition:

- a) Meter test system in operating condition without carrying case.
- b) Voltage and auxiliary circuits energised with reference voltage
- c) Without any current in the current circuits
- d) Upper temperature  $+45\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$
- e) No special precautions shall be taken regarding the removal of surface moisture
- f) Duration of test: 3 cycles  
24 h after the end of this test the meter test system shall be submitted to the following tests:
- g) An insulation resistance test according to clause 10.2.5
- h) A functional check.













The damp heat test also serves as a corrosion test. The result is judged visually. No trace of corrosion likely to affect the functional properties of the meter test system shall be apparent.

After the test meter test system shall show no damage and function as per this standard. Accuracy test shall be carried out on test points for control measurement as per Table 24

2007  
2008  
2009  
2010  
2011

## Annex A (Informative) Symbols according to IEC 60417:2002 DB

*Table 29 Symbols, may be used on metering equipment*

Number	Symbol	Reference	Description
1		IEC 60417-5031	Direct current
2		IEC 60417-5032	Alternating current
3		IEC 60417-5033	Both direct and alternating current
4a		IEC 60417-5032-1	Three-phase alternating current
4b		IEC 60417-5032-2	Three-phase alternating current with neutral conductor
5a		IEC 60417-5017	Earth; ground
5b		IEC 60417-5018	Functional earthing; functional grounding (US) <sup>b</sup>
6		IEC 60417-5019	Protective earth; protective ground
7		IEC 60417-5020	Frame or chassis
8			Not used
9			Not used
10			Not used
11		IEC 60417-5172	Protective class II equipment
12		IEC 60417-5036	Dangerous voltage
13			Not used
14		ISO 7000-0434B	Caution <sup>a</sup>

<sup>a</sup> The use of symbol number 14 requires manufacturers to state that documentation must be consulted in all cases where this symbol is marked.

<sup>b</sup> There may be national differences concerning the use of this symbol

2012  
2013  
2014  
2015  
2016

**Annex B**  
**(Normative)**  
**Reference conditions**

*Table 30 Reference conditions*

<b>Influence Quantity</b>	<b>Reference</b>	<b>Permissible tolerance</b>
Ambient temperature	Reference temperature or in its absence, 27°C	± 2°C
Voltage unbalance	All phase connected	-
Input mains Voltage	240V	± 10%
Input mains frequency	50Hz	± 2%
Waveform	Mains Voltage U	in accordance to IS17036
Continuous magnetic induction of external origin	Equal to Zero	-
Magnetic induction of external origin at the reference frequency	Magnetic induction equal to zero	< 0.05 mT
Electromagnetic RF fields, 30kHz to 2 GHz	Equal to Zero	< 1V/ m
Conducted disturbances, induced by radio frequency fields, 2 kHz to 80 MHz	Equal to Zero	< 1V
NOTE: If the tests are made at ambient temperatures other than the reference temperature, including permissible tolerances, the results shall be corrected by applying the appropriate temperature coefficient of the reference meter.		

2017

## Annex C (Informative)

### Test circuits and test signals for testing in the presence of harmonics


2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025  
2026  
2027  
2028

The test setup is for informative use and belongs to the connection of MUTs and standard meters generally. The verification of the working standard/electricity meter (MUT) has to be done with the standard meter.

Note 1: The values given in Figure 4 and Figure 6 are for 50 Hz only. For different frequencies the values shall be adapted accordingly.

#### 2029 C.1 Phase fired control (odd harmonics)

2030 The test layout of the harmonics test circuit is shown in Figure 2



2031  
2032


*Figure 2- Test circuit diagram (informative)*

2033  
2034  
2035  
2036  
2037  
2038  
2039  
2040  
2041  
2042  
2043  
2044  
2045  
2046  
2047

NOTE

1. In the presence of harmonics the standard meter shall measure the total active energy (fundamental and harmonics). For reactive energy the standard meter shall measure the fundamental only.
2. DUT is standard meter under test.

2048 The wave form of the phase-fired test values is shown in Figure 3




2049

2050

Figure 3 – Phase fired waveform

2051 The harmonic content of the phase-fired test values is shown in Figure 4

2052



2053


2054

Figure 4– Informative distribution of harmonic content of phase fired waveform

2055 **C.2 Burst control (sub-harmonics)**

2056 Test circuit diagram, see Figure 2

2057 The wave form of the burst-fired test values is shown in Figure 5




2058  
2059

Figure 5– Burst fired waveform

2060 The harmonic content of the burst-fired test values is shown in Figure 6

2061



2062  
2063

Figure 6 – Informative distribution of harmonics

2064

## Annex D (Informative)

### Guidelines for overall laboratory setup

2065  
2066  
2067  
2068  
2069  
2070  
2071  
2072  
2073  
2074  
2075  
2076  
2077  
2078  
2079  
2080  
2081  
2082  
2083  
2084  
2085  
2086  
2087  
2088  
2089  
2090  
2091  
2092  
2093  
2094  
2095  
2096  
2097  
2098  
2099  
2100

#### D.1 Introduction

If legally relevant measurement results are stored on electronic data storage devices, the data shall be readable for at least 10 years. Explanations, how, has to be given to the notified body

For every meter test equipment, a software log must be kept. Every first application of a new test software must be documented with date, program name and version number in the logbook. Old versions of the software have to be kept also. Changes in the software must be documented: which change at what time has been done, how the change influences the measuring results and the name of the author of change. The changes must be released by the person responsible. The MTS may be only used again for calibration or tests or batch tests after a new acceptance by the person responsible. The logging of new release can be done electronically if a complete and understandable recording is guaranteed.

The storage duration of software releases and documents are the task of accreditation of the lab.

All laboratories for the testing of electrical energy meters should have appropriate facilities for carrying out the required tests in accordance with the relevant standards and the corresponding requirements for test laboratories such as specified in e.g. ISO/IEC 17025.

#### D.2 General Conditions

The rooms for the laboratory should be:

- Sufficiently large, clean dry, dust free;
- Free from vibration. The calibration area should be adequately free from vibrations generated by central air conditioning plants, vehicular traffic and other sources to ensure consistent and uniform operating conditions. Continuous vibration in the lab may lead to malfunctioning of the sensors. Acoustic noise level in the laboratory should be maintained to facilitate proper performance of calibration work. A threshold noise level of 60 dBA is recommended;
- Sufficiently illuminated. The calibration & testing area should have adequate level of illumination. The recommended level of illumination is 450-700 lux on the working table;
- Protected against solar radiation.

#### D.3 Quality of mains supply

The test laboratory should have necessary arrangements to maintain power supply conditions as specified in Table 31.

*Table 31 Mains supply quality*

Quantity	Value
Voltage supply	1 phase 2 wire, 240 or 3 phase 4 wire, 3 x 240/415V, with a relative tolerance of $\pm 5\%$
Frequency	50 Hz +/- 1%
Voltage distortion	< 2%
Earth resistance	< 2 Ohm
Protection	Protection against, lightning, spikes, voltage surges. Individual equipment shall be protected against short circuit, earth fault and over current.

#### 2101 D.4 Standard meter

2102 The laboratory shall be equipped with an appropriate standard meter for determining the overall  
2103 accuracy of the MTS, for control measurement and other purposes.

## Annex E (Normative)

### Multi-secondary voltage transformer (Reference taken from IEC62057-1)

2104  
2105  
2106  
2107

#### 2108 **E.1 Introduction**

2109 Multi Secondary Voltage Transformers (MSVT) are necessary for testing single-phase meters the current  
2110 and voltage circuits of which are permanently connected together (meters with no jumper to open the  
2111 link between voltage and current circuits).  
2112

#### 2113 **E.2 Definitions**

##### 2114 **E.2.1 Meter With Permanently Closed Link**

2115 Meter, in which the link between the voltage circuit and current circuit cannot be opened for testing  
2116

2117 Note 1: In some cases the link may exist but it is either inaccessible or cannot be opened in order to prevent tampering. In some  
2118 electronic meter designs, the voltage and current circuits cannot be separated due to technical limitations imposed by the  
2119 integrated circuits used.  
2120

##### 2121 **E.2.2 Multi Secondary Voltage Transformer, MSVT**

2122 Isolating transformer, used to provide isolation between the primary and secondary windings while  
2123 maintaining the same voltage.

2124 Note 1: An MSVT has one primary winding and N or N+1 secondary windings. N is the number of meter test positions at the  
2125 MTS.  
2126

#### 2127 **E.3 Application**

2128 Meters are usually tested with the link between the voltage and current circuits opened, with the voltage  
2129 circuits of the MUTs connected in parallel and with the current circuits connected in series. This method  
2130 allows testing multiple meters at the same time.


2131 If the link between the voltage and current circuits cannot be opened, and the meters were connected  
2132 the same way, a voltage drop would occur on the current circuit of each meter and therefore the voltage  
2133 would be different on each test position.

2134 Hence, an MSVT is required to test meters with permanently closed link. The principle of the test is  
2135 illustrated in Figure 7 and Figure 8.

2136 The difference of both test layouts is in the connection method of the voltage circuit of the standard  
2137 meter. Also, the uncertainty calculation for the whole measuring circuit will be different. Both layouts are  
2138 suitable.

2139 Note 1: The MVST is an optional component of each MTS. The purchaser should specifically request that the MTS be equipped  
2140 or not with an MSVT depending on the kind of meters to be tested.  
2141






2142  
2143  
2144

Figure 7– Testing of single phase meters with closed link between the voltage and current circuits (variant 1)

2145  
2146



2147  
2148  
2149

Figure 8– Testing of single phase meters with closed link between the voltage and current circuits (variant 2)

2150 **E.4 Technical requirements**2151 **E.4.1 Number of windings and ratio**

2152 The MSVT shall meet the requirements specified in Table 32

2153

2154

*Table 32 Technical requirements of MSVTs*

Parameter	Requirement
Number of secondary windings	N (N = Meter test positions) Additional windings may be available for the standard meter to improve the accuracy (see Figure 8)
Nominal value of primary voltage	220 V...240 V(other voltages may be specified)
Nominal value of secondary voltage	220 V...240 V(other voltages may be specified)
Operating voltage range	-10 ...+ 15%
Nominal frequency	50 Hz
Operating frequency range	$f_n \pm 2\%$
Secondary burden at each winding	0 VA - 15 VA
Error between primary to secondary winding in the whole operation range. (only required if the standard meter is connected to the primary side of the MSVT)	$\leq \pm 0.1\%, \leq \pm 2 \text{ min}$
Error between each secondary winding in the whole operating range. (if the standard meter is connected to the secondary side of the MSVT)	$\leq \pm 0.05\%, \leq \pm 1 \text{ min}$

2155

2156 **E.5 Total accuracy of MTS with MSVT**

2157 The manufacturer shall provide the accuracy test results of each MSVT over the operating range.

2158 The maximum permissible limits of error are shown in Table F. 2

2159

2160

*Table 33 Maximum permissible limits of error of MTS with MSVT*

Operating range		Maximum permissible limits of error of MTS in % while using MSVT	
Voltage	Current range	PF = 1	PF = 0.5
240 V $\pm$ 10%	50 mA $\leq I \leq$ 120 A	$\delta W_{\max} + 0.07$	$\delta W_{\max} + 0.15$
NOTE: $\delta W_{\max}$ is taken according to Table 27			

2161

2162

2163

2164

2165

2166

2167

2168

2169

2170

2171  
2172  
2173

## Annex F (Normative) Isolating Current Transformer (ICT)

### 2174 F.1 Introduction

2175 Isolating Current Transformers (ICTs) are used for testing direct connected polyphaser meters with  
2176 current and voltage circuits permanently closed in each phase (no means to open the link between  
2177 voltage and current circuits).

### 2178 F.2 Definitions

#### 2179 F.2.1 Three phase closed-link meters

2180 Three phase meters in which the link between voltage and current circuit in all three phases are closed  
2181 permanently or it is not possible to open them for testing  
2182


#### 2183 F.2.2 Isolating Current Transformer (ICT)

2184 Three phase current transformer which has a ratio 1:1 and provides isolation in the current circuits of  
2185 the MTS, between the current source and the MUT.  
2186

### 2187 F.3 Application

2188 Testing of multiple numbers of three phase closed link meters requires isolation in the current circuits.  
2189 Each phase and each meter test position will require an ICT to provide the isolation.  
2190

2191 Note 1: ICTs are optional components of MTS. This mainly depends on the design of meters to be tested. The purchaser should  
2192 specifically mention in his technical requirements along with meter test positions.  
2193



2194  
2195

Figure 9– Testing of 3-phase meters with closed link between the voltage and current circuits

2196 **F.4 Technical requirements**

2197 ICTs shall fulfil the following technical characteristics of Table 34

2198 *Table 34 Technical requirements of ICT*

Technical Parameters	Requirements		
Maximum current ( $I_{max}$ )	120 A per phase (other secondary current according to ratio may be obtained)		
Minimum current	10mA per phase (optionally 1mA)		
Ratio	1:1 (other Ratios may be opted)		
Power rating	Minimum 40 VA per phase at 120 A max.		
	<b>Current Range</b>	<b>Ratio error %</b>	<b>Phase angle error, min</b>
Accuracy	25 mA < $I$ < 150 mA	0.2	10
	150 mA < $I$ < 1 A	0.05	3
	1A < $I$ < 120 A	0.01	1
Power supply of ICT	Shall be decided by the manufacturer		
Attention shall be paid on the sufficiency of maximum VA power rating of amplifier, maximum number of ICTs in each current circuit and required test current.			

2199

2200 The manufacturer and the purchaser may agree on the suitable requirements.

2201 **F.5 Wiring and terminals**2202 The ICT wiring and terminals shall meet the following requirements unless otherwise agreed by  
2203 the purchaser and the manufacturer

- 2204 • The ICT secondary cable should have appropriate length and size to keep the burden low;
- 2205 • The ICT terminals in the MTU shall be marked in each phase, identifying the inputs and the
- 2206 outputs.

2207 **F.6 Total accuracy of MTS with ICT**

2208 The overall error of the MTU while using ICT should not exceed the values specified in Table 35

2209

2210 *Table 35 Maximum permissible limits of error of MTS with ICT*

Test point		Maximum permissible limits of error of MTS in % while using ICT	
Voltage	Current Range	PF =1	PF=0.5
240 V	25 mA < $I$ < 150 mA	$\delta W_{max} + 0.2$	$\delta W_{max} + 0.7$
240 V	150 mA < $I$ ≤ 1 A	$\delta W_{max} + 0.05$	$\delta W_{max} + 0.3$
240 V	1A < $I$ ≤ 120A	$\delta W_{max} + 0.01$	$\delta W_{max} + 0.07$
NOTE 1 $\delta W_{max}$ is taken according to Table 27			
NOTE 2 During the error evaluation, the secondary of the ICT shall be connected to the nominal voltage potential of the MTU (closed link between voltage and current terminals at meters with links to be opened).			
NOTE 3 For active power measurements $\delta W_{max}$ is determined for $\cos \phi = 1$ and 0.5. For reactive power measurements the maximum permissible limits belong to $\delta W_{max}$ at $\sin \phi = 1$ and 0.5			

2211

2212 The manufacturer and the purchaser may agree on the suitable requirements.

Annex G  
(informative)

Wiring samples of test sets and MUTs

G.1 Connection of the reference meter for wiring check / error measurement for testing of Single Phase energy meter




Figure 10–Connection of the reference meter for wiring check / error measurement for testing of Single Phase energy meter

2244

2245 **G.2 Connection of the reference meter for wiring check / error measurement for**  
 2246 **testing of 3 Phase Direct connected energy meter**

2247

2248

2249

2250

2251

2252

2253

2254

2255

2256

2257

2258

2259

2260

2261

2262

2263

2264

2265

2266


2267

2268

2269

2270

2271



2272 *Figure 11–Connection of the reference meter for wiring check / error measurement for testing of*  
 2273 *3 Phase Direct connected energy meter*

2274

2275 **G.3 Connection of the reference meter for wiring check / error measurement for**  
 2276 **testing of 3 Phase CT operated meter (from secondary side)**

2277

2278

2279

2280

2281

2282

2283

2284

2285

2286

2287

2288

2289

2290

2291

2292

2293

2294

2295

2296

2297

2298

2299

2300


2301

2302

2303

2304

2305



2303 *Figure 12–Connection of the reference meter for wiring check / error measurement for testing of*  
 2304 *3 Phase CT operated energy meter (secondary)*

2306 **G.4 Connection of the reference meter for wiring check / error measurement for**  
 2307 **testing of 3 Phase CT operated meter (from primary side-installation**  
 2308 **checking)**

2309

2310

2311

2312

2313

2314

2315

2316

2317

2318

2319

2320

2321

2322

2323

2324

2325

2326

2327

2328

2329

2330

2331

2332

2333

2334

2335

2336


2337

2338

2339

2340


2341



2338 *Figure 15–Connection of the reference meter for wiring check / error measurement for testing of*  
 2339 *3 Phase CT operated energy meter (Primary side-installation checking)*



2342 **G.5 Connection of the reference meter for wiring check / error measurement for**  
 2343 **testing of 3 Phase CT-PT operated meter**



2370

2371 *Figure 16–Connection of the reference meter for wiring check / error measurement for testing of*  
 2372 *3 Phase CT-PT operated energy meter Using TTB)*

2373

2374

2375  
2376  
2377

## Annex H (informative) Maintenance of meter test system

2378

### **H.1 Maintenance of MTS (being used in laboratory)**

2379 For the maintenance of MTS it is must to use in dust free/pollution free environment as  
2380 mentioned parameters for reference condition vide clause Annex B. For in-service check  
2381 of MTS following procedure shall be followed.

- 2382 • Cleaning of filter/vent/Fan of MTS- User shall have planned maintenance whereas  
2383 cleaning of filter/vent /Fan shall be checked.
- 2384 • Tightening of terminals – inspection of MTS connection terminals shall be done  
2385 frequently (once in 3 months- as per planed maintained schedule), tightening shall be  
2386 made in case of loose contact found.
- 2387 • Reference meter of MTS shall be calibrated. The calibration frequency shall be  
2388 decided on the basis of National regulations, its frequency of use and manufacturer  
2389 recommendation.
- 2390 • Other components such as MSVT/ICT also shall be calibrated, in case any  
2391 recommendation from manufacturer is not provided. The calibration frequency shall  
2392 be decided on the basis of National regulations, its frequency of use and manufacturer  
2393 recommendation.
- 2394 • The complete check of the MTS for its overall error shall be made each year according  
2395 to procedure mentioned 14.2 .The measurement shall be taken at each measuring  
2396 position and on basic measurement load points as mentioned in 15.1.2.7. acceptance  
2397 limits defined in Table 35 and Table 33

2398

### **H.2 Maintenance of MTS (being used at Onsite)**

2399 For the maintenance of MTS following procedure shall be followed.

- 2400 • Cleaning of filter/vent/Fan of MTS- User shall have planned maintenance whereas  
2401 cleaning of filter/vent /Fan shall be checked.
- 2402 • Tightening of terminals – inspection of MTS connection terminals shall be done  
2403 frequently (once in 3 months- as per planed maintained schedule), tightening shall be  
2404 made in case of loose contact found.
- 2405 • Connection of the MTS at field shall be made according to procedure defined by  
2406 manufacturer or as per best field testing practices. Wherever earthing of MTS is  
2407 applicable it must be done by suitable means and relevant terminal of MTS.
- 2408 • Up keeping of connection accessories – all connection accessories such as cables,  
2409 terminals shall be check. In case MTS is used with clamp on CTs, Clamp on CT's jaw  
2410 has to be cleaned regularly by fine cotton cloth using corrosion cleaning spray  
2411 regularly to avoid and false measurement.
- 2412 • The MTS shall be calibrated. The calibration frequency shall be decided on the basis  
2413 of National regulation, frequency of use and manufacturer recommendation.

2414

2415

2416  
2417  
2418  
2419  
2420  
2421  
2422  
2423  
2424  
2425  
2426  
2427  
2428  
2429  
2430  
2431  
2432  
2433  
2434  
2435  
2436  
2437  
2438  
2439  
2440  
2441  
2442  
2443  
2444  
2445  
2446  
2447  
2448  
2449  
2450  
2451  
2452  
2453  
2454  
2455  
2456  
2457

## Annex I (informative) Testing of Smart Meter

Test system may have capability to test smart meters complies with IS16444 (part 1 and Part 2) and IS15959 (part 1, 2 and 3). The test shall be performed to prove the functionality of smart meters as per IS16444 (part 1 and 2) and IS15959 (Part 1, 2 and 3),

Following facility may be included as a part of smart meter testing

### **I.1 End to End testing**

Facility to perform End to End testing of smart meter communication infrastructure. The test system hardware and software shall be capable to integrate DCU/receiver/gateway or any other compatible technology to obtain data from communicable energy meter over the cloud or any remote medium. Testing shall be performed by sending command over integrated infrastructure and receive response from the integrated infrastructure. Reporting shall be made for each sent command and received response within test system software. As per clause 10.6.2 of IS16444 (part-1 & 2)

### **I.2 Test for parameter verification as per IS15959 (part 2 and 3) of implemented commands**

Test software, power source measuring system is required to test smart meter for parameter verification as per IS15959 (part 2 and 3) of implemented commands. For meter conformance test facility as per IEC62056 and parameter verification as per IS15959 part 2 and 3.

### **I.3 Recommended test facility as per IS15959 part 2 and 3**

#### **I.3.1 Functional test**

The Test system shall perform all the routine functional test as mentioned below simultaneously on all connected meters on the test bench over the communication port (wired and wireless both).

#### **I.3.1.1 As per Table A30 of IS15959 Part2 and Table 29 of IS15959 Part3**

- **Associations**

The associated test system software shall have facility to check object list of the current association of all connected smart meters on meter test bench.

The test shall be conducted using each association at a time such as Public Client, MR and US (LLS) via communication port by sending OBIS code to read the object list.

The report for each association shall be generated for its accessible attributes i.e. object list using associated test system software.

- **Data read**

The associated test system software shall have facility for selecting any five or more readouts from instantaneous parameter list table of IS15959 Part2 (Table A1 and Table A14) and IS15959 Part3 (Table 1 and Table 14). The user can select/ deselect the random parameters from the instantaneous parameters list table as per requirement of the specification using associated test system software.

The test shall be conducted using any suitable association such as MR and US (LLS) via communication port and sending OBIS code command for individual parameter read (instantaneous Voltage, PF, frequency, energy etc.).

2458 The report for each readout shall be generated for its response from the smart meter  
 2459 using associated test system software.

2460 • **Connect/disconnect**

2461 The associated test system software shall have facility to readout the status of  
 2462 connect disconnect state of all connected meters simultaneously with the test bench.  
 2463 The test shall be conducted using any suitable association such as MR and US (LLS)  
 2464 via communication port and sending OBIS code command for reading the status of  
 2465 load switch.

2466 The report for readout status of load switch shall be generated using associated test  
 2467 system software.

2468 **I.3.1.2 Name plate details**

2469 The associated test bench software shall communicate with the smart meter to read its name  
 2470 plate details as per corresponding table of IS 15959 Part2 (Table A12 and A26), IS15959 Part3  
 2471 (Table 12 and Table 25).

2472  
 2473 The test shall be conducted once the HDLC connection is establish between client and server  
 2474 using any association at a time such Public Client, MR and US(LLS) via communication and  
 2475 sending OBIS code command for name plate details (Serial No. manufacturer year etc.).  
 2476

2477 The report for response i.e. readout of nameplate details from the smart meter for each OBIS  
 2478 code shall be generated using associated test system software.

2479 **I.4 Provision for Burden measurement of the smart meter:**

2480 Facility to measure burden (power consumption) as per clause no 6.10.1 of IS16444 (part 1and  
 2481 2) using suitable methods:

2482 The power consumption in voltage circuit has to be measured in following conditions:

- 2483 • During idle mode of communication module
- 2484 • If a separate module to service a IHD is present
- 2485 • During data transmission per communication module.

2486 Under each of above mentioned condition the burden measurement in the voltage circuit shall  
 2487 be performed

2488 **I.5 Verification of electrical tamper conditions.**

2489 Following Electrical Tamper conditions wherever applicable, shall be created for its occurrence  
 2490 and restoration by the test bench. The created event shall be verified over the optical port and  
 2491 wireless port (Such as RF/GPRS/GSM etc.) for connected meters against the test conditions  
 2492 simulated by operator. These tests shall run in automatic mode simultaneously for all connected  
 2493 meters on test bench. Test shall be performed for both occurrence and restoration of  
 2494 corresponding tamper condition.

- 2495 • Voltage missing
- 2496 • Low voltage in any phase
- 2497 • Voltage unbalance
- 2498 • Current missing
- 2499 • Current reversal
- 2500 • Current unbalance

2501 The associated test bench software shall have the possibility to show the response received  
 2502 over different communication port such as optical and wireless port (Such as RF/GPRS/GSM  
 2503 etc.) on the same connected Smart meter on the test bench.

**2504 I.6 Influence of metrological stress on communication**

2505 Test bench shall be able to create the metrological stress conditions to all connected meters on  
2506 the test bench as mentioned below:-

- 2507 • 10% of 3rd harmonics in phase in current, As per IS13779/14697
- 2508 • 10% 5th harmonics in voltage and 40% of 5th harmonics in current,
- 2509 • 120% of Vref, As per IS13779/14697
- 2510 • I<sub>max</sub> applied to the meter, As per IS13779/14697
- 2511 • 60% of Vref,
- 2512 • frequency variation +10%
- 2513 • frequency variation -10%
- 2514 • low PF such as 0.1PF

2515 All above conditions shall be simulated by test system and the communication of the smart meter  
2516 shall be verified in the influenced conditions through performing any one functional test as per  
2517 above mentioned clause. The associate test system software shall having facility to report any  
2518 discrepancy in the response from meter in normal condition and stressed condition.

**2519 I.7 Automatic testing of Communication:**

2520 The associated test bench system software shall communicate with all connected meters  
2521 mounted on the test bench either as a single communication command OR combination of several  
2522 communication commands included in one test sequence i.e. for meter read out and  
2523 generation/simulation of the tamper conditions/ stress conditions by the test bench. The testing  
2524 shall be carried out in automatic mode to test the communication correctness on communication  
2525 ports between all connected smart meters and the test bench.  
2526

2527

2528

2529

2530

2531

2532

2533

2534

2535  
2536  
2537  
2538  
2539  
2540  
2541  
2542  
2543  
2544  
2545  
2546  
2547  
2548  
2549  
2550  
2551  
2552  
2553  
2554  
2555  
2556  
2557  
2558  
2559  
2560  
2561  
2562  
2563  
2564  
2565  
2566

## Annex J (Informative)

### Software requirement and Validation Points

- Programming facilities for setting and measurement of test parameters. Generation and storage of test programs: the program shall allow generating and storing test programs, with proper identifiers. It shall be possible to adapt the programs to different meter types, nominal values and ranges of current and voltage, and test purposes such as type test, calibration, sampling inspection, initial verification etc. It shall be possible to verify and approve such programs by Legal Metrology Bodies;
- Error compensation (optional): the program shall allow, as agreed and authorized by Legal Metrology Bodies, the compensation of the errors of the MTS and its components (standard meters, MSVTs, ICTs);
- Execution of test programs:
  - the program shall allow automatic or step-by-step execution of test programs;
  - it shall control, display and log the test parameters, such as connection mode, voltages, currents, frequency, phase angles, power factor, power, energy;
  - the program shall be able to send defined data and commands to the meter, as well as to receive and safely store data from the meter using the communication protocol and security features specified;
  - it shall also allow to give instructions to the operator and accept commands and parameters from duly authorized operators at specified points during the execution of the program;
  - the program shall monitor the operation of the MTS during execution of the program and if parameters are outside acceptable limits, give a warning sign or alarm and / or abort the program as appropriate;
  - The program shall provide information on its status, for example “Initialization”, “Measurement running”, “Waiting for input from operator”, “Aborted”, “Finished” etc.
- Evaluation, presentation and archiving results: the program shall automatically calculate the errors; evaluate the results of the tests for each test points, for each meter position, and for defined meter lots. It shall display and print the results and store them safely and with proper identifiers for further processing.
- Some of these aspects are further explained and augmented in the following sub-clauses.

#### 2567 **J.1 Control and supervision of the meter test system by the software**

2568 The software shall perform hardware supervision. Any malfunctions and faults of hardware  
2569 components shall be detected in order to prevent incorrect meter calibrations or test results.

2570  
2571 All data received from the measuring hardware shall be checked for plausibility and consistency. A  
2572 warning or hint message shall be given to the operator in case of implausible or inconsistent results.  
2573 If some measurements cannot be completed, this shall not lead to program interruptions or  
2574 malfunctions as far as this is feasible. Incomplete measurements shall not be evaluated, or if they are  
2575 evaluated, then they shall be marked unambiguously. They shall not affect the presentation and  
2576 storage of the results of other measurements, or if those measurements are affected by any way, they  
2577 shall be marked unambiguously.

## 2578 **J.2 Creation, protection and storage of test programs**

2579 All test programs and parameter sets used for legal metrology purposes shall be easily understandable,  
2580 properly documented, identifiable, adequately protected against inadmissible changes and safely  
2581 stored on suitable storage media (paper or electronic data storage devices). Any changes shall be  
2582 properly documented and, when necessary, approved by the responsible authority. The  
2583 documentation shall include data such as name of the operator, time and date, reason for and list of  
2584 changes, version etc.

2585 Parameter sets used for legally relevant purposes shall be stored with or unambiguously linked to the  
2586 test protocols and may not be changed afterwards.

## 2587 **J.3 Software logs**

2588 The user shall maintain a logbook.

2589 When the software is installed on a given hardware and under a given operating system, or when any  
2590 changes are made, the following information shall be logged:

2591

- 2592 • Date and time of installation or modification;
- 2593 • Name of operator having installed or modified the software;
- 2594 • Program name and version;
- 2595 • Identifiers of the relevant elements of the hardware controlled by the software;
- 2596 • List of changes;
- 2597 • Documentation of how the changes influence the results;
- 2598 • Date and time of authorizing the use of the software by the responsible authority.

2599  
2600 It shall be possible to prevent the use of the software or any modifications for legally relevant purposes  
2601 until its use has been authorized by the responsible authority.

2602

2603 Note 1: These requirements are verifiable by the local certification bodies and depend on the code of practice.

2604

## 2605 **J.4 Software Validation**

2606 Manufacturer shall validate the software as per the functions provided and supply software validation  
2607 compliance certificate to purchaser. Once this compliance certificate is provided no revalidation is  
2608 required.

2609

2610

2611

2612

2613

2614

2615

2616

2617 Annex K (informative)  
 2618 Example of Uncertainty calculation of MTS (without ICT or MSVT)  
 2619 Based of Document NABL141 + GUM  
 2620 The uncertainty of MTS shall be calculated at respective measurement point and an example is  
 2621 elaborated hereunder

<b>Parameter for Uncertainty Calculation:</b>		
<b>Active Energy Measurement</b>		
Range:	<b>115200</b>	<b>W</b>
<b>Description of Device Under calibration :</b>		Reference meter with test bench
Range :	115200.0	W
Value:	115200.0	W
Least Count / Resolution:	0.000	%
Calibrated value:	115200.0	W

2622

2623 **Type A:**

2624 Observation method: reading of %error by MTS

2625 Number of observations: 10

X1	0.016	<del>2626</del>
X2	0.015	%
X3	0.016	%
X4	0.017	%
X5	0.016	%
X6	0.015	%
X7	0.016	%
X8	0.018	%
X9	0.019	%
X10	0.017	%
Mean value:	0.0165	%
Standard deviation	0.00127	%
Repeatability error = (s n-1) / √n	0.00040	%
Degree of freedom (n-1)	9	

2627

2628 **TYPE B**

2629

Source of uncertainty	<u>Uncertainty of reference standard from calibration certificate (B1)</u>
Distribution	<u>Normal</u>
Divisor	<u>1.96</u>
Parameter value B1	<u>0.008%</u>
<b>Ub1</b> Uncertainty due to B1 = B1/Divisor	0.00408%
Degree of freedom	∞

2630



2631

Source of uncertainty	<u>Uncertainty of reference Standard from its specification</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Parameter value B2	<u>0.02%</u>
<b>Ub2</b> Uncertainty due to B2 = B2/Divisor	0.01155%
Degree of freedom	$\infty$

2632

Source of uncertainty	<u>Uncertainty due to Resolution of error indication of MTS</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
resolution	0.001%
Limit	<u>2</u>
Parameter value B3	<u>0.002%</u>
<b>Ub3</b> Uncertainty due to B3 = B3/Divisor	0.00116%
Degree of freedom	$\infty$

2633

Source of uncertainty	<u>Uncertainty due to Temperature co-efficient of Reference meter</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Temperature co-efficient	0.001%/ deg C
Temperature variation limit	<u>4</u>
Parameter value B4	<u>0.004%</u>
<b>Ub4</b> Uncertainty due to B4 = B4/Divisor	0.00231%
Degree of freedom	$\infty$

2634

Source of uncertainty	<u>Uncertainty due to Long term stability of Reference meter</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Parameter value B5	<u>0.01%</u>
<b>Ub5</b> Uncertainty due to B5 = B5/Divisor	0.00577%
Degree of freedom	$\infty$

2635

2636

2637

**Combined Uncertainty**

$U_c$	$= \sqrt{U_a^2 + U_{b1}^2 + U_{b2}^2 + U_{b3}^2 + U_{b4}^2 + U_{b5}^2}$				
$U_a$	$U_{b1}$	$U_{b2}$	$U_{b3}$	$U_{b4}$	$U_{b5}$
0.00040	0.00408	0.01155	0.00116	0.00231	0.00577
<b>Combined Uncertainty <math>U_c</math></b>	<b>0.01379</b>				

2638

2639 **Effective degree of freedom**  $v_{eff} = \frac{u_c^2(y)}{\sum_{i=1}^n \frac{u_i^2(x_i)}{u_i}} = 12530703 (\infty)$

2640 **Coverage factor (k) = 1.96**2641 **Expanded uncertainty (k x  $U_c$ ) =  $\pm 0.02703$** 

2642

2643

**UNCERTAINTY BUDGET**

Source of Uncertainty	Estimate of Quantity	Probability Distribution	Divisor	Standard Uncertainty	Sensitivity Coefficient	Uncertainty Contribution	Degree of freedom
Uncertainty of reference standard from calibration certificate	115200	Normal	1.96	0.00408	1.000	0.00408	$\infty$
Uncertainty of reference Standard from its specification	115200	Rectangular	1.7323	0.01155	1.000	0.01155	$\infty$
Uncertainty due to Resolution of error indication of MTS		Rectangular	1.7323	0.00116	1.000	0.00116	$\infty$
Uncertainty due to Temperature co-efficient of Reference meter		Rectangular	1.7323	0.00231	1.000	0.00231	$\infty$
Uncertainty due to Long term stability of Reference meter		Rectangular	1.7323	0.00577	1.000	0.00577	$\infty$
Repeatability Error, U <sub>a</sub> .		Normal	2	0.00040	1.000	0.00040	9
Combined Uncertainty U <sub>c</sub>	U <sub>c</sub>			0.01379		0.01379	$\infty$
Expanded Uncertainty		k=	1.96	0.01379		0.02703	$\infty$

Final Result =  $0.017 \pm 0.027 \%$

---

2644  
2645  
2646  
2647  
2648  
2649  
2650  
2651  
2652  
2653  
2654

## 2655 Example of Uncertainty calculation of MTS (with ICT)

2656 Based of Document NABL141 + GUM

2657 The uncertainty of MTS shall be calculated at respective measurement point and an example is  
2658 elaborated hereunder

<u>Parameter for Uncertainty Calculation:</u>		
<b>Active Energy Measurement</b>		
Range:	<b>115200</b>	<b>W</b>
<u>Description of Device Under calibration :</u>		Reference meter with test bench
Range :	115200.0	W
Value:	115200.0	W
Least Count / Resolution:	0.000	%
Calibrated value:	115200.0	W

2659

2660 **Type A:**

2661 Observation method: reading of %error by MTS

2662 Number of observations: 10

X1	0.016	<del>2603</del>
X2	0.015	%
X3	0.016	%
X4	0.017	%
X5	0.016	%
X6	0.015	%
X7	0.016	%
X8	0.018	%
X9	0.019	%
X10	0.017	%
Mean value:	0.0165	%
Standard deviation	0.00127	%
Repeatability error = (s n-1) / $\sqrt{n}$	0.00040	%
Degree of freedom (n-1)	<b>9</b>	

2664

2665 **TYPE B**

2666

Source of uncertainty	<u>Uncertainty of reference standard from calibration certificate (B1)</u>
Distribution	<u>Normal</u>
Divisor	<u>1.96</u>
Parameter value B1	<u>0.008%</u>
<b>U<sub>b1</sub></b> Uncertainty due to B1 = B1/Divisor	0.00408%
Degree of freedom	$\infty$

2667

2668

Source of uncertainty	<u>Uncertainty of reference Standard from its specification</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Parameter value B2	<u>0.02%</u>
<b>Ub2</b> Uncertainty due to B2 = B2/Divisor	0.01155%
Degree of freedom	$\infty$

2669

Source of uncertainty	<u>Uncertainty due to Resolution of error indication of MTS</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
resolution	0.001%
Limit	<u>2</u>
Parameter value B3	<u>0.002%</u>
<b>Ub3</b> Uncertainty due to B3 = B3/Divisor	0.00116%
Degree of freedom	$\infty$

2670

Source of uncertainty	<u>Uncertainty due to Temperature co-efficient of Reference meter</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Temperature co-efficient	0.001%/ deg C
Temperature variation limit	<u>4</u>
Parameter value B4	<u>0.004%</u>
<b>Ub4</b> Uncertainty due to B4 = B4/Divisor	0.00231%
Degree of freedom	$\infty$

2671

Source of uncertainty	<u>Uncertainty due to Long term stability of Reference meter</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Parameter value B5	<u>0.01%</u>
<b>Ub5</b> Uncertainty due to B5 = B5/Divisor	0.00577%
Degree of freedom	$\infty$

2672

2673

Source of uncertainty	<u>Uncertainty due to Isolation current transformer (ICT) Ratio and phase error (UPF)</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Parameter value B6 Error Due to ICT	0.01%
<b>Ub6</b> Uncertainty due to B6 = B6/Divisor	0.00577%
Degree of freedom	$\infty$

2674

2675

2676

2677

2678

2679

**(How to calculate Error in Power/Energy at Power factors and due to phase error is elaborated at the end of this example)**

2680 **Combined Uncertainty**

2681

$U_c$	$= \sqrt{U_a^2 + U_{b1}^2 + U_{b2}^2 + U_{b3}^2 + U_{b4}^2 + U_{b5}^2}$					
$U_a$	$U_{b1}$	$U_{b2}$	$U_{b3}$	$U_{b4}$	$U_{b5}$	$U_{b6}$
0.00040	0.00408	0.01155	0.00116	0.00231	0.00577	0.00577
<b>Combined Uncertainty <math>U_c</math></b>	<b>0.01495</b>					

2682

2683 **Effective degree of freedom**  $v_{eff} = \frac{u_{c(y)}^4}{\sum_{i=1}^n \frac{u_{(xi)}^4}{v_i}} = 17321243 (\infty)$ 2684 **Coverage factor (k) = 1.96**2685 **Expanded uncertainty (k x  $U_c$ ) = ± 0.02930**

2686

2687

**UNCERTAINTY BUDGET**

Source of Uncertainty	Estimate of Quantity	Probability Distribution	Divisor	Standard Uncertainty	Sensitivity Coefficient	Uncertainty Contribution	Degree of freedom
Uncertainty of reference standard from calibration certificate	115200	Normal	1.96	0.00408	1.000	0.00408	$\infty$
Uncertainty of reference Standard from its specification	115200	Rectangular	1.7323	0.01155	1.000	0.01155	$\infty$
Uncertainty due to Resolution of error indication of MTS		Rectangular	1.7323	0.00116	1.000	0.00116	$\infty$
Uncertainty due to Temperature co-efficient of Reference meter		Rectangular	1.7323	0.00231	1.000	0.00231	$\infty$
Uncertainty due to Long term stability of Reference meter		Rectangular	1.7323	0.00577	1.000	0.00577	$\infty$
Uncertainty due to Isolation current transformer (ICT) Ratio and phase error (UPF)		Rectangular	1.7323	0.00577	1.000	0.00577	$\infty$

Repeatability Error, Ua.		Normal	2	0.00040	1.000	0.00040	9
Combined Uncertainty Uc	U <sub>c</sub>			0.01495		0.01495	∞
Expanded Uncertainty		k=	1.96	0.01495		0.02930	∞

**Final Result =** 0.017 ± 0.029 %

2688  
2689  
2690  
2691  
2692

**For example if we include phase error of ICT in the uncertainty calculation following will be the type B factor (B5)**

Source of uncertainty	<u>Uncertainty due to Isolation current transformer (ICT) Ratio and phase error (0.5Lag)</u>
Distribution	<u>Rectangular</u>
Divisor	<u>1.7323</u>
Parameter value B5 Error Due to ICT	0.06% (0.01%+0.05%)
<b>Ub5</b> Uncertainty due to B5 = B5/Divisor	0.034636%
Degree of freedom	∞

2693  
2694  
2695

**Note: in above case Error in energy measurement due to phase error of ICT will also be considered. For eg.**

Applied Voltage		320	V 2696
Applied Current		120	Amp
Power factor (COS Ø)		0.50	lag
Three phase active power		57600	W
additional error in minutes		1	Min
phase angle		0.01666667	deg
Apparent power		115200	VA
Angle		60.0000	deg
Additional error		60.01666667	deg
PF incl additional error		0.49975	
Active power calc (PF*S)		57570.97677	
%error		-0.050	
Error % in reported power		± 0.050	%

2697  
2698

**Similarly in case of MSVT, the additional error in power/energy measurement shall be calculated.**