

(PREVIEW)

Indian Standard

**SPECIFICATION FOR
EMERGENCY LIGHTING UNITS**

1. SCOPE

1.1 This standard covers the requirements and methods of tests for emergency lighting units fitted with incandescent, fluorescent lamps and other discharge lamps.

1.2 The emergency lighting units covered in this standard are suitable for providing the emergency lighting between 1 to 3 hours duration and employ automatic switching on/off devices in the event of failure/restoration of normal power supply.