

केन्द्रीय मुहर विभाग - III

हमारा संदर्भ- केन्द्रीय मुहर विभाग-3/16: IS 335

12.10.2018

विषय: अनुपालन हेतु एस आई टी

सभी शाखा कार्यालय से आग्रह है कि एस आई टी का अनुपालन सुनिश्चित करें।

(अलिस्मिता खाग)
वैज्ञानिक 'बी' (सी एम डी-III)

प्रमुख (सी एम डी-III)

सभी क्षेत्रीय/शाखा कार्यालय
आई टी एस विभाग — बीआईएस इंटरनेट पर अपलोड करने हेतू

CENTRAL MARKS DEPARTMENT-III

Our Ref: **CMD-3/16: IS 335**

12.10.2018

Subject: SIT for IS 335

This has reference to the subject mentioned above.

BOs may kindly ensure implementation of the SIT.

Alismita Khag
Sc.B (CMD III)

Head (CMD - III)

Circulated to: All ROs/BOs

Copy to: ITS for hosting on Intranet

**SCHEME OF INSPECTION AND TESTING FOR CERTIFICATION OF
NEW INSULATING OILS
ACCORDING TO IS 335:2018**

1. LABORATORY - A laboratory shall be maintained which shall be suitably equipped (as per the requirement given in column 2 of Table 1) and staffed, where different tests given in the specification shall be carried out in accordance with the methods given in the specification.

1.1 The manufacturer shall prepare a calibration plan for the test equipment.

2. TEST RECORDS – The manufacturer shall maintain test records for the tests carried out to establish conformity.

3. LABELLING AND MARKING – As per the requirements of IS 335:2018.

4.1 REPACKING OF NEW INSULATING OIL – If a firm is doing only re-packing of new insulating oils at their premises, then each consignment of new insulating oil received shall be accompanied by a certificate bearing the Standard Mark of the Bureau.

4.2 LEVELS OF CONTROL - The tests as indicated in column 1 of [Table 1](#) and the levels of control in column 3 of [Table 1](#), shall be carried out on the whole production of the factory which is covered by this plan and appropriate records maintained in accordance with paragraph 2 above. In case a license is issued only for re-packing of new insulating oil, then the tests as indicated in [Table 2](#) of SIT and the levels of controls specified therein, shall be applicable, instead of [Table 1](#) of SIT.

5. CONTROL UNIT – For the purpose of Table 1 of this Scheme, each class of new insulating oil produced in a day shall constitute a control unit.

6. REJECTIONS – Disposal of non-conforming product shall be done in such a way so as to ensure that there is no violation of provisions of BIS Act, 2016.

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6.1	Viscosity	6.1, Table 1, Table 2	IS 335	R	1	Each control unit	If the insulating oil fails in any requirement, two more samples shall be drawn from the same control unit and tested for those particular requirements and the control unit shall be rejected if there is any further failure. The control unit so rejected may be suitably re-processed and the defects rectified. Such re-processed control unit may be marked when tested again in accordance with the Scheme and found conforming to the requirements of the Specification.
6.2	Pour Point	6.2, Table 1, Table 2	IS 335	R	1		
6.3	Water Content	6.3, Table 2	IS 335	R	1		
6.4	Breakdown Voltage	6.4, Table 2	IS 335	R	1		
6.5	DDF at 90 °C	6.5, Table 2	IS 335	S	1	Once in three months from each class of oil	
6.6	Appearance	6.6, Table 2	IS 335	R	1	Each control unit	
6.7	Acidity	6.7, Table 2	IS 335	S	1		
6.8	Interfacial Tension (IFT)	6.8, Table 2	IS 335	R	1		
6.9, 7.1	Sulphur Content	6.9, 7.1 Table 2	IS 335	S	1	Once in three months from each class of oil	
6.10	Corrosive Sulphur and Potentially Corrosive Sulphur	6.10, Table 2	IS 335	S	1		
6.11	Additives	6.11, Table 2	IS 335	R	1	Each control unit	
6.12, 7.1	Oxidation Stability	6.12, 7.1 Table 2	IS 335	S	1	Once in six months from each class of oil	
6.13, 7.3	Gassing Tendency	6.13, 7.3 Table 2	IS 335	S	1	Once in three months from each class of oil	

TABLE 1

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6.14, 7.2	Electrostatic Charging Tendency (ECT)	6.14, 7.2 Table 2	IS 335	S	1	Once in six months from each class of oil	If the insulating oil fails in any requirement, two more samples shall be drawn from the same control unit and tested for those particular requirements and the control unit shall be rejected if there is any further failure. The control unit so rejected may be suitably re-processed and the defects rectified. Such re-processed control unit may be marked when tested again in accordance with the Scheme and found conforming to the requirements of the Specification.
6.15	Flash Point	6.15, Table 2	IS 335	R	1	Each control unit	
6.16	Density	6.16, Table 2	IS 335	R	1		
6.17	Polycyclic Aromatics (PCA)	6.17, Table 2	IS 335	S	1		
6.18	Polychlorinated Biphenyls (PCB)	6.18, Table 2	IS 335	S	1		
6.19	2-Furfural (2-FAL) and Related Compounds Content	6.19, Table 2	IS 335	S	1	Once in six months from each class of oil	
6.20	Particle Content	6.20, Table 2	IS 335	S	1		
6.21	DBDS Content	6.21, Table 2	IS 335	S	1		
6.22	Stray Gassing of Oil	6.22	IS 335	S	1		

Note- 1: Sub-contracting is permitted to a laboratory recognized by the Bureau or Government laboratories empanelled by the Bureau.

Note- 2: Levels of control given in column 3 are only recommendatory in nature. The manufacturer may define the control unit/batch/lot and submit his own levels of control in column 3 with proper justification for approval by BO Head.

TABLE 2
(FOR REPACKING UNIT)

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6.1	Viscosity	6.1, Table 2	IS 335	R	1	*	If the insulating oil fails in any requirement, two more samples shall be drawn from the same consignment and tested for those particular requirements and the consignment shall be rejected if there is any further failure. The consignment so rejected may be returned to the supplier for re processing.
6.2	Pour Point	6.2, Table 2	IS 335	R	1		
6.3	Water Content	6.3, Table 2	IS 335	R	1		
6.4	Breakdown Voltage	6.4, Table 2	IS 335	R	1		
6.5	DDF at 90 °C	6.5, Table 2	IS 335	S	1	Once in six months from each class of oil received from each manufacturer	
6.6	Appearance	6.6, Table 2	IS 335	R	1	*	
6.7	Acidity	6.7, Table 2	IS 335	S	1		
6.8	Interfacial Tension (IFT)	6.8, Table 2	IS 335	R	1		
6.9, 7.1	Sulphur Content	6.9, 7.1 Table 2	IS 335	S	1	Once in six months from each class of oil received from each manufacturer	
6.10	Corrosive Sulphur and Potentially Corrosive Sulphur	6.10, Table 2	IS 335	S	1		
6.11	Additives	6.11, Table 2	IS 335	R	1	*	
6.12, 7.1	Oxidation Stability	6.12, 7.1 Table 2	IS 335	S	1	Once in a year from each class of oil received from each manufacturer	
6.13, 7.3	Gassing Tendency	6.13, 7.3 Table 2	IS 335	S	1	Once in six months from each class of oil received from each manufacturer	

TABLE 2
(FOR REPACKING UNIT)

(1)				(2)	(3)		
Test Details				Test equipment requirement R: required (or) S: Sub-contracting permitted	Levels of Control		
Cl.	Requirement	Test Methods			No. of Sample	Frequency	Remarks
		Clause	Reference				
6.14, 7.2	Electrostatic Charging Tendency (ECT)	6.14, 7.2 Table 2	IS 335	S	1	Once in a year from each class of oil received from each manufacturer	If the insulating oil fails in any requirement, two more samples shall be drawn from the same consignment and tested for those particular requirements and the consignment shall be rejected if there is any further failure. The consignment so rejected may be returned to the supplier for re processing.
6.15	Flash Point	6.15, Table 2	IS 335	R	1	*	
6.16	Density	6.16, Table 2	IS 335	R	1		
6.17	Polycyclic Aromatics (PCA)	6.17, Table 2	IS 335	S	1		
6.18	Polychlorinated Biphenyls (PCB)	6.18, Table 2	IS 335	S	1		
6.19	2-Furfural (2-FAL) and Related Compounds Content	6.19, Table 2	IS 335	S	1		
6.20	Particle Content	6.20, Table 2	IS 335	S	1		
6.21	DBDS Content	6.21, Table 2	IS 335	S	1		
6.22	Stray Gassing of Oil	6.22	IS 335	S	1		

* From each class of New Insulating Oil produced in a day by each manufacturer, in each consignment received.

Note- 1: Sub-contracting is permitted to a laboratory recognized by the Bureau or Government laboratories empanelled by the Bureau.

Note- 2: Levels of control given in column 3 are only recommendatory in nature. The manufacturer may define the control unit/batch/lot and submit his own levels of control in column 3 with proper justification for approval by BO Head.